FUNCTIONAL SERVICING AND STORMWATER MANAGEMENT REPORT

FOR

WINDMILL DEVELOPMENT GROUP LTD. DOMTAR LANDS REDEVELOPMENT – PHASE 1

CITY OF OTTAWA

PROJECT NO.: 14-717

SEPTEMBER 2017 – REV 2 © DSEL

FUNCTIONAL SERVICING AND STORMWATER MANAGEMENT REPORT FOR WINDMILL DEVELOPMENT GROUP LTD. DOMTAR LANDS REDEVELOPMENT – PHASE 1

SEPTEMBER 2017 – REV 2

TABLE OF CONTENTS

1.0	INTRODUCTION	1
1.1	Existing Conditions	3
1.2	Required Permits / Approvals	4
1.3	Pre-consultation	4
2.0	GUIDELINES, PREVIOUS STUDIES, AND REPORTS	5
2.1	Existing Studies, Guidelines, and Reports	5
3.0	WATER SUPPLY SERVICING	6
3.1	Existing Water Supply Services	6
3.2	Water Supply Servicing Design	7
3.3	Water Supply Conclusion	9
4.0	WASTEWATER SERVICING	10
4.1	Existing Wastewater Services	10
4.2	Wastewater Design	11
4.3	Wastewater Servicing Conclusion	12
5.0	STORMWATER MANAGEMENT	13
5.1	Existing Stormwater Services	13
5.2	Post-development Stormwater Management Targets	13
5.3	Stormwater Management System	13
5.4	Stormwater Servicing Conclusions	14
6.0	EROSION AND SEDIMENT CONTROL	15
7.0	UTILITIES	16
8.0	CONCLUSION AND RECOMMENDATIONS	17

FIGURES

Figure 1 Site Location

TABLES

Table 1 Water Supply Design Criteria Table 2 Water Demand - Historical Site Conditions Table 3 Water Demand – Proposed Site Conditions Table 4 Model Simulation Output Summary – Phase 1 Table 6 Wastewater Design Criteria Table 7 Summary of Anticipated Wastewater Discharge

APPENDICES

Appendix A	Servicing Check List / Pre-consultation
Appendix B	Water Supply Calculations
Appendix C	Wastewater Collection Calculations
Appendix D	Stormwater Management Calculations
Drawings / Figures	

FUNCTIONAL SERVICING AND STORMWATER MANAGEMENT REPORT FOR WINDMILL DEVELOPMENT GROUP LTD. DOMTAR LANDS REDEVELOPMENT – PHASE 1

CITY OF OTTAWA

SEPTEMBER 2017 – REV 2

PROJECT NO.: 14-717

1.0 INTRODUCTION

David Schaeffer Engineering Ltd. (DSEL) has been retained to prepare a Functional Servicing and Stormwater Management Report (FSR) for the proposed Domtar Lands Redevelopment in support of Windmill Development Group's application for Site Plan Control (SPC) for Phase 1 of the development.

The subject property consist of lands within the City of Ottawa urban boundary. The applicant also owns lands within Gatineau, Quebec that are planned to be designed and constructed concurrently with the proposed development within Ottawa. The Ontario and Quebec developments will be serviced independently, the following FSR is solely in support of the Phase 1 of the Ontario Site.

As illustrated in *Figure 1*, the subject property is located on parts of Chaudière and Albert Islands within the Ottawa River, it is accessible via Booth Street and the Chaudière Bridge. The following FSR is to support the development of Phase 1 only, as indicated in *Figure 1*, which measures approximately *1.09 ha*. Phase 1 is generally bounded by Booth Street to the east, Albert Island to the south and Energy Ottawa owned lands on Chaudière Island to the north, see site plan in *Drawings/Figures* for limits of Phase 1.

The subject site is currently comprised of thirteen parcels of land with two civic addresses, 3 & 4 Booth Street, herein referred to as the site.

FUNCTIONAL SERVICING AND STORMWATER MANAGEMENT REPORT WINDMILL DEVELOPMENT GROUP LTD. DOMTAR LANDS REDEVELOPMENT – PHASE 1

SEPTEMBER 2017 - REV 2



Figure 1: Site Location

The proposed development of Phase 1 involves the construction of a total of **3523m**² of retail, commercial and office space, approximately **71** residential units and associated roadways, surface and underground parking.

The objective of this report is to support the application for Site Plan Approval by providing sufficient detail to demonstrate that the development is supported by existing municipal servicing infrastructure and that the contemplated site design conforms to current City of Ottawa design standards, in addition to, state of the art design strategies to meet the client's "One Planet" strategy.

Servicing and grading presented in the detailed design of Phase 1 is consistent with the *Master Servicing Plan – Domtar Redevelopment Lands*, prepared by DSEL (March 2016), servicing and grading will be updated to reflect any future changes to the Master Servicing Plan.

1.1 Existing Conditions

A detailed survey was completed by Fairhall Moffat & Woodland Limited on December 11, 2014. As per the topographic survey, elevations vary from **46.20m** at the east edge of the Chaudière Island to **54.85m** to the west.

The subject site currently consists of several vacant industrial facilities, historically part of a paper mill that was in operation until 2007.

The site is made up of existing building footprint and gravel covered vacant lands. A portion of the Chaudière Island lands west of Booth Street consist of grassed and landscaped area.

Sewer and watermain mapping, along with as-recorded drawings, collected from the City of Ottawa indicate that the following services exist across the property frontages within the adjacent municipal right-of-ways:

Booth Street

- 203mm diameter ductile iron watermain (North of Middle Street)
- > 305mm diameter PVC watermain (South of Middle Street)
- > 250mm diameter sanitary sewer
- > 1200mm diameter storm sewer

Middle Street

- > 203mm diameter ductile iron watermain
- 250mm diameter sanitary sewer
- > 300mm diameter storm sewer
- Sanitary pumping station northwest corner of the Portage Bridge and Middle Street

Portage Bridge

- > 100mm diameter sanitary forcemain
- Sanitary pumping station, northwest of the Portage Bridge and Wellington Street intersection
- 450mm diameter storm sewer

1.2 Required Permits / Approvals

Development of the site is subject to the City of Ottawa Planning and Development Approvals process. The City of Ottawa must approve detailed engineering design drawings and reports, prepared to support the proposed development plan.

1.3 **Pre-consultation**

Pre-Consultation was conducted with the City of Ottawa and Rideau Valley Conservation Authority via email, along with a formal pre-consultation meeting held between the client and City staff on December 20, 2013. Correspondence and a servicing guidelines checklist are included in *Appendix A*.

2.0 GUIDELINES, PREVIOUS STUDIES, AND REPORTS

2.1 Existing Studies, Guidelines, and Reports

The following studies were utilized in the preparation of this report.

- Ottawa Sewer Design Guidelines, City of Ottawa, SDG002, October 2012. (City Standards)
- Ottawa Design Guidelines Water Distribution City of Ottawa, October 2012 (Water Supply Guidelines)
- \succ
- Technical Bulletin ISD-2010-2
 City of Ottawa, December 15, 2010.
 (ISD-2010-2)
- Technical Bulletin ISDTD-2014-2 City of Ottawa, May 27, 2014. (ISDTD-2014-2)
- Stormwater Planning and Design Manual, Ministry of the Environment, March 2003. (SWMP Design Manual)
- Ontario Building Code Compendium Ministry of Municipal Affairs and Housing Building Development Branch, January 1, 2010 Update (OBC)
- Low Impact Development Stormwater Management Planning and Design Guide

Toronto Region Conservation Authority (TRCA) & Credit Valley Conservation Authority (CVC), 2010 (*LID Manual*)

Master Servicing Study – Domtar Redevelopment Lands DSEL July 2015 (MSS – Domtar Redevelopment)

3.0 WATER SUPPLY SERVICING

3.1 Existing Water Supply Services

The subject property lies within the City of Ottawa 1W pressure zone. A 300mm diameter watermains exist within the Booth Street crossing underneath the Bronson Channel to connect to a 203mm watermain within Middle Street. The subject site is fed by 203mm watermains within Middle Street and Booth Street (North of the Bronson Channel). Drawings *EX-1* illustrate the existing water distribution network.

Historically, the site would have been serviced via several 203mm diameter service laterals connecting to the 203mm diameter watermain within Booth Street. As discussed previously, the historical conditions of the site up until 2007 was entirely industrial.

Table 1 summarizes the *Water Supply Guidelines* employed in the preparation of the historical and proposed water demand estimate.

Water Supply Design Criteria			
Design Parameter	Value		
Industrial – Heavy	55,000 L/gross ha/d		
Restaurant Demand	125 L/seat/d		
Residential Average Apartment Demand	1.8 person/unit		
Residential Daily Average	350 L/person/d		
Residential Maximum Daily Demand*	Varies		
Residential Maximum Hourly*	Varies		
Commercial-Floor space	2.5 L/m²/d		
Commercial-Industrial Maximum Daily Demand	1.5 x avg. day L/gross ha/d		
Commercial-Industrial Maximum Hour Demand	1.8 x avg. day L/gross ha/d		
Minimum Watermain Size	150mm diameter		
Minimum Depth of Cover	2.4m from top of watermain to finished grade		
During normal operating conditions desired	350kPa and 480kPa		
operating pressure is within			
During normal operating conditions pressure must	275kPa		
not drop below			
During normal operating conditions pressure shall	552kPa		
not exceed			
During fire flow operating pressure must not drop	140kPa		
below			
* Residential Max. Daily and Max. Hourly peaking factors per MOE Guidelines for Drinking-Water Systems Table 3-3, see calculations in Appendix B for peaking factors for Phase 1 and Phase 1A			
*** Table updated to reflect ISD-2010-2	nase in		

Table 1 Water Supply Design Criteria

Table 2 Summarizes the historical water demand based on the current City of Ottawa Water Supply Guidelines.

Water Demand - Historical Site Conditions		
Design Parameter	Historical Water Demand ¹	
	(L/min)	
Average Daily Demand	216.6	
Max Day	324.8	
Peak Hour	584.7	
	ations per <i>Water Supply</i> Appendix B for detailed	

Table 2

3.2 Water Supply Servicing Design

The proposed water servicing will consist of a new 300mm watermain within Booth Street. connected at the 300mm by 200mm tee within Middle Street. A watermain connection across the Portage Bridge will connect to the exiting watermain within Middle Street. As the total water demand is less than 50m³/day, Phase 1 will be constructed prior to the redundant connection across the Portrage Bridge and will be serviced by the existing 305mm watermain running under the Bronson Channel.

The existing watermain connection underneath the Bronson Channel that feeds the subject property was constructed in 1995. As per City recommendations a leakage test will not be required, see correspondence in **Appendix A**.

Each building will be serviced independently via connections to the private watermain network. Fire hydrants will be provided internally to provide adequate fire protection coverage as per the Water Supply Guidelines. Fire flow for the proposed and repurposed building was estimated with the FUS. Block 205-A resulted in the highest fire flow of 17,000 L/min, see Appendix B for detailed calculations. The pipe sizes have been sufficient sized to provide fire flow for all buildings in the ultimate condition.

To provide additional redundancy for fire protection in Phase 1, 2 dry hydrants are provided, see drawing **SSP-1** for locations of the hydrants. In the case where fire protection is required and the primary source of water on Booth is interrupted, the above described dry hydrants will be used to draw water directly from the Ottawa River to provide fire protection to the buildings

Table 3 summarize the anticipated water demand and boundary conditions for the proposed development, calculated using the Water Supply Guidelines.

Table 3					
Water Demand – Proposed Site Conditions					
Design Parameter	Anticipated Demand ¹ Phase 1 (L/min)	(m H₂C Connec	ndary ition ²) / kPa) ction @ Street	Conc (m H₂0 Conne Welli	ndary lition ²) / kPa) ction @ ngton reet
Average Daily Demand	34.7	61.7	605.3	58.6	574.9
Max Day + Fire Flow	146.5 + 17,000 =				
	17,146.5	50.3	493.4	52.5	515.0
Peak Hour	224.2	54.7	536.6	51.6	506.2
 Water demand calculation per <i>Water Supply Guidelines</i>. See <i>Appendix B</i> for detailed calculations. Boundary conditions supplied by the City of Ottawa for demands as indicated in correspondence. Assumed ground elevation @ Booth Street <i>53.4m</i>, @ Wellington Street <i>56.5m</i>, See <i>Appendix B</i>. 					

The boundary conditions summarized in *Table 3* are based water demands for phase 1 development. After further information was received on commercial, retail, office and community space, the resulting water demands decreased.

EPANet was utilized to determine the availability of pressures throughout the system during average day demand, max day plus fire flow, and peak hour demands. Additionally, the model was used to assess maximum pressure for the future conditions. This static model determines pressures based on the available head provided by the City of Ottawa boundary conditions. The model utilizes the Hazen-Williams equation to determine pressure drop, while the pipe properties have been selected in accordance with *Water Supply Guidelines*. The model was prepared to assess the available pressure at the finished first floor of each building.

To ensure that adequate pressure is available during the fire flow scenario, additional hydrants have been proposed to provide fire protection. Fire protection for Block 205-A will be provided by both hydrant FH 2 & FH 3. Both were modeled assuming a flow of **8,500 L/min** totaling **17,000 L/min** as per the **FUS** estimated fire demand.

Table 4 summarizes the pressures in each scenario including the fire flow scenario yielding the lowest pressure. **Appendix B** contains output reports and model schematics for each scenario.

Table 4 Model Simulation Output Summary – Phase 1				
Location	Average Day (kPa)	Max Day + Fire Flow (kPa)	Peak Hour (kPa)	
Block 205-A	589.1	312.9	520.1	
Block 208	590.1	342.2	521.2	
FH 3	597.4	207.0	528.6	
FH 4	613.4	204.1	544.5	
Note: FH3 & FH4 modelled as service Block 206	suming a fire flow of 10	,000 L/min demand at e	ach hydrant to	

As demonstrated in **Table 4**, the anticipated pressures during the average day simulations are higher than allowable pressures in **Table 1**. Pressure reducing valves are recommended. The recommended pressures from the **Water Supply Guidelines** are respected during peak hour and max day + fire flow scenarios.

The model predicted that water will flow in all areas of the system and no 'dead' zones were found.

It should be noted that the pressures in **Table 4** represent the available pressure at the building meter. The mechanical designer must ensure that the internal distribution system is designed in accordance with the OBC.

3.3 Water Supply Conclusion

The site will be serviced by a connection to the Booth Street watermain as the total water demand for Phase 1 is less than 50m³/day a single connection is proposed.

An EPANet model was prepared based on boundary conditions received from the City of Ottawa. Pressures in average day and peak hour scenario exceed the recommended pressures as per the *Water Supply Guidelines,* pressure reducing valves are recommended. The proposed system is sufficiently sized to provide fire flow at minimum pressures.

4.0 WASTEWATER SERVICING

4.1 Existing Wastewater Services

The subject site, based on City of Ottawa's infrastructure maps & utility plans, is connected to the 250mm sanitary sewer within Middle Street. To accomplish this connection, a series of pumps stations direct flow to a single private pump station within the subject lands east of Booth Street. This existing private pump station discharge via a forcemain to the Middle Street sanitary sewer. A figure, prepared by Greenough Environmental Consulting Inc. for Domtar Inc., showing the location of on-site pump stations and forcemains can be found in *Drawings/Figures.* The Middle Street sanitary sewer discharges via gravity flow to an existing pump station northwest of the intersection of Middle Street and The Portage Bridge. A 100mm forcemain directs sanitary flow to a second pump station to the south, across the Bronson Channel. The south pump station discharges via a 100mm forcemain to the 1830mm diameter interceptor sewer (IS) north of Sparks Street. Both pump stations are owned and operated by the NCC and service commercial and recreational development on Victoria Island.

Refer to drawings *EX-1* for existing wastewater services.

A field investigation of the existing main pump station on Chaudière Island was completed by DSEL on June 30, 2015. The field investigation was to determine the existing condition of the pump station including wet well size, start and stop elevations, pump type and model and existing pump discharge. A flow rate of **6.7** L/s was observed during operation of the pump through the existing flow meter connected to the forcemain. The pump curve based on the existing pumps was obtained from the manufacturer. The pump curve suggests that the observed flow rate would result in the pump operating in an overloaded condition. See existing pump curve in **Appendix C** a technical memo by HMM.

Table 5 summarizes the *City Standards* employed in the estimate of available capacity within the municipal wastewater sewer systems, and in the calculation of wastewater flow rates for the historical and proposed development.

A capacity analysis was completed by JFSA to determine the capacity of the existing sanitary sewer within the Ville De Gatineau to convey the flow from Zibi Ontario and Zibi Gatineau. It was concluded there is sufficient capacity within the sewer to convey the ultimate flow from the subject site, see *Appendix A* for the full report.

Wastewater Design Criteria				
Design Parameter Value Value				
Industrial-Heavy	55,000 L/gross ha/d			
Restaurant Demand	125 L/seat/d			
Industrial Peaking Factor*	4.75			
Residential 1 Bedroom Apartment Demand	1.4 person/unit			
Residential 2 Bedroom Apartment Demand	2.1 person/unit			
Residential Average Apartment Demand	1.8 person/unit			
Residential Daily Average	350 L/person/d			
Commercial Floor Space	5 L/m²/d			
Peaking Factor	Harmon's Peaking Factor. Max 4.0, Min 2.0			
Infiltration and Inflow Allowance	0.28L/s/ha			
Sanitary sewers are to be sized employing the Manning's Equation	$Q = \frac{1}{n} A R^{\frac{2}{3}} S^{\frac{1}{2}}$			
Minimum Sanitary Sewer Lateral	135mm diameter			
Minimum Manning's 'n'	0.013			
Minimum Depth of Cover	2.5m from crown of sewer to grade			
Minimum Full Flowing Velocity	0.6m/s			
Maximum Full Flowing Velocity	3.0m/s			
* Industrial Peaking Factor determined as per MOE Guidelines for Flow Peaking Factors Graph. Extracted from Sections 4 and 6 of the City of Ottawa Sewer Des				

Table 5

4.2 Wastewater Design

Wastewater servicing will be accomplished for Phase 1 through a centralized temporary pump station located within Building 525. A proposed forcemain will convey flow from the pump station across the Union Bridge span to the gravity sanitary sewers part of Zibi Gatineau Phase 1 development. Wastewater will ultimately be directed to existing sanitary sewers within Rue Laurier. The Ville de Gatineau has confirmed that the Phase 1 and ultimate flow can be directed to the existing sanitary sewers, pending confirmation of the capacity of the 900mm sanitary sewer within Rue Laurier, see Appendix A for correspondence.

Individual buildings within the proposed development will be serviced internally via gravity draining sanitary sewer network; detailed layout and sizing is shown by drawing SSP-1 included with this report.

Table 6 below summarizes the anticipated wastewater discharge from the proposed development based on criteria found in Table 5.

Table 6 Summary of Anticipated Wastewater Discharge		
Design Parameter	Phase 1 Flow (L/s)	
Average Dry Weather Flow Rate	0.8	
Peak Dry Weather Flow Rate	2.4	
Peak Wet Weather Flow Rate	2.7	

A conceptual pump station design report has been prepared by Hatch, dated April 2016. The pump station design contemplates a peak flow rate of **11.9 L/s** for Phase 1. Further information on the scope of Phase 1 proposed sanitary discharge from has lowered this to a peak wet weather flow rate of **2.7 L/s**. The design contemplates a 100mm sanitary forcemain directing flow from the pump station to the gravity sewers within Zibi Gatineau. As discussed in **Section 4.1**, there is sufficient capacity within the Gatineau sanitary system to convey the ultimate flows form the Zibi Ontario and Zibi Gatineau developments. The design contemplates new pumps and re-using the existing wet well located within Building 525.

In the event of service interruption, mobile pumper trucks will be employed until the service is restored.

For further detail on the proposed pump station design, please refer to Conceptual Design Report prepared by Hatch found in *Appendix C*.

4.3 Wastewater Servicing Conclusion

Existing sanitary servicing is provided by a centralized pump station located on Chaudière Island, discharging to a series of gravity and pump stations until eventually discharging to the Interceptor Sewer.

The proposed development will discharge to a temporary pump station located within Building 525 and be conveyed via a 100mm forcemain to the gravity sewers within Zibi Gatineau's site, eventually discharging to the Ville de Gatineau sewers within Rue Laurier.

The proposed wastewater design conforms to all relevant *City Standards*.

5.0 STORMWATER MANAGEMENT

5.1 Existing Stormwater Services

Stormwater runoff from the existing subject property is directed uncontrolled to the Ottawa River. The major and minor flow is directed to the Ottawa River overland with a small portion of flow directed by catch basins along Booth Street. The site currently consists of varying sloped topography (0.5% to >5%) and mostly impervious building footprint or associated parking area.

The existing site contains no stormwater management quality controls or controls for flow attenuation.

Runoff from the site is directed to the Ottawa River directly downstream of the Chaudière Falls which has a drop and breadth of 15 and 60m, respectively. The dam is used by Hydro Ottawa and Hydro-Quebec to produce electricity. The dam is also monitored and controlled by the Ottawa River Regulation and Planning Board for flood control.

5.2 Post-development Stormwater Management Targets

Stormwater management requirements for the proposed development are based on relevant *City Standards* and pre-consultation with City of Ottawa staff. It has been established that the following criteria apply:

- Increase to flood risk and flood levels in the Ottawa River will not be impacted by the proposed development and therefore stormwater quantity controls are not required
- Based on the consultation with the City & RVCA, stormwater quality controls will be required to achieve an "enhanced" level of quality control as per the SWMP Design Manual, 80% reduction in Total Suspended Solids (TSS) prior to release to the Ottawa River

5.3 Stormwater Management System

The stormwater management system will consist of a private storm sewer system, outlasting at the north edge of Chaudière Island, east of Booth Street.

The private stormwater sewer system has been sized to convey an uncontrolled 5-year storm runoff rate in accordance with the *City Standards*. Detailed layout and sizing is illustrated by *SSP-1* is included with this report.

The Rational Method was utilized to calculate the runoff from the storm sewer catchment areas; Rational Method "C" values for the catchment areas were derived using "*Table 5.7 Runoff Coefficients for Various Soil Conditions*" from the *City Standards*.

To meet the specified stormwater quality criteria an end of pipe oil/grit separator (OGS) unit will be designed to provide a TSS reduction of at least 80% achieving an "enhanced" level of quality control as per the *SWMP Design Manual*. Building runoff is considered clean, therefore, buildings adjacent to the shoreline will have roof leaders discharge directly the Ottawa River. It is proposed to provide a Stormceptor *STC4000* (or approved equivalent) prior to discharge to the Ottawa River.

Buildings adjacent to the Ottawa River will discharge clean roof runoff directly to the River without additional quality control as per pre-consultation with the RVCA.

5.4 Stormwater Servicing Conclusions

Stormwater runoff will be captured by a private storm sewer system conveyed to an outlet to the Ottawa River east of Booth Street.

Private storm sewer designed to convey the uncontrolled 5-year runoff rate in accordance with the *City Standards.*

To achieve the runoff quality criteria identified through consultation, an end of pipe oil/grit separator will provide an "enhanced" level of treatment as per the **SWMP Design Manual**.

The design of the proposed storm sewer system conforms to all relevant *City Standards*.

6.0 EROSION AND SEDIMENT CONTROL

Soil erosion occurs naturally and is a function of soil type, climate and topography. The extent of erosion losses is exaggerated during construction where vegetation has been removed and the top layer of soil becomes agitated.

Prior to topsoil stripping, earthworks or underground construction, erosion and sediment controls will be implemented and will be maintained throughout construction.

Silt fence will be installed around the perimeter of the site and will be cleaned and maintained throughout construction. Silt fence will remain in place until the working areas have been stabilized and re-vegetated.

Catchbasins will have a *Siltsack* or approved equivalent installed under the grate during construction to protect silt from entering the storm sewer system. Inlet catchbasins will have *Inletsoxx* or approved equivalent installed during construction to protect silt from entering the storm sewer system

A mud mat will be installed at the construction access in order to prevent mud tracking onto adjacent roads.

Erosion and sediment controls must be in place during construction, See *EC-1* for detailed erosion and sediment control measures. The following recommendations to the contractor will be included in contract documents.

- Limit extent of exposed soils at any given time.
- Re-vegetate exposed areas as soon as possible.
- Minimize the area to be cleared and grubbed.
- Protect exposed slopes with plastic or synthetic mulches.
- Install silt fence to prevent sediment from entering existing ditches.
- > No refueling or cleaning of equipment near existing watercourses.
- Provide sediment traps during dewatering.
- Install appropriate catch basins inlet protection.
- Plan construction at proper time to avoid flooding.

Establish material stockpiles away from watercourses, so that barriers and filters may be installed.

The contractor will, at every rainfall, complete inspections and guarantee proper performance. The inspection is to include:

- Verification that water is not flowing under silt barriers.
- Clean and replace Siltsack as needed at catch basins.

In addition to the above mentioned erosion and sediment controls, the storm sewer system and OGS shall be installed prior to extensive site works. All runoff will be directed to the OGS prior to discharge to the Ottawa River. Daily inspection of the OGS and pumping, if required, shall be implemented during the entire duration of the site works.

7.0 UTILITIES

Existing underground hydro ducts within Booth and Middle Street providing connection to hydro powerhouses on Victoria and Chaudière Island.

Existing gas mains are located within Booth Street right-of-way

Existing Bell cable located within Booth Street right-of-way and the Portage Bridge

Utility servicing has been coordinated with the individual utility companies prior to site development.

8.0 CONCLUSION AND RECOMMENDATIONS

David Schaeffer Engineering Ltd. (DSEL) has been retained to prepare a Functional Servicing and Stormwater Management Report to support the proposed development of Domtar Lands Redevelopment in support of Windmill Development Group's application for Site Plan Control (SPC).

- An internal water distribution model was completed that verified pressures during average day and peak hour scenarios, pressure reducing control are recommended based on the resulting pressures;
- Fire hydrants have are proposed to provide adequate fire protection at each building in Phase 1;
- Sanitary servicing is to be provided by a temporary pump station within Building 525 conveying flow to the Ville de Gatineau sanitary sewer system.
- A minimum TSS removal of 80% will be required for post-development stormwater runoff from the site, provided by an end of pipe oil/grit separator;
- Utility services will need to be coordinated with utility companies prior to development;
- Based on the preceding report, adequate servicing capacity exists to support the proposed development

Prepared by, David Schaeffer Engineering Ltd.



Reviewed by, David Schaeffer Engineering Ltd.

2017-09-07. Ton 14-717

Per: Steven L. Merrick, P.Eng.

Per: Adam D. Fobert, P.Eng

© DSEL

 $z: \label{eq:linear} rotation (dsel) \end{tabular} to the linear linea$

APPENDIX A

Pre-Consultation

DEVELOPMENT SERVICING STUDY CHECKLIST

14-717

1 General Content	N1 / A
Executive Summary (for larger reports only).	N/A
Date and revision number of the report.	Report Cover Sheet
Location map and plan showing municipal address, boundary, and layout of proposed development.	Drawings/Figures
Plan showing the site and location of all existing services.	Figure 1
Development statistics, land use, density, adherence to zoning and official plat and reference to applicable subwatershed and watershed plans that provide context to applicable subwatershed and watershed plans that provide context to which individual developments must adhere.	Section 1.0
Summary of Pre-consultation Meetings with City and other approval agencies.	Section 1.3
Reference and confirm conformance to higher level studies and reports (Mast Servicing Studies, Environmental Assessments, Community Design Plans), or in the case where it is not in conformance, the proponent must provide justification and develop a defendable design criteria.	
Statement of objectives and servicing criteria.	Section 1.0
Identification of existing and proposed infrastructure available in the immedia area.	te Sections 3.1, 4.1, 5.1
 Identification of Environmentally Significant Areas, watercourses and Municip Drains potentially impacted by the proposed development (Reference can be made to the Natural Heritage Studies, if available). 	al Section 5.0
 Concept level master grading plan to confirm existing and proposed grades in the development. This is required to confirm the feasibility of proposed stormwater management and drainage, soil removal and fill constraints, and potential impacts to neighbouring properties. This is also required to confirm that the proposed grading will not impede existing major system flow paths. 	GP-1
Identification of potential impacts of proposed piped services on private services (such as wells and septic fields on adjacent lands) and mitigation required to address potential impacts.	N/A
Proposed phasing of the development, if applicable.	N/A
Reference to geotechnical studies and recommendations concerning servicing	
All preliminary and formal site plan submissions should have the following information: -Metric scale -North arrow (including construction North) -Key plan -Name and contact information of applicant and property owner -Property limits including bearings and dimensions -Existing and proposed structures and parking areas -Easements, road widening and rights-of-way -Adjacent street names	SSP-1
.2 Development Servicing Report: Water	
Confirm consistency with Master Servicing Study, if available	N/A

	Confirm consistency with Master Servicing Study, if available	N/A
\boxtimes	Availability of public infrastructure to service proposed development	Section 3.1
\boxtimes	Identification of system constraints	Section 3.1
\boxtimes	Identify boundary conditions	Section 3.1, 3.2
\boxtimes	Confirmation of adequate domestic supply and pressure	Section 3.3

\times	Confirmation of adequate fire flow protection and confirmation that fire flow is calculated as per the Fire Underwriter's Survey. Output should show available fire flow at locations throughout the development.	Section 3.2
\triangleleft	Provide a check of high pressures. If pressure is found to be high, an assessment is required to confirm the application of pressure reducing valves.	Section 3.2
	Definition of phasing constraints. Hydraulic modeling is required to confirm servicing for all defined phases of the project including the ultimate design	N/A
	Address reliability requirements such as appropriate location of shut-off valves	N/A
	Check on the necessity of a pressure zone boundary modification	N/A
	Reference to water supply analysis to show that major infrastructure is capable	
\triangleleft	of delivering sufficient water for the proposed land use. This includes data that shows that the expected demands under average day, peak hour and fire flow	Section 3.2, 3.3
\triangleleft	conditions provide water within the required pressure range Description of the proposed water distribution network, including locations of proposed connections to the existing system, provisions for necessary looping, and appurtenances (valves, pressure reducing valves, valve chambers, and fire	Section 3.2
	hydrants) including special metering provisions. Description of off-site required feedermains, booster pumping stations, and	
	other water infrastructure that will be ultimately required to service proposed development, including financing, interim facilities, and timing of implementation.	N/A
\triangleleft	Confirmation that water demands are calculated based on the City of Ottawa Design Guidelines.	Section 3.2
	Description of a model advantation of the last of the	
	Provision of a model schematic showing the boundary conditions locations, streets, parcels, and building locations for reference.	N/A
		N/A
	streets, parcels, and building locations for reference.	N/A Section 4.2
.3	streets, parcels, and building locations for reference. Development Servicing Report: Wastewater Summary of proposed design criteria (Note: Wet-weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed infrastructure). Confirm consistency with Master Servicing Study and/or justifications for deviations.	
.3	streets, parcels, and building locations for reference. Development Servicing Report: Wastewater Summary of proposed design criteria (Note: Wet-weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed infrastructure). Confirm consistency with Master Servicing Study and/or justifications for	Section 4.2
.3	streets, parcels, and building locations for reference. Development Servicing Report: Wastewater Summary of proposed design criteria (Note: Wet-weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed infrastructure). Confirm consistency with Master Servicing Study and/or justifications for deviations. Consideration of local conditions that may contribute to extraneous flows that are higher than the recommended flows in the guidelines. This includes groundwater and soil conditions, and age and condition of sewers. Description of existing sanitary sewer available for discharge of wastewater from proposed development.	Section 4.2 N/A
3 3 1	streets, parcels, and building locations for reference. Development Servicing Report: Wastewater Summary of proposed design criteria (Note: Wet-weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed infrastructure). Confirm consistency with Master Servicing Study and/or justifications for deviations. Consideration of local conditions that may contribute to extraneous flows that are higher than the recommended flows in the guidelines. This includes groundwater and soil conditions, and age and condition of sewers. Description of existing sanitary sewer available for discharge of wastewater	Section 4.2 N/A N/A
.3	streets, parcels, and building locations for reference. Development Servicing Report: Wastewater Summary of proposed design criteria (Note: Wet-weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed infrastructure). Confirm consistency with Master Servicing Study and/or justifications for deviations. Consideration of local conditions that may contribute to extraneous flows that are higher than the recommended flows in the guidelines. This includes groundwater and soil conditions, and age and condition of sewers. Description of existing sanitary sewer available for discharge of wastewater from proposed development. Verify available capacity in downstream sanitary sewer and/or identification of upgrades necessary to service the proposed development. (Reference can be made to previously completed Master Servicing Study if applicable) Calculations related to dry-weather and wet-weather flow rates from the development in standard MOE sanitary sewer design table (Appendix 'C')	Section 4.2 N/A N/A Section 4.1
3	streets, parcels, and building locations for reference. Development Servicing Report: Wastewater Summary of proposed design criteria (Note: Wet-weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed infrastructure). Confirm consistency with Master Servicing Study and/or justifications for deviations. Consideration of local conditions that may contribute to extraneous flows that are higher than the recommended flows in the guidelines. This includes groundwater and soil conditions, and age and condition of sewers. Description of existing sanitary sewer available for discharge of wastewater from proposed development. Verify available capacity in downstream sanitary sewer and/or identification of upgrades necessary to service the proposed development. (Reference can be made to previously completed Master Servicing Study if applicable) Calculations related to dry-weather and wet-weather flow rates from the	Section 4.2 N/A N/A Section 4.1 Section 4.2

Forcemain capacity in terms of operational redundancy, surge pressure and maximum flow velocity. N/A Identification and implementation of the emergency overflow from sanitary pumping stations in relation to the hydraulic grade line to protect against basement flooding. N/A Special considerations such as contamination, corrosive environment etc. N/A IA Development Servicing Report: Stormwater Checklist Section 5.1 Outlets (i.e. municipal drain, right-of-way, watercourse, or private property) Section 5.1, Append A drawing showing the subject lands, its surroundings, the receiving watercourse, existing drainage patterns, and proposed drainage pattern. EX-1 Water quantity control objective (e.g. controlling post-development peak flows to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sever design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects. Section 5.2 Ø bescription of the stormwater management concept with facility locations and descriptions with references and supporting information Section 5.3 Section from private seves and supporting information Section 5.2 Section from private seves and supporting information Section 5.2 Section from private seves and supporting information Section 5.2	\mathbf{X}	Pumping stations: impacts of proposed development on existing pumping stations or requirements for new pumping station to service development.	Section 4.0
Identification and implementation of the emergency overflow from sanitary N/A pumping stations in relation to the hydraulic grade line to protect against basement flooding. N/A Special considerations such as contamination, corrosive environment etc. N/A 4 Development Servicing Report: Stormwater Checklist Section 5.1 analysis of available capacity in existing public infrastructure. Section 5.1, Append A drawing showing the subject lands, its surroundings, the receiving watercourse, existing drainage patterns, and proposed drainage pattern. EX-1 Water quantity control objective (e.g. controlling post-development peak flows to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long term cumulative effects. Section 5.2 Description of the stormwater management concept with facility locations and descriptions with references and supporting information Section 5.3 Section 5.4 GPr-1 Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed. Appendix A Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists. Section 5.2. Storing a cality exist. Section 5.3 <td></td> <td>Forcemain capacity in terms of operational redundancy, surge pressure and</td> <td>N/A</td>		Forcemain capacity in terms of operational redundancy, surge pressure and	N/A
Special considerations such as contamination, corrosive environment etc. N/A 4 Development Servicing Report: Stormwater Checklist Description of drainage outlets and downstream constraints including legality of outlets (i.e. municipal drain, right-of-way, watercourse, or private property) Section 5.1 4 Analysis of available capacity in existing public infrastructure. Section 5.1, Append a Adrawing showing the subject lands, its surroundings, the receiving watercourse, existing drainage patterns, and proposed drainage pattern. Ex-1 Water quantity control objective (e.g. controlling post-development peak flows to pre-development level for storm events ranging from the 2 or 5 year event Section 5.2 (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects. Section 5.2 Water Quality control objective (basic, normal or enhanced level of protection based on the sensitivities of the receiving watercourse) and storage Section 5.3 Description of the stormwater management concept with facility locations and description Authority that has jurisdiction on the affected watershed. Appendix A Gonfirm consistency with sub-watershed and Master Servicing Study, if applicable study exists. Section 5.2 Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists. Section 5.3		Identification and implementation of the emergency overflow from sanitary pumping stations in relation to the hydraulic grade line to protect against	N/A
g Description of drainage outlets and downstream constraints including legality of outlets (i.e. municipal drain, right-of-way, watercourse, or private property) Section 5.1 Analysis of available capacity in existing public infrastructure. Section 5.1, Append A drawing showing the subject lands, its surroundings, the receiving watercourse, existing drainage patterns, and proposed drainage pattern. EX-1 Water quantity control objective (e.g. controlling post-development peak flows to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects. Section 5.2 Water Quality control objective (basic, normal or enhanced level of protection based on the sensitivities of the receiving watercourse) and storage requirements. Section 5.3 Description of the stormwater management concept with facility locations and descriptions with references and supporting information Section 5.3 Set-back from private sewage disposal systems. N/A Watercourse and hazard lands setbacks. GP-1 Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed. Appendix A paplicable study exists. Confirm consistency with sub-watershed and Master Servicing Study, if applicable study e		-	N/A
outlets (i.e. municipal drain, right-of-way, watercourse, or private property)Section 5.1Analysis of available capacity in existing public infrastructure.Section 5.1, AppendA drawing showing the subject lands, its surroundings, the receiving watercourse, existing drainage patterns, and proposed drainage pattern.EX-1Water quantity control objective (e.g. controlling post-development peak flows to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects.Section 5.2Water Quality control objective (basic, normal or enhanced level of protection based on the sensitivities of the receiving watercourse) and storage requirements.Section 5.3Description of the stormwater management concept with facility locations and descriptions with references and supporting informationSection 5.3Set-back from private sewage disposal systems.N/AWatercourse and hazard lands setbacks.GP-1Record of pre-consultation with the Ontario Ministry of Environment and the Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exist.Section 5.2Storage requirements (complete with calculations) and conveyance capacity for minor events (1:5 year return period) and major events (1:100 year return period).Section 5.3Identification of watercourses within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals. <td< td=""><td>.4</td><td>Development Servicing Report: Stormwater Checklist</td><td></td></td<>	.4	Development Servicing Report: Stormwater Checklist	
A drawing showing the subject lands, its surroundings, the receiving EX-1 Water quantity control objective (e.g. controlling post-development peak flows EX-1 Vater quantity control objective (e.g. controlling post-development peak flows EX-1 (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects. Water Quality control objective (basic, normal or enhanced level of protection Section 5.2 based on the sensitivities of the receiving watercourse) and storage Section 5.2 requirements. Section 5.3 Set-back from private sewage disposal systems. N/A Watercourse and hazard lands setbacks. GP-1 Record of pre-consultation with the Ontario Ministry of Environment and the Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists. Section 5.2 Section 5.3 Storage requirements (complete with calculations) and conveyance capacity for minor events (1:5 year return period) and major events (1:100 year return period). Identification of watercourses within the proposed development and how watercourses within the proposed formerous areas and drainage Calculate pre and pos	3		Section 5.1
watercourse, existing drainage patterns, and proposed drainage pattern. EX-1 Water quantity control objective (e.g. controlling post-development peak flows to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects. Section 5.2 Water Quality control objective (basic, normal or enhanced level of protection based on the sensitivities of the receiving watercourse) and storage Section 5.2 requirements. Description of the stormwater management concept with facility locations and descriptions with references and supporting information Section 5.3 Set-back from private sewage disposal systems. N/A Watercourse and hazard lands setbacks. GP-1 Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed. Appendix A Ocoffirm consistency with sub-watershed and Master Servicing Study, if applicable study exists. Section 5.2 Storage requirements (complete with calculations) and conveyance capacity for minor events (1:5 year return period) and major events (1:100 year return period). Section 5.1 Identification of watercourses within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with	<	Analysis of available capacity in existing public infrastructure.	Section 5.1, Appendix D
Water quantity control objective (e.g. controlling post-development peak flows section 5.2 Water quantity control objective (asign) to 100 year return period); if other section 5.2 objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects. Section 5.2 Water Quality control objective (basic, normal or enhanced level of protection based on the sensitivities of the receiving watercourse) and storage Section 5.2 requirements. Description of the stormwater management concept with facility locations and descriptions with references and supporting information Sector 5.3 Set-back from private sewage disposal systems. N/A Watercourse and hazard lands setbacks. GP-1 Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed. Appendix A Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists. Section 5.2 Storage requirements (complete with calculations) and conveyance capacity for minor events (1:5 year return period) and major events (1:100 year return Section 5.3 Section 5.4 Section 5.3 genicable study exists. Section 5.3 Storage requirements (complete with calculations) and conveyance capacity for <td>]</td> <td></td> <td>EX-1</td>]		EX-1
3 based on the sensitivities of the receiving watercourse) and storage Section 5.2 requirements. Description of the stormwater management concept with facility locations and descriptions with references and supporting information Section 5.3 Set-back from private sewage disposal systems. N/A Watercourse and hazard lands setbacks. GP-1 Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed. Appendix A Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists. Section 5.2 Storage requirements (complete with calculations) and conveyance capacity for Section 5.3 mior events (1:5 year return period) and major events (1:100 year return section 5.3 Section 5.4 development with applicable approvals. Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage catchments in comparison to existing conditions. N/A Any proposed diversion of drainage catchment areas from one outlet to another. N/A Proposed minor and major systems including locations and sizes of stormwater trunk sewers, and stormwater management facilities. Appendix D If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including	3	to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into	Section 5.2
descriptions with references and supporting information Section 5.3 Set-back from private sewage disposal systems. N/A Watercourse and hazard lands setbacks. GP-1 Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed. Appendix A Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists. Section 5.2 Storage requirements (complete with calculations) and conveyance capacity for minor events (1:5 year return period) and major events (1:100 year return period). Section 5.3 Identification of watercourses within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals. Section 5.1, 5.3 Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage catchments in comparison to existing conditions. N/A Any proposed diversion of drainage catchment areas from one outlet to another. N/A Proposed minor and major systems including locations and sizes of stormwater trunk sewers, and stormwater management facilities. Appendix D If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100- year return period storm event. N/A Identification of potential impacts to receiving watercours]	based on the sensitivities of the receiving watercourse) and storage	Section 5.2
Set-back from private sewage disposal systems. N/A Watercourse and hazard lands setbacks. GP-1 Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed. Appendix A Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists. Section 5.2 Storage requirements (complete with calculations) and conveyance capacity for minor events (1:5 year return period) and major events (1:100 year return period). Section 5.3 Identification of watercourses within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals. Section 5.1, 5.3 Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage catchments in comparison to existing conditions. N/A Any proposed diversion of drainage catchment areas from one outlet to another. N/A Proposed minor and major systems including locations and sizes of stormwater trunk sewers, and stormwater management facilities. Appendix D If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100- year return period storm event. N/A Identification of potential impacts to receiving watercourses N/A	3		Section 5.3
Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed.Appendix AConfirm consistency with sub-watershed and Master Servicing Study, if applicable study exists.Section 5.2Storage requirements (complete with calculations) and conveyance capacity for minor events (1:5 year return period) and major events (1:100 year return period).Section 5.3Identification of watercourses within the proposed development and howSection 6.0watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals.Section 5.1, 5.3Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage catchments in comparison to existing conditions.N/AAny proposed diversion of drainage catchment areas from one outlet to another.N/AProposed minor and major systems including locations and sizes of stormwater trunk sewers, and stormwater management facilities.N/AIf quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100- year return period storm event.N/A			N/A
Conservation Authority that has jurisdiction on the affected watershed.Appendix AConfirm consistency with sub-watershed and Master Servicing Study, if applicable study exists.Section 5.2Storage requirements (complete with calculations) and conveyance capacity for minor events (1:5 year return period) and major events (1:100 year return period).Section 5.3Identification of watercourses within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals.Section 6.0Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage another.Section 5.1, 5.3Proposed diversion of drainage catchment areas from one outlet to another.N/AProposed minor and major systems including locations and sizes of stormwater trunk sewers, and stormwater management facilities.Appendix DIf quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100- year return period storm event.N/A]	Watercourse and hazard lands setbacks.	GP-1
Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists.Section 5.2Storage requirements (complete with calculations) and conveyance capacity for minor events (1:5 year return period) and major events (1:100 year return period).Section 5.3Identification of watercourses within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals.Section 6.0Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage acatchments in comparison to existing conditions.Section 5.1, 5.3Any proposed diversion of drainage catchment areas from one outlet to another.N/AProposed minor and major systems including locations and sizes of stormwater trunk sewers, and stormwater management facilities.Appendix DIf quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100- year return period storm event.N/A			Appendix A
Storage requirements (complete with calculations) and conveyance capacity forminor events (1:5 year return period) and major events (1:100 year returnSection 5.3period).Identification of watercourses within the proposed development and howwatercourses will be protected, or, if necessary, altered by the proposedSection 6.0development with applicable approvals.Calculate pre and post development peak flow rates including a description ofexisting site conditions and proposed impervious areas and drainageSection 5.1, 5.3catchments in comparison to existing conditions.N/AAny proposed diversion of drainage catchment areas from one outlet to another.N/AProposed minor and major systems including locations and sizes of stormwater trunk sewers, and stormwater management facilities.Appendix DIf quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100- year return period storm event.N/AIdentification of potential impacts to receiving watercoursesN/A]	Confirm consistency with sub-watershed and Master Servicing Study, if	Section 5.2
watercourses will be protected, or, if necessary, altered by the proposed Section 6.0 development with applicable approvals. Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage Section 5.1, 5.3 catchments in comparison to existing conditions. Section 5.1, 5.3 Any proposed diversion of drainage catchment areas from one outlet to another. N/A Proposed minor and major systems including locations and sizes of stormwater trunk sewers, and stormwater management facilities. Appendix D If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100-year return period storm event. N/A Identification of potential impacts to receiving watercourses N/A]	Storage requirements (complete with calculations) and conveyance capacity for minor events (1:5 year return period) and major events (1:100 year return	Section 5.3
Calculate pre and post development peak flow rates including a description of Section 5.1, 5.3 catchments in comparison to existing conditions. Section 5.1, 5.3 Any proposed diversion of drainage catchment areas from one outlet to another. N/A Proposed minor and major systems including locations and sizes of stormwater trunk sewers, and stormwater management facilities. Appendix D If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100-year return period storm event. N/A Identification of potential impacts to receiving watercourses N/A	3	Identification of watercourses within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed	Section 6.0
Any proposed diversion of drainage catchment areas from one outlet to another. N/A Proposed minor and major systems including locations and sizes of stormwater trunk sewers, and stormwater management facilities. Appendix D If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100-year return period storm event. N/A Identification of potential impacts to receiving watercourses N/A]	Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage	Section 5.1, 5.3
 Proposed minor and major systems including locations and sizes of stormwater trunk sewers, and stormwater management facilities. If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100-year return period storm event. Identification of potential impacts to receiving watercourses 		Any proposed diversion of drainage catchment areas from one outlet to	N/A
If quantity control is not proposed, demonstration that downstream system hasadequate capacity for the post-development flows up to and including the 100- year return period storm event.Identification of potential impacts to receiving watercoursesN/A]	Proposed minor and major systems including locations and sizes of stormwater	Appendix D
Identification of potential impacts to receiving watercourses N/A]	If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100-	N/A
			N/A
J Identification of municipal drains and related approval requirements.		Identification of municipal drains and related approval requirements.	N/A

\boxtimes	Descriptions of how the conveyance and storage capacity will be achieved for the development.	Section 5.3
	100 year flood levels and major flow routing to protect proposed development	
\boxtimes	from flooding for establishing minimum building elevations (MBE) and overall	SWM-1
	grading.	
	Inclusion of hydraulic analysis including hydraulic grade line elevations.	N/A
\boxtimes	Description of approach to erosion and sediment control during construction for	Section 7.0
	the protection of receiving watercourse or drainage corridors.	Section 7.0
	Identification of floodplains – proponent to obtain relevant floodplain	
	information from the appropriate Conservation Authority. The proponent may	
	be required to delineate floodplain elevations to the satisfaction of the	N/A
	Conservation Authority if such information is not available or if information	
	does not match current conditions.	
	Identification of fill constraints related to floodplain and geotechnical	N/A
	investigation.	N/A
4.5	Approval and Permit Requirements: Checklist	
\boxtimes	Conservation Authority as the designated approval agency for modification of	
	floodplain, potential impact on fish habitat, proposed works in or adjacent to a	
	watercourse, cut/fill permits and Approval under Lakes and Rivers Improvement	
	Act. The Conservation Authority is not the approval authority for the Lakes and	Section 1.2
	Rivers Improvement ct. Where there are Conservation Authority regulations in	
	place, approval under the Lakes and Rivers Improvement Act is not required,	
	except in cases of dams as defined in the Act.	
	Application for Certificate of Approval (CofA) under the Ontario Water	N/A
	Resources Act.	NYA
	Changes to Municipal Drains.	N/A
	Other permits (National Capital Commission, Parks Canada, Public Works and	N/A
	Government Services Canada, Ministry of Transportation etc.)	
4.6	Conclusion Checklist	
\times	Clearly stated conclusions and recommendations	Section 9.0
	Comments received from review agencies including the City of Ottawa and	
\times	information on how the comments were addressed. Final sign-off from the	Attached Response Letter
	responsible reviewing agency.	
7	All draft and final reports shall be signed and stamped by a professional Engineer registered in Ontario	

Steve Merrick

To: Subject: Adam Fobert RE: NCC Support for Redundant Water Access

From: Gaspar, Fred
Sent: Wednesday, August 27, 2014 03:43 PM Eastern Standard Time
To: 'Jonathan Westeinde' <<u>JonathanW@windmilldevelopments.com</u>>
Cc: Willis, Stephen; Zanetti, Marco; Miner, Chantal; 'Rodney Wilts' <<u>rodney@windmilldevelopments.com</u>>; Chakraburtty, Bina; Comtois, Jean-Gilles; Barakengera, Martin
Subject: NCC Support for Redundant Water Access

Good afternoon Jonathan.

This email serves to confirm the National Capital Commission's commitment to work with Windmill Development Group Ltd. towards finalizing an agreement for the use of NCC-owned lands primarily along Middle Street on Victoria Island (your option #3 attached) for the purpose of achieving the redundant water servicing requirement being requested by the City of Ottawa as part of its Planning review of your development proposal.

Please understand that NCC staff do not have the authority to bind the organization on these matters at this point. Authority for Federal Land Use & Transaction Approvals rests exclusively with our Board of Directors. Additionally, further authorities may be required for certain commercial terms that may be concluded.

Having reviewed the three options you provided to us earlier, NCC staff have determined that option 3 offers the best opportunity for success insofar as it best supports our common objectives and therefore represents an appropriate use of federal lands, subject to a final design plan to be reviewed and approved by the NCC, as well as the successful conclusion of negotiations on mutually-acceptable commercially fair and reasonable terms. Once that is concluded, NCC staff will positively recommend this option to our Board for Approval.

On this basis, please feel free to share this email with the City of Ottawa as necessary and appropriate to confirm our support for your redundant water servicing requirements.

I trust this meets your immediate requirements. Please let me know if you require further information or clarification.

Best regards,

Fred Gaspar Director, Planning, Approvals and Environmental Management 202 – 40 rue Elgin Street OTTAWA ON K1P 1C7 ©613.239.5678x5776





Steve Merrick

Subject:

RE: Watermain testing Booth Street

From: Dover, Steve [mailto:Steve.Dover@ottawa.ca]
Sent: June 16, 2015 1:19 PM
To: 'Adam Fobert'
Cc: Buchanan, Richard; Smadella, Karin
Subject: RE: Watermain testing Booth Street

Hi Adam,

Should the City require that a leakage test is undertaken on Booth Street under the water channel for 305 mm PVC watermain installed in 1995, the City's Water Distribution staff would undertake the test since the test would require operation of valves as well as notification of water service disruption.

Based on the age and watermain material installed I see no reason to undertake a leakage test of this section of watermain.

Regards,

Steve Dover Project Manager Environmental Engineering, City of Ottawa 951 Clyde Avenue, Ottawa, ON K1Z 5A6 Tel: (613) 580-2424 Ext.13613 Cell: (613) 266-3809 Fax: (613) 728-4183 e-mail: steve.dover@ottawa.ca

From: Adam Fobert [mailto:afobert@dsel.ca] Sent: Tuesday, June 16, 2015 11:12 AM To: Dover, Steve Cc: Buchanan, Richard Subject: Watermain testing

Hello Steve,

It was nice to finally meet you face to face on Friday regarding the Windmill project.

You had mentioned a couple of names of companies that could perform a leakage test of that existing 300mm PVC main crossing the river. Could you pass those names on?

Also, I'm assuming that we'd have to shut the main down to do this test. Is there a protocol for informing users of the shut down? Are there specifications that I need to pass onto the contractor performing the leakage test? And lastly, I'm assuming that we'll need a City watermain inspector present since they'll be touching a piece of municipal infrastructure. Correct?

Thanks for your help.

***** PLEASE NOTE THE CHANGES TO THE PHONE NUMBER AND UNIT NUMBER *****

Adam Fobert, P.Eng. Manager of Site Plan Design

DSEL david schaeffer engineering ltd.

120 Iber Road, Unit 103 Stittsville, ON K2S 1E9

direct: (613) 836-0626 cell: (613) 222-9493 email: <u>afobert@DSEL.ca</u>

This email, including any attachments, is for the sole use of the intended recipient(s) and may contain private, confidential, and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited. If you are not the intended recipient or if this information has been inappropriately forwarded to you, please contact the sender by reply email and destroy all copies of the original.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

To: Subject: Mottalib, Abdul RE: 717: Windmill Zibi - Preliminary responses to City comments

From: Mottalib, Abdul [mailto:Abdul.Mottalib@ottawa.ca]

Sent: January-12-16 4:16 PM

To: 'Steve Merrick' <smerrick@dsel.ca>

Cc: 'Dan Clement' <dan@windmilldevelopments.com>; Scott Bentley <scottbentley@windmilldevelopments.com>; 'Kristen Jorgensen' <kristen@windmilldevelopments.com>; 'Miguel Tremblay' <tremblay@fotenn.com>; Paul Black <black@fotenn.com>; Nitsche, Kersten <Kersten.Nitsche@ottawa.ca>; Buchanan, Richard <Richard.Buchanan@ottawa.ca>; Adam Fobert <afobert@dsel.ca>; Mottalib, Abdul <Abdul.Mottalib@ottawa.ca> Subject: RE: 717: Windmill Zibi - Preliminary responses to City comments

Hi Steve,

We have reviewed the sketch and we are okay with the fire hydrant locations as shown on the sketch. We are also fine with the maximum fire flow rate shown on the sketch provided the shown flow is available during firefighting. The consultant has to discuss this issue in detail with respect to their water model created for the site in the related section of the revised study.

Regarding item 3:

We are still reviewing this concern and will get back to you as soon as possible.

Thanks,

Abdul Mottalib, P. Eng.

From: Steve Merrick [mailto:smerrick@dsel.ca]
Sent: January 07, 2016 2:31 PM
To: Mottalib, Abdul
Cc: 'Dan Clement'; Scott Bentley; 'Kristen Jorgensen'; 'Miguel Tremblay'; Paul Black; Nitsche, Kersten; Buchanan, Richard; Adam Fobert
Subject: RE: 717: Windmill Zibi - Preliminary responses to City comments

Hi Abdul,

To follow up on our meeting yesterday, please find attached sketch showing hydrant locations and proximity of the buildings to be serviced. The sketch also indicates the maximum flow rate proposed at each hydrant.

Feel free to call to discuss if you have any questions or concerns.


Steve Merrick, EIT. Project Coordinator / Junior Designer

DSEL david schaeffer engineering ltd.

120 Iber Road, Unit 103

phone: (613) 836-0856 ext. 561 **cell**: (613) 222-7816 **email**: smerrick@DSEL.ca

This email, including any attachments, is for the sole use of the intended recipient(s) and may contain private, confidential, and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited. If you are not the intended recipient, or if this information has been inappropriately forwarded to you, please contact the sender by reply email and destroy all copies of the original.



z: \projects\14-717_windmill-the_isles\b_design\b2_drawings\b2-5_sketches and figures\2015-01-07_hydrant-distance\2016-01-07_717_slm.dwg

Steve Merrick

To: Subject: Adam Fobert RE: Zibi Ontario - Potential Servicing via Gatineau Due Diligence

From: Desforges, Mario [mailto:desforges.mario@gatineau.ca]

Sent: March-04-16 10:33 AM

To: Marc-André Gélinas < marc-andre.gelinas@quadrivium.biz>

Cc: 'Dan Clement' <<u>dan@windmilldevelopments.com</u>>; 'Scott Bentley' <<u>scottbentley@windmilldevelopments.com</u>>; Adam Fobert <<u>afobert@dsel.ca</u>>; Robert Freel <<u>rfreel@dsel.ca</u>>; Cadieux, André <<u>cadieux.andre@gatineau.ca</u>> **Subject:** RE: Zibi Ontario - Potential Servicing via Gatineau Due Diligence

Bonjour Marc-André

Tel que mentionné suite à cette rencontre du 12 février dernier, et tel que mentionné un peu plus tôt cette semaine, le débit d'eaux usées de pointe (52 l/sec) prévu pour le projet Zibi-Ottawa, est beaucoup plus élevé que celui qui m'avait été fourni (10 l/sec) lorsqu'on nous a demandé si nous étions prêts à regarder les possibilités de recevoir et traiter les eaux usées de ce projet.

Ainsi, bien qu'à première vue, le réseau de la ville de Gatineau semble avoir de façon général la capacité suffisante pour accepter ce débit, il y a tout de même un tronçon d'égout de 900 mm de diamètre dont la capacité résiduelle devra être vérifié afin de déterminer si il elle est suffisante pour véhiculer les eaux usée du projet Zibi-Ottawa. Ce tronçon est indiqué avec une flèche rouge ci-après et est le tronçon d'égout situé entre le point de rejet du projet Zibi-Gatineau, et le collecteur principale d'égout.

Nous demandons donc à la compagnie Windmill de faire évaluer la capacité résiduelle de ce tronçon d'égout afin de déterminer si elle est suffisante pour recevoir les eaux usées du projet Zibi-Ottawa. Lors de cette analyse, il faudra tenir compte des débits d'eaux usées actuels dans le bassin de desserte ainsi que des débits générés par la densification qui se fait actuellement au centre-ville de Gatineau.

Également, tel que mentionné lors de la rencontre du 12 février dernier, la compagnie Windmill devra surdimensionner le réseau d'égout sanitaire prévu dans la phase 1 du projet Zibi-Gatineau afin de pouvoir accepter les eaux usées du projet Zibi-Ottawa. Compte tenu des échéanciers de réalisation de la phase 1 du projet, la compagnie Windmill devra probablement surdimensionner le réseau d'égout sanitaire du projet Zibi-Gatineau, sans avoir la certitude qu'une entente sera conclu afin que les eaux usées du projet Zibi-Ottawa puisse être traiter par les installation de la ville de Gatineau. La compagnie Windmill devra dons assumer ce risque.


Finalement, si la ville de Gatineau accepte de recevoir les eaux usées du projet Zibi-Ottawa, il faudra évaluer la quotepart du coût des infrastructures existantes et futures requises pour transporter et traiter ces eaux usées et qui devra être payée par la compagnie Windmill à la ville de Gatineau. Il faudra également évaluer les coûts d'opération annuelle pour traiter les eaux usées.

Si tu as des questions concernant le présente courriel, n'hésite pas à m'appeler.

Salutations sincères

Mario Desforges, ing

Coordonnateur - développement des réseaux Gestion du territoire - Service des infrastructures Réseaux et aménagements urbains Ville de Gatineau Tél.: 819-243-2345 poste 4307 Télec.: 819-595-7321



De : Marc-André Gélinas [mailto:marc-andre.gelinas@quadrivium.biz]
Envoyé : 12 février 2016 15:06
À : Desforges, Mario
Cc : 'Dan Clement'; 'Scott Bentley'; Adam Fobert; Robert Freel
Objet : TR: Zibi Ontario - Potential Servicing via Gatineau Due Diligence

Bonjour Mario,

Pour faire suite à notre rencontre de cet après-midi, tu trouveras ci-joint les plans montrant les différentes options pour desservir le projet Zibi-Ottawa par le projet Zibi-Gatineau. De plus, tu trouveras ci-dessous les débits estimés provenant du projet Zibi-Ottawa.

Comme discuté, svp nous informer si vos installations existantes sont en mesure de recevoir ce débit additionnel.

Pour de plus amples renseignements, n'hésite pas à m'appeler.

Merci et bonne de semaine,

Marc-André Gélinas, ing., P.Eng.

Directeur Infrastructures

Téléphone : 819-243-4474 poste 259 Courriel : <u>marc-andre.gelinas@quadrivium.biz</u>

QUADRIVIUM | L'ingénierie avec passion 290 boulevard St-Joseph, unité 2, Gatineau (Québec) J8Y 3Y3 Téléphone : 819-243-4474 |Télécopieur : 819-243-4482 www.quadrivium.biz

De : Adam Fobert [mailto:afobert@dsel.ca]
Envoyé : 8 février 2016 12:15
À : 'Scott Bentley' <<u>scottbentley@windmilldevelopments.com</u>>; Marc-André Gélinas <<u>marc-andre.gelinas@quadrivium.biz</u>>
Cc : 'Chris Stacey' <<u>chris@windmilldevelopments.com</u>>; 'Paul Rankin' <<u>paul@windmilldevelopments.com</u>>; 'Dan Clement' <<u>dan@windmilldevelopments.com</u>>; 'Carola Lima' <<u>carola@windmilldevelopments.com</u>>
Objet : RE: Zibi Ontario - Potential Servicing via Gatineau Due Diligence

Hello Scotty and Marc-Andre,

We have estimated that the full buildout will have the following flows:

Wastewater (ie Sanitary Pump station): Peak flow = 52L/s

Water:

Average Day = 720L/min Maximum Day = 1660L/min Peak Hour = 3570L/min

Fire Flow:

Min required: 9,000L/min Max required: 22,000L/min

Marc-Andre, can you coordinate the available water pressures for the above? Please note that we require the pressure available during Average Day, Maximum Day + Fire Flow, and Peak hour. Thank you.

Adam Fobert, P.Eng. Manager of Site Plan Design

DSEL david schaeffer engineering ltd.

120 Iber Road, Unit 103

Stittsville, ON K2S 1E9

office: (613) 836-0856 direct: (613) 836-0626 cell: (613) 222-9493 email: <u>afobert@DSEL.ca</u>

This email, including any attachments, is for the sole use of the intended recipient(s) and may contain private, confidential, and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited. If you are not the intended recipient or if this information has been inappropriately forwarded to you, please contact the sender by reply email and destroy all copies of the original.

From: Scott Bentley [mailto:scottbentley@windmilldevelopments.com]

Sent: February-01-16 12:48 PM

To: Adam Fobert <<u>afobert@dsel.ca</u>>; 'Marc-André Gélinas' <<u>marc-andre.gelinas@quadrivium.biz</u>>; Glencor Engineering Ltd <<u>glencor@on.aibn.com</u>>; Scott Funnell <<u>scott.funnell@wspgroup.com</u>>; Robert Lefebvre <<u>rlefebvre@gwal.com</u>> Cc: Chris Stacey <<u>chris@windmilldevelopments.com</u>>; Paul Rankin <<u>paul@windmilldevelopments.com</u>>; Dan Clement <<u>dan@windmilldevelopments.com</u>>; Carola Lima <<u>carola@windmilldevelopments.com</u>>

Subject: Zibi Ontario - Potential Servicing via Gatineau Due Diligence Importance: High

Good Afternoon Team,

I want to follow up from last week's meeting to get a sense of the direction we are headed and what obstacles remain. We want to have this all wrapped up by **4 March 2016**. Below are a quick list of tasks, rough order of completion, and the main points of contact:

- Meeting with Ville de Gatineau to discuss feasibility: Marc-Andre (please confirm as soon as you have met)
- Water Modelling to verify pressures: Adam and Marc-Andre
- Prelim Concept of Services Pipeline: Adam and Robert
- Meeting with Public Services for Union Bridge feasibility: Adam and Scott F (tentatively scheduled for 8th to 12th of Feb)
- Corrosion Inspection of Chaudiere Crossing Pipeline Structures: Dave
- Structural Inspection of Chaudiere Crossing Pipeline Structures: Scott F
- Follow up with the City of Ottawa: Adam

For the on-site inspections, I'd ask you schedule/coordinate access with Chris Stacy.

Lastly, if you haven't already submitted a services proposal, please get something into my hands ASAP!

Thank-you

Scotty

Scott Bentley, CD CTech Project Manager Zibi District Thermal System & Ontario Infrastructure WINDMILL DEVELOPMENT GROUP Suite 201, 1306 Wellington Street West Ottawa, ON K1Y 3B2 t: 613.820.5600 x (121) c: 613.864.8206

scottbentley@windmilldevelopments.com www.windmilldevelopments.com Avis : Ce message contient des renseignements confidentiels appartenant exclusivement à Quadrivium conseil inc. Il est protégé par le secret professionnel et est à l'usage exclusif du destinataire. Toute autre personne est par les présentes avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si vous avez reçu ce message par erreur, veuillez nous en aviser immédiatement par retour du courrier électronique ou par téléphone au numéro mentionné ci-dessus, et détruire ce message. Merci.

Note : This communication and any attachment(s) is intended only for the party to whom it is addressed and may contain information which is privileged or confidential and belongs to Quadrivium conseil inc. Any other delivery, distribution, copying or disclosure is strictly prohibited and is not a waiver of privilege or confidentiality. If you have received this communication in error, please notify the sender immediately by return electronic mail or telephone mentioned below, and destroy the message. Thank you.

MISE EN GARDE CONCERNANT LA CONFIDENTIALITÉ – La présente communication est confidentielle. Si vous n'êtes pas le destinataire visé ou son mandataire chargé de lui transmettre cette communication, vous êtes par la présente informé qu'il est expressément interdit d'en dévoiler la teneur, de la copier, de la distribuer ou de prendre quelque mesure fondée sur l'information qui y est contenue. Si vous avez reçu cette communication par erreur, veuillez nous en informer immédiatement par téléphone ou par courriel et détruire l'original, sans tirer ni conserver de copie.





J.F. Sabourin et associés inc. 2368 St-Louis, unité 101, Gatineau, QC J8V 1A2 tél.: 819.243.6858, téléc.: 819.243.8194

Ville de Gatineau C.P. 1970, Succursale B Gatineau, Québec J8X 3Y9 13 mai 2016 Notre dossier : 1163-04

Attention : M. Mario Desforges, ing., Coordonnateur - développement des réseaux

Objet : Plan directeur des bassins 56 à 58 du secteur Hull à Gatineau

Monsieur,

Les services de JFSA ont été retenus afin d'élaborer un plan directeur de drainage permettant de cibler la capacité résiduelle du réseau pseudo-domestique afin d'examiner la possibilité de recevoir les eaux usées en provenance du projet de développement Zibi-Ottawa. Ainsi, un plan directeur des bassins 56 à 58 délimités dans le plan directeur sanitaire fait par JFSA en 2013 est nécessaire afin d'évaluer les débits d'eaux usées actuels dans le bassin ainsi qu'à l'ultime, le tout, en intégrant les débits apportés par le projet domiciliaire Zibi –Ottawa et Gatineau.

Sans s'y limiter, le mandat confié à JFSA comprend les tâches et les livrables suivants :

- 1. Inventaire et collecte des données;
- 2. Calcul et établissement des débits « intrants » dans les bassins versants;
- 3. Modélisation hydrologique SWMHYMO;
- 4. Modélisation hydraulique PCSWMM;
- 5. Analyse du secteur actuel et à l'ultime;
- 6. Rédaction d'une lettre-rapport.



LOCALISATION ET TYPE DE RÉSEAU

Le secteur à l'étude est compris dans le quadrilatère formé des bassins 56 à 58 en provenance du plan directeur d'égout sanitaire (JFSA, 2013). L'ensemble du réseau compris dans les bassins 56 et 57 est desservi par un réseau pseudo-domestique. Quant au bassin 58, celui-ci est desservi par un réseau sanitaire. La Figure 1 illustre l'emplacement de ces sous-bassins à l'étude en rouge. Il est à noter que les projets domiciliaires Zibi – Ottawa et Zibi –Québec sont illustrés en jaune et en vert respectivement dans la Figure 1.




Figure 1 : Emplacement du secteur à l'étude



DÉVELOPPEMENT DES MODÈLES HYDROLOGIQUES ET HYDRAULIQUES

SOURCES D'INFORMATION

Les informations utilisées pour développer les modèles hydrologiques et hydrauliques proviennent principalement de la base de données de la ville de Gatineau. Ces données comprennent, sans s'y limiter :

- Base de données GIS de la ville de Gatineau comprenant la liste des conduites, des regards, des puisards, des rues et des bâtiments existants dans le secteur à l'étude ;
- Plan directeur d'égout sanitaire de la ville de Gatineau (JFSA, 2013).

DESCRIPTIONS DES MODÈLES UTILISÉS

Pour l'analyse de la portion pseudodomestique du secteur à l'étude, le modèle SWMHYMO et le modèle PCSWMM ont été utilisés. Le premier est un modèle hydrologique possédant des routines spécifiquement développées pour la simulation des eaux usées domestiques, commerciales ainsi qu'industrielles et des eaux parasitaires (infiltration, captage, drains français) présentes dans les réseaux séparés et pseudoséparés. Le second est un modèle hydraulique dynamique qui reprend les hydrogrammes calculés par le modèle hydrologique afin de simuler les effets de laminage et les conditions de surcharge (profils piézométriques) sur la longueur de chaque conduite du réseau étudié.

SWMHYMO

Le modèle SWMHYMO, tout comme ses prédécesseurs HYMO et OTTHYMO, est un modèle mathématique complexe utilisé pour simuler la réponse hydrologique de grands et petits bassins versants. Le modèle repose sur des paramètres physiques simples de bassins ruraux ou urbains qui sont facilement estimés. De plus, diverses pratiques de drainage peuvent être représentées (ex : bassins de rétention, acheminement dans de longues conduites ou ruisseau, captage partiel par les régulateurs de débits dans les puisards). Le modèle peut utiliser des événements de pluies synthétiques ou bien des données horaires de pluies réelles. Il peut également être utilisé pour simuler la réponse hydrologique des réseaux d'égout. SWMHYMO possède des routines spécifiquement développées pour la simulation des eaux usées domestiques, commerciales ainsi qu'industrielles et des eaux parasitaires (infiltration, captage, drains français) présentes dans les réseaux séparés et pseudoséparés. Les apports d'eau simulés par les calculs du modèle SWMHYMO peuvent être décrits comme suit :



En temps sec, SWMHYMO calcule :

- L'infiltration plus ou moins constante en provenance de la nappe phréatique, basée sur des mesures de débits, ou sur d'anciens rapports ÉPIC, lorsque disponibles;
- ii. La variation horaire et journalière des apports des eaux usées causée par l'utilisation domestique;
- iii. Les apports des eaux usées en provenance des commerces, industries et institutions. Étant donné la nature de ce type de débit, seuls des débits constants sont actuellement considérés.

En temps de pluie, SWMHYMO calcule :

- Le ruissellement et le captage de celui-ci, en provenance des surfaces directement reliées au réseau d'égout (ex. toiture, gouttière, entrée en contrepente, regard placé dans un point bas de la rue, etc.);
- ii. Le ruissellement et le captage de celui-ci, en provenance des superficies drainées par les drains de fondation;
- Le ruissellement et le captage de celui-ci, en provenance des surfaces drainées par les fissures et les joints non étanches des conduites et des cheminées aux points d'accès.

PCSWMM

La modélisation hydraulique du réseau sanitaire et pseudo-domestique a été effectuée à partir du logiciel PCSWMM. Ce dernier a été employé afin de déterminer l'hydraulique des réseaux existants et projetés ainsi que la capacité résiduelle des réseaux existants.

Selon le tableau 10-4 du guide de gestion des eaux pluviales du MDDELCC, le logiciel PCSWMM convient adéquatement pour la modélisation dynamique du comportement d'un réseau d'égout.

Le modèle hydraulique dynamique reprend les hydrogrammes générés par le modèle hydrologique (SWMHYMO) afin de simuler les effets de laminage et les conditions de surcharge (profils piézométriques) sur la longueur de chaque conduite étudiée. Le modèle repose sur des paramètres physiques simples tels la géométrie des conduites, la pente, la longueur, le coefficient de rugosité, le coefficient de perte de charge entre les conduites, etc.



MÉTHODOLOGIE

Les modèles hydrologiques et hydrauliques du réseau permettront, dans un premier temps de comprendre le comportement du secteur ainsi que l'interaction entre les réseaux et d'évaluer la capacité résiduelle actuelle du réseau. Les lignes directrices suivies pour la réalisation du mandat peuvent se résumer comme suit et sont décrites en détail dans les sections suivantes :


- 1. Caractérisation des bassins versants: Cueillette d'informations, validation des limites du bassin versant, découpage en surface de drainage en fonction du réseau et de la topographie du terrain;
- Modélisation et évaluation des conditions existantes et ultimes : Sélection des paramètres pour les modélisations hydrologiques et hydrauliques, simulation des pluies synthétiques, établissement des conditions existantes et ultimes;
- 3. Synthèse des conclusions et des recommandations.


MODÈLE HYDROLOGIQUE

Une pluie synthétique d'une récurrence 1 dans 100 ans d'une durée de 4 heures a été utilisée pour simuler l'apport d'eau provenant des drains français. Cette pluie de type Chicago a été dérivée des courbes IDF de l'aéroport international d'Ottawa présentée à l'Annexe A. Celle-ci a été modifiée afin de tenir compte de l'effet des changements climatiques. Cette modification s'est effectuée en majorant les intensités des courbes IDF à 10 % pour un événement centenaire, tel que recommandé par le Guide de gestion des eaux pluviales (MDDEP et MAMROT, 2011, Guide de Gestion des eaux pluviales, Chapitre 2-19.).

Le découpage des surfaces de drainage du secteur à l'étude pour la modélisation SWMHYMO du réseau pseudo-domestique existant et à l'ultime, présenté à la Figure 2 et 3 respectivement, est essentiellement celle en provenance du plan directeur sanitaire fait par JFSA, en 2013 ainsi que leur superficie en hectares. Au total, 3 surfaces de drainage ont été définies. Le nom, la superficie en hectare, la population et la superficie du secteur commercial sont tous des éléments présentés à l'intérieur des Figures 2 et 3. Les fichiers d'entrées et de sorties du modèle SWMHYMO sont présentés à l'Annexe B.







Le Tableau 1 montre les paramètres utilisés dans la codification du modèle SWMHYMO. Une description détaillée de chacun d'entre eux est présentée à la suite de ce tableau.

Description des paramètres	Nom des paramètres et valeurs
Débit journalier moyen associé à la population	ADFp= 320 (L/personne/jour)
Nombre de personnes par résidence	2.1 personnes/résidences
Facteur de pointe associé au ADFp	PKFp = 4
Ratio de l'aire commerciale, industrielle et institutionnelle sur l'aire totale	Xacom = variable selon l'utilisation de la surface de drainage
Débit journalier moyen associé aux aires industrielles, commerciales et institutionnelles	ADFa = variable selon l'utilisation de la surface de drainage (L/ha/jour)
Facteur de pointe associé au ADFa	PKFa = 1 (constant)
Ratio de l'aire totale utilisée dans le calcul de l'infiltration	XAgwf = 1
Débit journalier moyen associé à l'infiltration quasi	ADFg = 12 000 (L/ha/jour) Réseau domestique
constante	ADFg = 16 000 (L/ha/jour) Réseau pseudo-domestique
Facteur de pointe associé au ADFg	PKFg = 1
Rapport de la surface totale imperméable directement connectée à l'égout	C_DCON = 0.02
Longueur du débit hydrologique moyen des aires directement connectées définies par C_DCON	AVGLEN = 0
Ratio de l'aire totale contribuant à l'infiltration rapide par des drains français	C_WEEP = 2% selon la surface de drainage résidentielle
Temps requis pour l'infiltration de l'eau dans le sol au- dessus des drains français	K_WEEP = 0.75 h (réseaux pseudo)
Ratio de l'aire totale contribuant à l'infiltration lente (ex: conduites craquées)	C_SLOW = 0.003
Temps requis pour l'infiltration de l'eau dans le sol au- dessus du système	K_SLOWi = 10 hr
Augmentation de la valeur de K_SLOWi considérant le temps de parcours dans le réseau	K_SLOWii = 0.005 (hr/ha)

Tableau 1 : Paramètres du modèle hydrologique SWMHYMO



Les débits domestiques journaliers sont basés sur un apport d'eau de 320 L/personne/jour pour un bassin versant résidentiel mixte (Ministère de l'Environnement, 1982, Directive 004, section 6.1.1). Le facteur de pointe (PKFp) a été déterminé en fonction du débit moyen généré par chaque superficie de drainage (Ministère de l'Environnement, 1982, Directive 004, figure 6.1.3.1, section 6.1.5).

Des taux de 12 000 et de 16 000 l/ha/jour ont été utilisés pour simuler l'infiltration des réseaux domestique et pseudo-domestique respectivement. Ces taux proviennent du chapitre 6.1.2.1 de la Directive no.004 « Réseau d'égout ».

En ce qui concerne les apports d'eau en provenance des commerces et usages institutionnels, les valeurs basées sur le tableau 2.1 Débit domestique de conception basé sur la littérature (Ministère de l'Environnement, 2001, Guide pour l'étude des technologies conventionnelles de traitement des eaux usées d'origine domestique, Chapitre 2) ont été employées. Il est à noter que l'inventaire de l'ensemble des unités de logement, des commerces, des immeubles à bureau et des industries a été réalisé à l'aide de l'atlas de Gatineau et des outils géomatiques. De plus, pour ce qui est des édifices de nature fédéral, l'estimation du nombre d'employés a été réalisée avec les *Normes d'aménagement du gouvernement du Canada relative à l'initiative Milieu de travail 2.0* du Gouvernement du Canada. L'inventaire des bâtiments est présenté à l'Annexe C.

Le paramètre C_DCON, soit le pourcentage de captage direct, est déterminé par l'estimation du nombre d'entrées en contre-pente, le nombre de drains de toit et le nombre de gouttières de toitures directement branchées aux drains français. La valeur du paramètre C_DCON varie entre 0 et 0,2 %. Une hypothèse de 5% des drains de toit raccordé à l'égout pseudo-domestique a été faite en fonction de la superficie totale des toits présents dans les sous-bassins 56 et 57.

Le nombre de bâtiments pour lesquels les gouttières jettent un pourcentage de l'eau reçue sur la toiture sur une surface perméable a été utilisé afin d'estimer la valeur du paramètre C_WEEP. Le C_WEEP a donc été fixé à 0.0005. Pour des fins de conception, le temps requis (K_WEEP) par l'eau pour percoler dans le remblai et/ou le sol naturel se retrouvant près des drains de fondation ou des tuyaux de drainage a été estimé à 45 minutes.



Le paramètre C_SLOW, représentant le pourcentage de la superficie totale du bassin versant contribuant à l'apport de ruissellement par infiltration, a été supposé comme étant égal à 0.003 pour le secteur à l'étude. Le paramètre KSLOWi, défini comme étant le temps requis par l'eau pour s'infiltrer à travers les couches de sol au-dessus des conduites collectrices, a été évalué à 10 heures. Le paramètre KSLOWii, considérant le temps de transport à l'intérieur des conduites d'égouts, a été estimé à 0,005 heure/ha.

MODÈLE HYDRAULIQUE

Les simulations hydrauliques ont été effectuées avec le modèle hydraulique PCSWMM tel que décrit précédemment. Celui-ci permet l'analyse complexe des écoulements qui varient entre des conditions à surface libre et en charge. Il est à noter que les données de base des conduites proviennent de la base de données de la ville de Gatineau.

L'élaboration du modèle hydraulique a été réalisée à l'aide de plusieurs hypothèses énoncées comme suit :

- L'apport d'eau usée de l'usine Kruger a été considéré comme une conduite de 600 mm d'une pente de 0.3% coulant pleine. Plus précisément, il s'agit d'un débit de 0.34 m³/s;
- Le modèle actuel tient compte de l'apport d'eaux usées des développements domiciliaire Zibi Gatineau (52.8 L/s pour les blocs 1 à 24 et 3L/s pour les blocs 25 à 26) et Ottawa (52 L/s);
- Les hydrogrammes ont été intégrés à l'intérieur d'un seul nœud pour chaque sous-bassin, et ce, en raison du manque d'information sur les raccordements de chacun des bâtiments existants. Il est à noter que cette façon d'étudier les conduites réceptrices est beaucoup plus conservatrice, car il y a beaucoup moins de laminage à l'intérieur du modèle hydraulique;
- Le modèle à l'ultime tient compte des projections de 2051, c'est-à-dire 100 logements/ hectares, et ce, pour tous les lots résidentiels et ceux ayant actuellement un stationnement.



MODÉLISATION DES CONDITIONS ACTUELLES ET ULTIMES

Dans l'optique que le débit d'eau usée des nouvelles conduites du projet domiciliaire du projet Zibi Ottawa va être reçu par le réseau de la ville de Gatineau, considérant que ce réseau fera l'objet de densification importante à l'ultime et considérant les objectifs du présent mandat, les scénarios étudiés se limitent aux éléments suivants :

- Modélisation avec les conditions actuelles : Ajout de l'apport d'eau usée du projet Zibi Ottawa à l'égout pseudo-sanitaire (900 mm) sur la rue Eddy en tenant compte des conditions actuelles;
- Modélisation avec les conditions à l'ultime : Ajout de l'apport d'eau usée du projet Zibi Ottawa à l'égout pseudo-sanitaire sur la rue Eddy (900 mm) avec un développement à l'ultime des bassins 56 à 58.

Par ailleurs, il est important de mentionner que puisqu'aucune mesure de débit n'est disponible pour les bassins versants 56 à 58, la calibration des modèles n'a donc pas été effectuée pour cette étude.


La Figure 4 illustre l'emplacement de la conduite pseudo-domestique réceptrice.

MODÉLISATION AVEC LES CONDITIONS ACTUELLES

Dans un premier temps, la modélisation hydrologique et hydraulique des bassins 56 à 58 a permis d'évaluer la capacité hydraulique de la conduite réceptrice (# 11 231) d'un diamètre de 900 mm à recevoir l'apport d'eau usée en provenance du développement Zibi Ottawa. À noter que l'effet des changements climatiques a été intégré dans le modèle hydraulique du réseau existant pseudo-domestique considérant que le projet Zibi va être réalisé sur plusieurs phases. L'ajout du projet de développement Zibi Ottawa va générer un débit de pointe de 52 L/s.

La simulation hydraulique du secteur à l'étude, comprenant les conditions existantes, a donc été exécutée afin d'évaluer la performance locale du réseau actuel. Avec l'ajout des débits du projet Zibi Ottawa et Gatineau, une pluie de récurrence 1 :100 ans avec l'effet des changements climatiques ainsi que la contribution actuelle des bassins 56 à 58, les conduites ne démontrent aucune difficulté à transiter ces débits. De surcroît, la conduite réceptrice (# 11 231) est actuellement amplement capable de recevoir les débits puisque le niveau d'eau n'atteint pas la moitié de son diamètre, tel qu'illustré à l'Annexe D. Il est à noter que cette conduite se déverse dans le collecteur sanitaire qui possède un diamètre de 1800 mm.





En effet, le Tableau 2 montre la capacité de la conduite réceptrice et les débits de pointe d'eau usée des différents bassins et projet domiciliaire. La capacité résiduelle a été calculée par modélisation hydraulique en fonction des points d'entrée des débits dans le modèle PCSWMM. Il est à noter que les points d'entrées des bassins 56 à 58 sont près des exutoires de ceux-ci.

eau 2 :	: Débit intrants et capacité résiduelle de la conduite réceptrice					
		Débit (m³/s)				
Capacité ¹	Conduite # 11 231	0.94				
	Bassin 56	0.145				
sées	Bassin 57	0.033				
Apport en eaux usées	Bassin 58	0.001				
en ea	Usine Kruger (600Ø coulant plein)	0.340				
orte	Zibi Ottawa	0.052				
App	Zibi Gatineau (bloc 1 à 24)	0.053				
	Zibi Gatineau (bloc 25 à 26)	0.003				
	Capacité résiduelle	0.390				

Tableau 2 : Débit intrants et capacité résiduelle de la conduite réceptrice

Note

1 Capacité coulant pleine obtenue par PCSWMM

Par ailleurs, il est important de mentionner que les conduites en provenance du projet Zibi-Gatineau devront être augmentées de diamètre afin de permettre de transiter les nouveaux apports prévus pour le projet de développement Zibi- Ottawa.



MODÉLISATION AVEC LES CONDITIONS À L'ULTIME

La modélisation hydraulique avec les conditions à l'ultime a été réalisée avec les projections du schéma d'aménagement de la ville de Gatineau qui prévoit une densité de 100 logements/ hectares, et ce, pour l'horizon 2051. Ainsi, les débits obtenus avec les superficies actuellement commerciale, institutionnelle et industrielle demeurent les mêmes. Cependant, les débits estimés avec les superficies à l'intérieur des bassins à l'étude caractérisés par des stationnements et des logements ont été estimés avec la densité de l'horizon 2051.

Une fois les débits intégrés dans le modèle hydraulique, la capacité de la conduite réceptrice (# 11 231) a pu être évaluée. Celle-ci a amplement la capacité de transiter les débits engendrés par un schéma d'aménagement à l'ultime, car l'eau atteint seulement la moitié du diamètre de la conduite, tel qu'illustré à l'Annexe D.

Afin d'avoir une meilleure compréhension de ce constat, le Tableau 3 présente la capacité de la conduite réceptrice et les débits de pointe d'eau usée des différents bassins et projet domiciliaire. La capacité résiduelle a été calculée par modélisation hydraulique en fonction des points d'entrée des débits dans le modèle PCSWMM. Tel qu'indiqué précédemment les points d'entrées des bassins 56 à 58 sont près des exutoires de ceux-ci. Il est à noter que seulement le bassin 56 a une légère augmentation du débit puisque celui-ci a dans ce scénario la densité prévue en 2051.

		Débit (m³/s)
Capacité ¹	Conduite # 11 231	0.94
s	Bassin 56	0.150
Apport en eaux usées	Bassin 57	0.033
וחא ר	Bassin 58	0.001
n ea	Usine Kruger (600Ø coulant plein)	0.340
ort e	Zibi Ottawa	0.052
bpdd	Zibi Gatineau (bloc 1 à 24)	0.053
4	Zibi Gatineau (bloc 25 à 26)	0.003
	Capacité résiduelle	0.347

Tableau 3 : Débit intrant et capacité résiduelle de la conduite réceptrice

Note

1 Capacité coulant pleine obtenue par PCSWMM



CONCLUSION ET RECOMMANDATIONS

L'analyse effectuée du réseau situé sur l'île de Hull a permis de vérifier la capacité des conduites à recevoir les débits en provenance du développement Zibi à Ottawa qui se situe en partie sur les îles Chaudière et Albert. L'objectif du présent mandat était d'évaluer à l'aide de modèles hydrologique et hydraulique, la capacité des réseaux existants à recevoir les eaux usées du projet Zibi en condition actuelle et ultime.

La capacité des conduites existantes présentes dans la rue Eddy et le Boulevard Alexandre-Taché a ainsi été analysée dans ce présent rapport. En effet, la capacité des conduites est suffisante pour transiter le débit, sans être en charge, engendrée par le nouveau développement Zibi, soit de 52 L/s. La capacité résiduelle obtenue par modélisation est de 0.39 m³/s. Lors des simulations en condition ultime, la capacité résiduelle s'est avérée légèrement moindre, c'est-à-dire de 0.35 m³/s. Il est donc possible d'affirmer que cette conduite a amplement la capacité de recevoir le débit en provenance du projet domiciliaire Zibi-Ottawa.

Il est important de mentionner que les paramètres de modélisation hydrologique ont été estimés par des hypothèses et grâce à la connaissance de certaines caractéristiques du secteur. Cependant, si la Ville désire valider ces paramètres, une calibration à l'aide de mesure de débit ce doit d'être réalisée à quelques endroits clé du secteur à l'étude.

Parallèlement, l'accroissement du débit transité par les conduites réceptrices faisant partie du projet domiciliaire Zibi-Gatineau doit faire l'objet d'une mise à jour des diamètres puisque celles-ci reçoivent maintenant un débit supplémentaire de 52 L/s.

De cette manière, JFSA a permis d'identifier la capacité résiduelle de la conduite réceptrice du projet de développement Zibi ce qui permet l'atteinte des objectifs du présent mandat.



En espérant le tout à votre entière satisfaction, veuillez agréer, Monsieur Desforges, l'expression de nos sentiments les meilleurs.

Benoit Doré, M. ing. P. Eng.

MELAA,


Vanesa Carolin Pereira, ing. OIQ # 5045387

Marcel Roy, ing, Directeur général de l'Outaouais OIQ # 36996

cc Jean-François Sabourin, M. ing, ing, JFSA inc.



ANNEXE



JFSA

Experts-conseils en ressources hydriques et en environnement



PLUIES SYNTHÉTIQUES

STORMS 2010 - Ver. 3.0.0 per 210 180 Chicago 4 hr 100ans aeroport Ottawa Avec CC 150 Temps (minutes) 120 Statistiques de l'événement: Fichier de pluie: Y:\Proj\1163\04 (Plan directeur)\Design\SWMHYMO\M04Ch100.STM Commentaire pour fichier de pluie: Chicago 4 hr 100ans aeroport Ottawa Avec CC 6 8 - 8 rin Ass 0 0.00 Τ 190.58 171.52 152.46 114.35 19.06 133.41 95.29 76.23 57.17 38.12


Pluie totale		82.25 (mm)		
Durée de l'événement (h)	"	4:00:00		
Pas de temps	"	10 (minutes)		
Intensité moy.	•	20.56 (mm/h)	~	
Intensité max.	= 19	90.58 (mm/h	190.58 (mm/h) à 80.00 (minutes)	inutes)
Intensités Maximum Moyennes: (mm/h)	Moyenne	s: (mm/h	(
Durées	5 min	10 min	15 min	30 min
Intensité moy. (mm/h)	190.58	190.58	147.66	99.58

es	5 min	10 min	15 min	30 min	1 hre	2 hres	3 hres	6 hres	12 hres	24 hres
sité moy. (mm/h)	190.58	190.58	147.66	85.66	61.21	35.92	25.97	13.71	6.85	3.43

J.F. Sabourin et associés Inc.

Précipitation (mm/h)









Experts-conseils en ressources hydriques et en environnement

at	13/05/2016 7:42 AM		
Metric unit:	s / ID numbers OFF	72 73	Groundwater baseflow
	[Plan directeur - bassin 56 à 58-] Project Number: [1163-04]	73 74	<pre>XAgwf=[1], ADFg=[16000](1/ha/day), PKFg=[1] ===================================</pre>
Date :		75	Direct connections
Modeller :	(VCP)	76	C_DCON=[0.02], AVGLEN=[0](m)
Company :	JFSA .	77	Weeping tile connections
License # :	4706892	78	C_WEEP=[0], K_WEEP=[0.75] (hrs)
***********	*********	79	Slow infiltration
	- Windmill- Condition Existante	80	C_SLOW=[0.003], K_SLOWi=[10](hrs), K_SLOWii=[0.005](hrs/ha)
		81	END=-1
Pluies Chicag	o 4hrs MacDonald Cartier avec l'effet des CC	82 ** 82 *# BASSIN NO	-
	une semaine estivale (sans école): Valeur de PKFp=-121	84 *# POINT D'ENTREE	: 58
	a/day selon le chapitre 6.1.2.2 de la Directive no.001 "Captage	85 *# SUPERFICIE	- 0 5515
et distributi		86 *# UTILISATION	: 100% COMMERCIAL
	sé sur un taux de 2.1 personnes/logement selon le recensement	87 *# EAUX PARASITES	: O DRAIN DANS SOL, O TOIT PLATS, O TOIT EN PENTE
2011		88 *# TYPE DE CONDUIT	E : Sanitaire
-Edifices n'on	t pas de drains français, mais seulement résidences et petits commerces	89 **	
- Les drains de	e toit des édifices sont raccordés au pluvial, mais nous avons mis 5% dans le j	90 COMPUTE DWF+WWF	NHYD=["21921"], DT=[1]min, AREA=[0.5515](ha),
-Taux d'infilt:	ration pris du Tableau: Débit d'eaux d'infiltration observés dans les	91	NDays=[0] (must be entered when no rainfall is provided)
reseaux d'ego	uts du Québec devant faire l'objet de réfection (Brière, 2009)	92 93	Residential (or Population) driven flows
TART	TZERO=[0.0], METOUT=[2], NSTORM=[1], NRUN=[100]	93	POP =[0], ADFp=[320] (1/cap/day), PKFp=[-121]
	["M04Ch100.3TM"] <storm filename,="" for="" line="" nstorm="" one="" per="" td="" time<=""><td>95</td><td> Com / Ind / Inst (or Area) driven flows</td></storm>	95	Com / Ind / Inst (or Area) driven flows
		96	XAcom=[1], ADFa=[126705.653](1/ha/day), PKFa=[1]
EAD STORM	STORM_FILENAME=["STORM.001"]	97	Groundwater baseflow
		98	XAgwf=[1], ADFg=[12000](1/ha/day), PKFg=[1]
AVE ALL HYDS		99	WET WEATHER FLOW (I/I) PARAMETERS
BASSIN NO		100	Direct connections C_DCON=[0], AVGLEN=[0](m)
POINT D'ENTREE		101 102	C_DCON=[0], AVGLEN=[0](m) Weeping tile connections
SUPERFICIE		103	C WEEP=[0], K WEEP=[0] (hrs)
	: 13.08% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL	104	Slow infiltration
EAUX PARASITES	: 0 DRAIN DANS SOL, 0 TOIT PLATS, 0 TOIT EN PENTE	105	C_SLOW=[0.003], K_SLOWi=[10](hrs), K_SLOWii=[0.005](hrs/ha)
TYPE DE CONDUI	TE : Pseudo	106	END=-1
COMMENTAIRES	: C_WEEP est 2% des lot qui contribuent au secteur résidentiel	107 **	-
	: C_DCON est estimé à 5% des drains de toit sont raccordés par erreur	108 **	-
MPUTE DWF+WWF	<pre>NHYD=["25985"], DT=[1]min, AREA=[38.20](ha),</pre>	109 **	-
DWFOIL DWE+WWE	NDID=[25905], DI=[1]min, AKLA=[30.20](hi), NDays=[0] (must be entered when no rainfall is provided)	110 FINISH	
	======== DRY WEATHER FLOW PARAMETERS ===============	111	
	Residential (or Population) driven flows		
	POP =[206], ADFp=[320] (1/cap/day), PKFp=[-121]		
	Com / Ind / Inst (or Area) driven flows		
	<pre>KAcom=[0.8692], ADFa=[31605](1/ha/day), PKFa=[1]</pre>		
	Groundwater baseflow		
	XAgwf=[1], ADFg=[16000](1/ha/day), PKFg=[1] ===================================		
	Direct connections		
	C DCON=[0.02], AVGLEN=[0](m)		
	Weeping tile connections		
	C_WEEP=[0.0005], K_WEEP=[0.75](hrs)		
	Slow infiltration		
	C_SLOW=[0.003], K_SLOWi=[10](hrs), K_SLOWii=[0.005](hrs/ha)		
	END=-1		
	: 57		
POINT D'ENTREE			
	: 4.6975		
UTILISATION	: 100% COMMERCIAL		
	: O DRAIN DANS SOL, O TOIT PLATS, O TOIT EN PENTE		
TYPE DE CONDUI			
COMMENTAIRE	: C_DCON est estimé à 5% des drains de toit sont raccordés par erreur		
MPUTE DWF+WWF			
DMPUTE DWF+WWF	<pre>NHYD=["6"], DT=[1]min, AREA=[4.6975](ha), NDays=[0] (must be entered when no rainfall is provided)</pre>		
	NDays=[0] (must be entered when no rainrall is provided)		
	Residential (or Population) driven flows		
	POP =[52], ADFp=[320] (1/cap/day), PKFp=[-121]		
	Com / Ind / Inst (or Area) driven flows		
	XAcom=[1], ADFa=[129617](1/ha/day), FKFa=[1]		
	-		
-	Page 1 of 2		Page 2 of 2

Sani.sum 13/05/2016 7:43 AM ____ _____
 SSSS
 W
 M
 M
 H
 H
 Y
 Y
 M
 M

 S
 W
 W
 MM
 MM
 H
 H
 Y
 Y
 M
 M

 S
 W
 W
 M
 M
 H
 H
 Y
 Y
 M
 M

 S
 W
 W
 M
 M
 H
 H
 Y
 M
 M

 S
 W
 M
 M
 H
 H
 Y
 M
 M
 222 2 2 222 11 11 11 11 11 000 333 ____ 000 Ver 5 OCT 2 222 000 \$ 254 333 2 222 0000 11 11 StormWater Management HYdrologic Model
 Sconmatter management introtogic model
 122
 000
 11
 sas

 SindErMO Ver/5.500
 SindErMO Ver/5.500
 122
 000
 11
 sas

 A single event and continuous hydrologic simulation model
 122
 122
 122
 122

 Distributed by:
 J.F. Sabourin and Associates Inc.
 123
 124
 124

 Ottawa, Ontarico:
 (613) 836-3884
 124
 124

 Gatineau, Oubeber:
 (12) 243-6858
 124

 E-Mail:
 sambymögifsa.Com
 124
 terms PROGRAM ARRAY DIMENSIONS
 Maximum value for ID numbers : 11
 Max. number of ring lines: 105408
 Max. number of flow points : 105408 S U M M A R Y O U T P U T RUN DATE: 2016-05-12 THE: 09:32:28 RUN COUNTER: 000240 Input file: Y:\Proj\li63\04 (Blan directeur)\Design\SMMIND(\Sani.dat Summary file: Y:\Proj\li63\04 (Plan directeur)\Design\SMMIND(\Sani.out Summary file: Y:\Proj\li63\04 (Plan directeur)\Design\SMMIND(\Sani.sum * User comments: 1: * 2 Project Name: [Plan directeur - bassin 56 à 58-] Project Number: [1163-04] Date : 02/08/2016 Modeller : [VCP] Company : JTSA License # : 4706892 ‡*' Secteur Hull - Windmill- Condition Existante Pluies Chicago 4hrs MacDonald Cartier avec l'effet des CC

Page 1 of 3

Sani	i.sum									1	3/05/20	16 7:43 AM	4
143 144	<pre># TYPE DE CONDUITE : S: R0100:C00006</pre>	DTmin-	ID:NHYD-									R.CDW	n
145	COMPUTE DWF+WWF		00:DWF			. 55			_date	0:00	13.85	n/a	
146		1.0	01:21921			. 55	.001	No	_date	11:31	14.06	n/a	
147	R0100:C00007												
148	FINISH												
149													
150	*******************	*******	********	***	*******	****	********	***	******	******	*******	********	1
151	WARNINGS / ERRORS	/ NOTES	3										
152			-										
153	Simulation ended on	2016-05	5-12 ;	at	09:32:29								
154				===									2
155													
350													

72	***************************************
73	
74	
75	
76	
22	
78	RUN#:COMMAND#
	R0100:C00001
80	KING CONT
81	
82	[TZERO = .00 hrs on 0] [METOUT= 2 (1=imperial, 2=metric output)]
83	[NETORM= 1]
84	
0 2	
0.0	Bendent Weeks (Die diesetere Anneis 56 2 50 1) Device Markens (1160 041
87	# Project Name: [Plan directeur - bassin 56 à 58-] Project Number: [1163-04] # Date : 02/05/2016
00	* Modeller : (VCP)
00	# Company : JFSA
0.0	* Company . 0154
91	* LICENSE * . 170032
	# Secteur Hull - Windmill- Condition Existante
93	
	Pluies Chicago 4hrs MacDonald Cartier avec l'effet des CC
95	
	≠ # -Simulation d'une semaine estivale (sans école): Valeur de PKFp=-121
	# -ADFQ=5500 1/ha/day selon le chapitre (sans ecole): Valeur de PKrp-121 # -ADFQ=5500 1/ha/day selon le chapitre 6.1.2.2 de la Directive no.001 "Captage
90	# et distribution de l'eau" # -Population basé sur un taux de 2.1 personnes/logement selon le recensement
	Formation base sur un caux de 2.1 personnes/logement selon le recensement \$ 2011
100	• 2011 • Stifician alast and device formation and any foldered at article and
101	# -Édifices n'ont pas de drains français, mais seulement résidences et petits commerces # - Les drains de toit des édifices sont raccordés au pluvial, mais nous avons mis 5% dans le p:
	# - Les d'anfiltration pris du Tableau: Débit d'eaux d'infiltration observés dans les
104	Frank a initiation pris da lableau: Debit a caux a initiation observes dans les réseaux d'égouts du Quèbec devant faire l'objet de réfection (Brière, 2009)
	* research a egouss an quebec devino faire i objec de refección (friete, 2005)
	RELOCCODE2
107	Filename = STORM.001
108	
109	(SDT=10.00:SDUR= 4.00:FTOT= 82.25)
	[301-10:00:300k- 4:00:P101- 82:23]
111	R0100:C00003
112	SAVE HYD START SAVING ALL SIMULATED HYDROGRAPHS.
113	SAVE HID START SAVING ALL STRUCKTED HIDROGRAFHS.
114	
115	
116	
	# BASSIN NO : 56
	POINT D'ENTRE: 25985
110	• FOIRI D'LAIRLE : 20500
120	<pre># SUPERFICIE : 38.20 ha # UTILISATION : 13.08% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL</pre>
121	# EAUX PARASITES : 0 DERIN DANS SOL, 0 TOIT FLATS, 0 TOIT EN PENTE
	# TYPE DE CONDUTE : DEGUD
122	<pre># TFE DE CONDUTE : Pseudo # COMMENTAIRES : C_WEEP est 2% des lot qui contribuent au secteur résidentiel</pre>
124	 Constantion is Constantion in the set of t
125	* : C_DCOM est estime a su des drains de toit sont raccords par erreur Rollou:CO0004DTmin-ID:NHYDAREAha-QPEAKcms-TpeakDate hh:mmRVmm-R.CDWI
126	CONDITION IN THE ADDRESS AND A CONDUCT AND ADDRESS AND
127	COMPUTE DWF+WWF 1.0 00:DWF 38.20 .020 No date 7:55 4.51 n/a 1.0 01:25985 38.20 .145 No_date 1:50 6.39 n/a
128	4 RIGGTN NO . 57
120	# BASSIN NO : 57 # POINT D'ENTREE : 6
120	
121	<pre># SUPERFICIE : 4.6975 # UTILISATION : 100% COMMERCIAL</pre>
122	<pre># UTILISATION : 100% COMMERCIAL # EAUX PARASITES : 0 DRAIN DANS SOL, 0 TOIT PLATS, 0 TOIT EN PENTE</pre>
122	T TUDE DE CONDITE - O DESIGNO COL, O TOLI FLEID, O TOLI LE FLEIL
124	# TYPE DE CONDUITE : Pseudo # COMENTAIRE : C_DCON est estimé à 5% des drains de toit sont raccordés par erreur PROMOCONDOS
125	* Commandation : C_DOW est estime a 5% des drains de tots sont laccordes par erreur Roldo:CO005Dmin-ID:NHYDRaha-QPEAKcms-TpeaKcms-TpeaKlate_hh:mmRAHm-R.CDWI
136	
130	COMPUTE DWF+WWF 1.0 00:DWF 4.70 .008 No_date 7:55 14.89 n/a 1.0 01:6 4.70 .033 No_date 1:31 16.74 n/a
	# BASSIN NO : 58
129	# POINT D'ENTREE - 21921
140	4 9110PDF1CTF - 0 5515
141	# SUPERFICIE : 0.5515 # UTILISATION : 100% COMMERCIAL
142	# CAUX PARASITES : 0 DRAIN DANS SOL, 0 TOIT PLATS, 0 TOIT EN PENTE
476	T MAN THEORY PALLA PARE DOLY . INT PLATE, . INT PLATE
	Page 2 of 3

13/05/2016 7:43 AM

Sani.sum

prev2051.dat	13	/05/2016 7:43 AM Sani	prev2051.dat		13/05/2016
0 Metric units	s / ID numbers OFF	72		Residential (or Population) driven flows	
				POP =[160], ADFp=[320] (1/cap/day), PKFp=[-121]	
	[Plan directeur - bassin 56 à 58-] Project Number: [1163-0	4] 74		Com / Ind / Inst (or Area) driven flows	
# Date :	02/05/2016	75		XAcom=[1], ADFa=[129617](1/ha/day), PKFa=[1]	
*# Modeller :	(VCP)	76 77		Groundwater baseflow	
*# Company : . *# License # :	ADDCOOD	78		XAgwf=[1], ADFg=[16000](1/ha/day), PKFg=[1] ===================================	
'# License # :	4/00092			Direct connections	
	- Windmill- Condition à l'ultime	80		C_DCON=[0.02], AVGLEN=[0] (m)	
•		81		Weeping tile connections	
	o 4hrs MacDonald Cartier avec l'effet des CC	82		C WEEP=[0], K WEEP=[0.75] (hrs)	
*#		83		Slow infiltration	
*# Simulation bas	sée sur les prévisions de 2051, c'est-à-dire 100 log./ ha	84		C_SLOW=[0.003], K_SLOWi=[10] (hrs), K_SLOWii=[0.005] (hrs/ha	a)
1		85		END=-1	
	une semaine estivale (sans école): Valeur de PKFp=-121 ha/day selon le chapitre 6.1.2.1 de la Directive no.004 "Résea		*# BASSIN NO		
*# d'égout"	ha/day selon ie chapitre 0.1.2.1 de la Directive h0.004 kesea	1 07	*# POINT D'ENTREE	. 21021	
*# -Population bas	sé sur un taux de 2.1 personnes/logement selon le recensement	89	*# SUPERFICIE	: 0.5515	
*# 2011		90	*# UTILISATION	: 100% COMMERCIAL	
*# -Édifices n'ont	t pas de drains français, mais seulement résidences et petits	commerces 91	*# EAUX PARASITES	: O DRAIN DANS SOL, O TOIT PLATS, O TOIT EN PENTE	
*# - Les drains de	e toit des édifices sont raccordés au pluvial, mais nous avons	mis 5% dans le 1 92	*# TYPE DE CONDUIT	E : Sanitaire	
*# -Taux d'infiltr	ration pris du Tableau: Débit d'eaux d'infiltration observés d	ans les 93	* # COMMENTAIRE	: Pas de stationnement	
	uts du Québec devant faire l'objet de réfection (Brière, 2009)				1
START			COMPUTE DWF+WWF	NHYD=["21921"], DT=[1]min, AREA=[0.5515](ha),	
STARL	<pre>TZERO=[0.0], METOUT=[2], NSTORM=[1], NRUN=[100] ["M04Chl00.STM"] <storm filename,="" for="" line="" nstorm<="" one="" per="" pre=""></storm></pre>	96 97		NDays=[0] (must be entered when no rainfall is provided) ========== DRY WEATHER FLOW PARAMETERS ====================================	
	[MOACHIOU.SIM] <storm filename,="" for="" line="" msiorm<="" one="" per="" td=""><td></td><td></td><td> Residential (or Population) driven flows</td><td></td></storm>			Residential (or Population) driven flows	
READ STORM	STORM FILENAME=["STORM.001"]	99		POP =[0], ADFp=[320] (1/cap/day), PKFp=[-121]	
		100		Com / Ind / Inst (or Area) driven flows	
	ON=[1]	101		XAcom=[1], ADFa=[117860](1/ha/day), PKFa=[1]	
·§		102		Groundwater baseflow	
*# BASSIN NO	: 56	103		XAgwf=[1], ADFg=[12000](1/ha/day), PKFg=[1]	
*# POINT D'ENTREE *# SUPERFICIE	: 25985	104		======= WET WEATHER FLOW (I/I) PARAMETERS =======	
*# UTILISATION	: 38.20 MA : 13.08% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL	105		Direct connections C DCON=[0], AVGLEN=[0](m)	
*# EAUX PARASITES	: 0 DRAIN DANS SOL, 0 TOIT PLATS, 0 TOIT EN PENTE	107		Weeping tile connections	
*# TYPE DE CONDUIT		108		C WEEP=[0], K WEEP=[0](hrs)	
*# COMMENTAIRES	: Les stationnements (2.98 ha) ont été considérés comme rés			Slow infiltration	
*#	: C_WEEP est 2% des lot qui contribuent au secteur résident			C_SLOW=[0.003], K_SLOWi=[10] (hrs), K_SLOWii=[0.005] (hrs/ha	a)
18	: C_DCON est estimé à 5% des drains de toit sont raccordés ;	par erreur 111		END=-1	
COMPUTE DWE+WWE	NHYD=["25985"], DT=[1]min, AREA=[38.20](ha),			-	
COMPUTE DWE+WWE	NDays=[0] (must be entered when no rainfall is provided)				
	======= DRY WEATHER FLOW PARAMETERS =========		FINISH		
	Residential (or Population) driven flows	116			
	POP =[1675], ADFp=[320] (1/cap/day), PKFp=[-121]				
	Com / Ind / Inst (or Area) driven flows				
	XAcom=[0.8692], ADFa=[31605](1/ha/day), PKFa=[1]				
	Groundwater baseflow				
	XAgwf=[1], ADFg=[16000](1/ha/day), PKFg=[1] ===================================				
	Direct connections				
	C DCON=[0.02], AVGLEN=[0](m)				
	Weeping tile connections				
	C_WEEP=[0.0005], K_WEEP=[0.75](hrs)				
	Slow infiltration				
	C_SLOW=[0.003], K_SLOWi=[10](hrs), K_SLOWii=[0.005](hrs/ha)				
	END=-1				
	: 57	1			
*# POINT D'ENTREE					
*# SUPERFICIE	: 4.6975				
*# UTILISATION	: 100% COMMERCIAL				
*# EAUX PARASITES	: 0 DRAIN DANS SOL, 0 TOIT PLATS, 0 TOIT EN PENTE				
*# TYPE DE CONDUIT	IE : Pseudo				
*# COMMENTAIRES	: Les stationnements (0.512 ha) ont été considérés comme ré				
1	: C_DCON est estimé à 5% des drains de toit sont raccordés ;	par erreur			
**					
COMPUTE DWF+WWF	<pre>NHYD=["6"], DT=[1]min, AREA=[4.6975](ha), NDays=[0] (must be entered when no rainfall is provided)</pre>				
	NDays=[0] (must be entered when no rainfall is provided) ======== DRY WEATHER FLOW PARAMETERS ====================================				
	Page 1 of 2			Page 2 of 2	

Sani_prev2051.sum 13/05/2016 7:44 AM _____ _____
 SSSS
 W
 M
 M
 H
 H
 Y
 Y
 M
 M

 S
 W
 W
 MM
 H
 H
 Y
 Y
 M
 M

 S
 W
 W
 MM
 H
 H
 Y
 Y
 M
 M

 S
 W
 W
 M
 M
 H
 H
 Y
 M
 M

 S
 W
 W
 M
 M
 H
 H
 Y
 M
 M

 S
 W
 M
 M
 H
 H
 Y
 M
 M
 000 222 2 2 222 11 11 11 11 11 000 333 ____ Ver 5 OCT 2 222 000 11 3 **#** 254 11 333 **#** 2222 °000[°] StormWater Management HYdrologic Model two process Area of the process of the proces S U M M A R Y O U T P U T RUN DATE: 2016-05-12 THE: 09:43:19 RUN COUNTER: 000241 Laput file: Y: (Proj)(162)04 (Plan dimensur/)(Design/SHMETMON/Prévision 2051/Sani_prev2051.cs Summary file: Y: (Proj)(1163)04 (Plan dimensur/)(Design/SHMETMON/Prévision 2051/Sani_prev2051.cs Summary file: Y: (Proj)(1163)04 (Plan dimensur/)(Design/SHMETMON/Prévision 2051/Sani_prev2051.cs * User comments: * 2 #
#
Project Name: [Plan directeur - bassin 56 à 58-] Project Number: [1163-04]
Date : 02/05/2016
Modeller : [UCP]
Company : JTSA
License # : 4706882
License # : 4706882 Secteur Hull - Windmill- Condition à l'ultime Secteur Hull - Windmill- Condition à l'ultime Pluies Chicago Anrs MacDonald Cartier avec l'effet des CC Simulation basée sur les prévisions de 2051, c'est-à-dire Simulation basée sur les prévisions de 2051, c'est-à-dire 100 log./ ha -Simulation d'une semaine estivale (sans école): Valeur de PKFp=-121 -ADFg=16000 1/ha/day selon le chapitre 6.1.2.1 de la Directive no.004 "Réseau d'égut" -Population basé sur un taux de 2.1 personnes/logement selon le recensement repulation base sur un taux de 2.1 personnes/logement seion Le recensement 2011
 Zolifices n'ont pas de drains français, mais seulement résidences et petits commerces
 Les drains de toit des édifices sont raccordés au pluvial, mais nous avons mis 5% d
 Taux d'infiltration pris du Tableau: Débit d'éaux d'infiltration observés dans les
 réseaux d'égouts du Québec devant faire l'objet de réfection (Briter, 2009) dans le p

Page 1 of 3

	1.0 01	:6	4.70	.033	No date	1:31	17.47	n/a
# BASSIN NO : S	58				-			
# POINT D'ENTREE : 2	21921							
SUPERFICIE : (
# UTILISATION : 1								
# EAUX PARASITES : (SOL, 0 TO	IT PLATS, 0 1	OIT EN	PENTE			
# TYPE DE CONDUITE								
# COMMENTAIRE : 1								
R0100:C00006	DTmin-TI							B C
COMPUTE DWF+WWF	1.0 00): DWF	. 55	.001	No_date	0:00	12.97	n/a
COMPUTE DWF+WWF	1.0 00):DWF 1:21921	. 55	.001	No_date No_date	0:00	12.97	n/a
COMPUTE DWF+WWF R0100:C00007	1.0 00):DWF 1:21921	. 55	.001	No_date No_date	0:00	12.97	n/a
COMPUTE DWF+WWF	1.0 00):DWF 1:21921	. 55	.001	No_date No_date	0:00	12.97	n/a
COMPUTE DWF+WWF R0100:C00007 FINISH	1.0 00):DWF L:21921	. 55 . 55	.001	No_date No_date	0:00	12.97 13.17	n/a n/a
COMPUTE DWF+WWF R0100:C00007 FINISH	1.0 00):DWF L:21921	. 55 . 55	.001	No_date No_date	0:00	12.97 13.17	n/a n/a
COMPUTE DWF+WWF R0100:C00007 FINISH	1.0 00):DWF L:21921	. 55 . 55	.001	No_date No_date	0:00	12.97 13.17	n/a n/a
COMPUTE DWF+WWF R0100:C00007 FINISH	1.0 00 1.0 01):DWF 1:21921	.55	.001	No_date No_date	0:00	12.97 13.17	n/a n/a

72	
73	** END OF RUN : 99
74 75	*****
76 77	
78	
80	RUN#:COMMAND#
82	R0100:C00001
83 84	[TZERO = .00 hrs on 0] [METOUT= 2 (1=imperial, 2=metric output)]
85 86	[NSTORM= 1] [NRUN = 0100]
87 88	# Project Name: (Plan directeur - bassin 56 à 58-) Project Number: (1163-04)
89 90	<pre># Date : 02/05/2016 # Modeller : [VCP]</pre>
91 92	<pre># Company : JFSA # License # : 4706892</pre>
93	# Secteur Hull - Windmill- Condition à l'ultime
95 95	ŧ
97	# Pluies Chicago 4hrs MacDonald Cartier avec l'effet des CC # 8 Similation basis ann las asimisians de 2051, clast à dise 100 los / basis 8 Similation basis ann las asimisians de 2051, clast à dise 100 los / basis 8 Similation basis anno 100 los / basis anno 100 los / basis anno 100 los / basis 8 Similation basis anno 100 los / basis anno 100 lo
99	
101	# -Simulation d'une semaine estivale (sans école): Valeur de PKFp=-121 # -ADFg=16000 1/ha/day selon le chapitre 6.1.2.1 de la Directive no.004 "Réseau
	# d'égout" # -Population basé sur un taux de 2.1 personnes/logement selon le recensement
105	# 2011 # -Édifices n'ont pas de drains français, mais seulement résidences et petits commerces
107	# - Les drains de toit des édifices sont raccordés au pluvial, mais nous avons mis 5% dans le p: # -Taux d'infiltration pris du Tableau: Débit d'eaux d'infiltration observés dans les
108	‡ réseaux d'égouts du Québec devant faire l'objet de réfection (Brière, 2009) R0100:C00002
110	READ STORM
111	Filename = STORM.001
112 113	
114	Comment = Chicago 4 hr 100ans aeroport Ottawa Avec CC (SDT=10 00-SDUR= 4 00-PTOT= 82 251
	[SDT=10.00:SDUR= 4.00:PTOT= 82.25] R0100:C00003
115 116	[SDT=10.00:SDUR= 4.00:FTOT= 82.25] R0100:C00003
116 117	[SDT=10.00:SDUR= 4.00:PTOT= 82.25] R0100:C00003
116	[SDT=10.00:SDUR= 4.00:FTOT= 82.25] R0100:C00003
116 117 118 119 120	[SDT=10.00.SDUR= 4.00:FTOT= 82.25] ROID0:COUCOUD
116 117 118 119 120 121	[JDT=10.00:SDUR= 4.00:FTOT= 82.25] RODO:CONDOG
116 117 118 119 120 121 122 123	[SDT=10.00:SDUR= 4.00:FTOT= 82.25] ROIO0:CONDOG
116 117 118 119 120 121 122 123 124	[SDT=10.00.SDUR= 4.00:FTOT= 82.25] ROID0:CODOD
116 117 118 119 120 121 122 123 124 125	[SDT=10.00:SDUR= 4.00:FTOT= 82.25] ROIO0:CODO03
116 117 118 119 120 121 122 123 124 125 126 127	[SDT=10.00:SDUR= 4.00:FTOT= 82.25] ROIO0:CODO03
116 117 118 119 120 121 122 123 124 125 126 127 128	[JDT=10.00:SDUR= 4.00:FTOT= 82.25] ROIO:CODODO- I SAVE HTD START SAVING ALL SIMULATED HYDROGRAPHS. BASSIN NO : 56 # POINT D'ENTREE : 25965 # UTILISATION IS 0.20 ha SUPERFICIE : 38.20 ha # UTILISATION IS 13.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 13.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 13.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 13.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL, 86.92% COMMERCIAL ET INDUSTRIEL # UTILISATION IS : 14.06% RESIDENTIEL # UTI
116 117 118 119 120 121 122 123 124 125 126 127 128 129	[SDT=10.00:SDUR= 4.00:FTOT= 82.25] ROIO0:CODO03
116 117 118 119 120 121 122 123 124 125 126 127 128 129	<pre>[JDT=10.00:SDUR= 4.00:PTOT= 82.25] BOIO:CONDOG</pre>
116 117 118 119 120 121 122 123 124 125 126 127 128 129 130 131 132	[SDT=10.00:SDUR= 4.00:PTOT= 82.25] ROIO:CONDOG
116 117 118 119 120 121 122 123 124 125 126 127 128 129 130 131 132 133	[SDT=10.00:SDUR= 4.00:FTOT= 82.25] ROI00:CODO02
116 117 118 119 121 122 123 124 125 126 127 128 129 130 131 132 133	[JDT=10.00:SDUR= 4.00:FTOT= 82.25] ROIO0:CONDOG
116 117 118 129 121 122 123 124 125 126 127 128 129 130 131 132 133 134 135	[SDT=10.00:SDUR= 4.00:FTOT= 82.25] ROI00:CODOD
116 117 118 129 121 122 123 124 125 126 127 128 129 130 131 132 133 134 135	[JDT=10.00:SDUR= 4.00:FTOT= 82.25] ROIO0:CONDOG
116 117 118 120 121 122 122 122 126 127 126 127 120 131 132 134 135 136 137 138	<pre>[JDT=10.00:SDUR= 4.00:FTOT= 82.25] ROI00:CONDON</pre>
116 117 118 120 121 122 124 125 126 127 128 129 130 131 132 134 135 136 137 138	<pre>[3DT=10.00:3DUR= 4.00:PTOT= 82.25] BOIO:COODO2</pre>
116 117 119 120 122 123 124 125 126 127 128 130 131 133 134 136 137 138 138 138 138	<pre>[JDT=10.00:SDUR= 4.00:FTOT= 82.25] ROIO0:CONDON</pre>
116 117 119 120 1212 123 124 125 126 127 128 130 131 1334 1356 137 138 138 138 138	<pre>[3DT=10.00:3DUR= 4.00:PTOT= 82.25] BOIO:COODO2</pre>
116 117 118 119 120 121 122 123 124 125 126 127 128 129 130 131 132 133 134 135 136 137 138 139 140	<pre>[3DT=10.00:SDUR= 4.00:PTOT= 82.25] BOIO0:CONDOS</pre>

......







INVENTAIRE DES BÂTIMENTS




Experts-conseils en ressources hydriques et en environnement


Bassin	Rue	Identification	Туре	Débit commercial (L/j)	Débit résidentiel (L/j)
56	Laurier	Musée Canadien de l'histoire	Cinéma	4425	(47))
50	Launer	Musee canadien de l'histoire	Musée	125000	
56	Laurier	Hôtel Four point	Hôtel	60300	
56	Laurier	Resto-Bar l'Ardoise	Restaurant	6250	
56	Laurier	Usine Kruger	Industriel		
		Maison du citoyen	Bureaux (6 étages)	22500	
56	Laurier	Salles de théatre	Théâtre	22980	
		Salles de réunion	Salle	3195	
		École	École	300	
56	Laurier	Édifice Jos Montferrand -Palais de justice	Bureaux	41250	
56	Laurier	Édifice Portage III	Bureaux	337500	
56 56	Victoria	Place du Portage I (50 Victoria)	Bureaux	165000	
56	Victoria	Bistro Vitalie 67 Victoria 61-63 rue Victoria	Restaurant	3125	2880
56	Victoria Victoria	85 rue Victoria	Logement	3000	2880
56	Victoria		Bureaux (3 étages)	5000	2000
56	Hôtel-de-Ville	95-97 rue Victoria (immeuble à logement) Édifice du Portage II	Logement Bureaux	67500	2880
56	Hôtel-de-Ville	105, Hôtel-de-Ville (Place Bell)	Bureaux	11250	
56	Hôtel-de-Ville	Planète poutine	Restaurant	3125	
56	Hôtel-de-Ville	CrocoBento	Restaurant	3125	
56	Hôtel-de-Ville	Nettoyeur à sec	Magasin au détail	200	
56	Hôtel-de-Ville	Avintage	Magasin au détail	200	
56	Hôtel-de-Ville	Point de départ	Club sportif	250	
56	Hôtel-de-Ville	Duvernay Studio et suite	Logement	250	20160
56	Wright	115 Wright - Delev, Beaudoin Avocat	Bureaux	500	20100
56	Wright	Duplex-triplex rue Wright	Logement	500	26240
56	Wright	Novalogix	Bureaux	500	20210
56	Wright	136 Wrigth	Bureaux	1000	
56	Wellington	147 rue Wellington	Bureaux	1000	
56	Wellington	Duplex-triplex rue Wellington	Logement		3520
56	Wellington	149 rue Wellington	Bureaux	500	
56	Wellington	160-168 rue Wellington	Bureaux	1500	
56	Wellington	165 rue Wellington	Magasin commercial	600	
56	Laval	45 à 47 rue Laval	Restaurant	6250	
50	Lavai	45 a 47 fue Lavai	Magasin commercial	200	
56	Laval	41 à 43 rue Laval	Restaurant	3125	
50	Lavai		Salon de beauté	3250	
56	Laval	39 rue Laval	Restaurant	3125	
56	Laval	37 rue Laval (Vivazen)	Salon de beauté	3250	
56	Laval	35 rue Laval (Vision centre-ville)	Bureaux	500	
56	Laval	33 rue Laval (Groupe Marc Dubé)	Bureaux	500	
56	Laval	31 rue Laval (tatouage Hellbound)	Magasin commercial	200	
56	Laval	36 rue Laval (Bar)	Bar	6250	
56	Laval	42-44 rue Laval	Bar	6250	
			Logement		1600
56	Laval	48-50 rue Laval	Logement		1600
56	Aubry	2 rue Aubry	Logement		1600
56	Aubry	3-9 rue Aubry	Restaurants - Bar	6250	
56	Kent	3 rue Kent (Le Bistro)	Bar	6250	
56	Promenade du Portage	123-125 Promenade du Portage	Restaurant	3125	
			Magasin commercial	400	
56	Promenade du Portage	127-131 Promenade du Portage	Logement		960
	-		Restaurant	3125	
56	Promenade du Portage	133-141 Promenade du Portage	Magasin commercial	1400	
56	Promenade du Portage	143-147 Promenade du Portage	Magasin commercial	400	
56	Promenade du Portage	149 Promenade du Portage	Magasin commercial	200	
56	Promenade du Portage	153 Promenade du Portage	Centre dentaire	1825	
56	Promenade du Portage	155 Promenade du Portage	Magasin commercial	200	
56	Promenade du Portage	157 Promenade du Portage	Magasin commercial	200	
56	Promenade du Portage	159 Promenade du Portage	Magasin commercial	200	
56	Promenade du Portage	161 Promenade du Portage	Magasin commercial	200	
56	Promenade du Portage	163 Promenade du Portage	Restaurant	3125	
			Magasin commercial	400	
56	Promenade du Portage	169 Promenade du Portage	Logement		2880
20					
56 56	Promenade du Portage	171 Promenade du Portage	Magasin commercial Restaurant	200 1875	

Bassin	Rue	Identification	Туре	Débit commercial (L/j)	Débit résidentiel (L/j)	
56	Dramanada du Dantana	172 Promonodo du Portogo	Magasin commercial	200		
56	Promenade du Portage	173 Promenade du Portage	Logement		1600	
56	Promenade du Portage	175 Promenade du Portage	Magasin commercial	200		
		175 Fromenade du Fortage	Restaurant	9375		
56	Promenade du Portage	177 Promenade du Portage	Magasin commercial	200		
50	r onenade da r ortage	177 Homenade da Fortage	Magasin commercial	800		
56	Promenade du Portage	179 (Coiffure Chez Henri)	Bureaux	4000		
		· · ·	Salon de coiffure	6500		
56	Promenade du Portage	191 (Place des Explorateurs)	Bureaux	6000		
56	Promenade du Portage	200 (Place du Centre)	Bureaux	67500		
57	Leduc	8-10 rue Leduc	Cinéma	4425		
	r data	Terrene Chaudibre (10 (terren)	Magasin commercial	200		
57	Eddy	Terrasse Chaudière (19 étages)	Bureaux	260000		
57	Eddy	22 rue Eddy	Bureaux	225000		
		40 Promenade du Portage	Postouront	3125		
57	Promenade du Portage	Galo piri piri Howard's pawn shop	Restaurant Magasin commercial	200		
		subway	Restaurant	3125		
		48 Promenade du Portage	Restaurant	5125		
57	Promenade du Portage	studio palm beach, salon de bronzage	Magasin commercial	200		
57	r tomenade da r ortage	Dermabronze	Magasin commercial	200		
		50 Promenade du Portage	Magasin commercial	200		
57	Promenade du Portage	Le Petit Chicago	Bar	6250		
57	Promenade du Portage	Nouveau commerces	Magasin commercial	2000		
		51 Promenade du Portage				
57	Promenade du Portage	Université du Mexique	École	45000		
57	Promenade du Portage	60 Promenade du Portage	Magasin commercial	600		
	-	61 Promenade du Portage				
57	Promenade du Portage	Banque Scotia	Bureaux	4500		
67	Dremenada du Dantaga	70 Promenade du Portage				
57	Promenade du Portage	Le pub du bon vivant	Restaurant	6250		
57	Promenade du Portage	75 Promenade du Portage	Magasin commercial	800		
57	Promenade du Portage	77 Promenade du Portage	Restaurant	3125		
5,	i tomendue du tortage	// Homenade ad Fortage	Logement		2880	
57	Promenade du Portage	78-84 Promenade du Portage	Restaurant	6250		
57			Logement		4160	
57	Promenade du Portage	85 Promenade du Portage	Magasin commercial	600		
		-	Logement		5440	
57	Promenade du Portage	86-92 Promenade du Portage	Bureaux	9375		
		Clinique podiatrique	Clinique	750		
57	Dramanada du Dautaar	00 102 Dromonodo du Dante	Restaurant	3125		
57	Promenade du Portage	99-103 Promenade du Portage	Restaurant	3125	44.00	
57	Dromonado du Dantear	107 Promonado du Portaza	Logement	2125	4160	
57	Promenade du Portage	107 Promenade du Portage	Bureaux	3125		
57	Promenade du Portage	112 à 114 Promenade du Portage	Salar /ma	1050		
		Centre d'esthétique et d'électrolyse	Salon/spa Restaurant	1950 3125		
57	Promenade du Portage	Pizzeria 115 Promenade du Portage	Restaurant	1250		
57	Promenade du Portage Promenade du Portage	115 Promenade du Portage 116 Promenade du Portage	Bureaux Bureaux	2500		
57	Promenade du Portage	117 Promenade du Portage (Mardi Gras)	Bar	6250		
57	Promenade du Portage	119 Promenade du Portage (Mardi Gras)	Bureaux	1250		
57	ronage du Fortage	120 Promenade du Portage	Durcdux	1230		
		Voyage intair Transit	Magasin commercial	400		
57	Promenade du Portage	Entreprise systems and solutions group	Magasin commercial	400		
		Locaux à louer	Magasin commercial	400		
58	Promenade du Portage	1 Promenade du Portage	Bureaux	65000	1	











JFSA



Profil de la conduite réceptrice en condition actuelle



Profil de la conduite réceptrice en condition future

APPENDIX B

Water Supply

Windmill Zibi - Ontario Phase 1A

Water Demand Design Flows per Unit Count City of Ottawa - Water Distribution Guidelines, July 2010



Phase	Block	Туре	Unit	Rate	No. of Units	Avg Day	Max Day	Peak Hour
						L/min	L/min	L/min
1	208	Office	75	L/p/d	140	0.8	1.2	2.1
1	208	Retail	2.5	L/m²/d	1457	2.5	3.8	6.8
1	208	Restaurant	125	L/seat/d	8	0.7	1.0	1.9
1	205.5A	Res	563.5	L/unit/d	71	27.8	136.1	205.6
1	205.5A	Retail	2.5	L/m²/d	768	1.3	2.0	3.6
Temp Office - Albert	EX	Office	75	L/p/d	30	1.6	2.3	4.2
					Total	34.7	146.5	224.2

Notes:

* Development stats per Windmill schedule dated 2016-02-01 and additional information received via email 2016-02-08.

* Office unit rate per Ontario Building Code 8.2.1.3.B. Assuming 1 employee per 9.3m² of floor space.

* Residential Unit rate assuming 70% one bedroom (1.4p/unit), 30% two bedroom (2.1 p/unit)

* Windmill estimated maximum number of employees occupying Albert Island

* Energy Ottawa maximum employees to work at Chaudiere Office provided by EO via letter dated March 1, 2016 Max Day PF Peak Hour PF

Estimated Total Residential Population 115 4.9 7.4

Fire Flow Estimation per Fire Underwriters Survey

Water Supply For Public Fire Protection - 1999

Fire Flow Required - Block 205

1. Base Requirement



$F = 220C\sqrt{A}$	L/min	Where F is the fire flow, C	is the Type of construction and ${f A}$ is the Total floor area
I = LLOC VII			

Type of Construction: Composite

40% Wood Frame

Vood Framo

60% Non-Combustible Construction

С	1.08	Type of Construction Coefficient per FUS Part II, Section 1
Α	6250.0	m ² Total floor area based on FUS Part II section 1

Fire Flow 18783.9 L/min

19000.0 L/min rounded to the nearest 1,000 L/min

Adjustments

2. Reduction for Occupancy Type

Limited Combustible	-15%

Fire Flow 16150.0 L/min

3. Reduction for Sprinkler Protection

Sprinklered	-50%
Reduction	-8075 L/min

4. Increase for Separation Distance

 10.1m-20m >45m	15% 0%	
% Increase	55%	value not to exceed 75% per FUS Part II, Section 4
Increase	8882.5 L/min	-

Total Fire Flow

 Fire Flow
 16957.5 L/min
 fire flow not to exceed 45,000 L/min nor be less than 2,000 L/min per FUS Section 4

 17000.0 L/min
 rounded to the nearest 1,000 L/min

Notes:

-Type of construction, Occupancy Type and Sprinkler Protection information provided by ______. -Calculations based on Fire Underwriters Survey - Part II

Fire Flow Estimation per Fire Underwriters Survey

Water Supply For Public Fire Protection - 1999

Fire Flow Required - Block 208

1. Base Requirement



60% Non-Combustible Construction

$F = 220C\sqrt{A}$ L/min	Where F is the fire flow, C is the Type of construction and A is the Total floor area
--------------------------	--

Type of Construction: Composite 40% Wood Frame

C 1.08 Type of Construction Coefficient per FUS Part II, Section 1
 A 2533.0 m² Total floor area based on FUS Part II section 1

Fire Flow 11958.2 L/min

12000.0 L/min rounded to the nearest 1,000 L/min

Adjustments

2. Reduction for Occupancy Type

Limited Combustible	-15%

Fire Flow	10200.0 L/min

3. Reduction for Sprinkler Protection

Sprinklered	-50%
Reduction	-5100 L/min

4. Increase for Separation Distance

	Increase	6120.0 L/min	-
	% Increase	60%	value not to exceed 75% per FUS Part II, Section 4
W	3.1m-10m	20%	_
Е	10.1m-20m	15%	
S	20.1m-30m	10%	
Ν	10.1m-20m	15%	

Total Fire Flow

Fire Flow 11220.0 L/min fire flow not to exceed 45,000 L/min nor be less than 2,000 L/min per FUS Section 4 11000.0 L/min rounded to the nearest 1,000 L/min

Notes:

-Type of construction, Occupancy Type and Sprinkler Protection information provided by ______. -Calculations based on Fire Underwriters Survey - Part II

Steve Merrick

Subject:

RE: Chaudiere/Albert Island Development - Water Boundary Condition Request

From: Bazinet, Kristin [mailto:Kristin.Bazinet@ottawa.ca]
Sent: August-04-15 7:30 AM
To: Steve Merrick <smerrick@dsel.ca>; 'Adam Fobert' <afobert@DSEL.ca>
Cc: Buchanan, Richard <Richard.Buchanan@ottawa.ca>; Mottalib, Abdul <Abdul.Mottalib@ottawa.ca>
Subject: FW: Chaudiere/Albert Island Development - Water Boundary Condition Request

Hi Steve – find attached the boundary conditions as requested.

Thanks, Kristin

Kristin Bazinet. P.Eng Development Review Examen des demandes d'aménagement



City of Ottawa | Ville d'Ottawa 613.580.2424 ext./poste 12180 ottawa.ca/planning / ottawa.ca/urbanisme

The following are boundary conditions, HGL, for hydraulic analysis at the Chaudière/Albert Islands Phase 1(Pressure Zone 1W), assumed to be connected to (see attached PDF for location):

- 1) 406mm on Wellington
- 2) 305mm on Booth

Minimum HGL = 108.0m (same at both locations)

Maximum HGL = 115.1m (same at both locations), the maximum pressure is estimated to be greater than 80 psi. A pressure check at completion of construction is recommended to determine if pressure control is required.

Fire Flow*	Connection 1 (Wellington)
150 L/s	110.7m
217 L/s	110.1m
250 L/s	109.8m

300 L/s	109.2m
367 L/s	108.3m

*Includes Max Day demands of 2.49 L/s distributed evenly between both connection points (i.e. 1.75L/s at each connection point)

Fire Flow*	Connection 2 (Booth)
150 L/s	109.4m
217 L/s	107.4m
250 L/s	106.3m
300 L/s	104.2m
367 L/s	101.1m

*Includes Max Day demands of 2.49 L/s distributed evenly between both connection points (i.e. 1.75 L/s at each connection point)

These are for current conditions and are based on computer model simulation.

Disclaimer: The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation.

From: Buchanan, Richard
Sent: July 28, 2015 2:46 PM
To: Bazinet, Kristin
Subject: FW: Chaudiere/Albert Island Development - Water Boundary Condition Request

Can you send this in for the boundary conditions and forward to DSEL?

Richard Buchanan, CET Program Manager, Development Review (Urban Services) Outer Gestionaire de programme (Secteur urbain) Exterieur



City of Ottawa | Ville d'Ottawa 613.580.2424 ext./poste 27801 From: Steve Merrick [mailto:smerrick@dsel.ca]
Sent: July-28-15 1:17 PM
To: Abdul <<u>Abdul.Mottalib@ottawa.ca</u>>
Cc: Adam Fobert <<u>afobert@dsel.ca</u>>
Subject: RE: Chaudiere/Albert Island Development - Water Boundary Condition Request

Hi Abdul,

We require updated boundary conditions for Phase 1 of the above noted development. The connection locations are consistent with previous requests. Anticipated demands are as follows:

	L/min	L/s
Avg. Daily	69.6	1.16
Max Day	149.4	2.49
Peak Hour	228.7	3.81

Max Day + Fire Flow = 149.4 + 20,000 L/min

I hope you can expedite this process we are looking to submit as soon as possible.


Steve Merrick, EIT. Project Coordinator / Junior Designer


DSEL david schaeffer engineering ltd.

120 Iber Road, Unit 103 Stittsville, ON K2S 1E9

phone: (613) 836-0856 ext. 561 **fax**: (613) 836-7183 **email**: smerrick@DSEL.ca

This email, including any attachments, is for the sole use of the intended recipient(s) and may contain private, confidential, and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited. If you are not the intended recipient, or if this information has been inappropriately forwarded to you, please contact the sender by reply email and destroy all copies of the original.





	2017-07-10_717_slm.rpt		
Page 1	8/9/20	017 10:35:37 AM	
******	*************	******	
*	EPANET	*	
*	Hydraulic and Water Quality	*	
*	Analysis for Pipe Networks	*	
*	Version 2.0	*	

Input File: 2017-07-10_717_slm.net

Link - No	ode T	able	:
-----------	-------	------	---

Link	Start	End	Length	Diameter
ID	Node	Node	m	mm
43	29	BOOTH_CONNECTION	3	300
9	11	8	20	300
10	11	1	70	300
12	FH1	1	2.2	200
19	11	BLOCK205-A	10	150
21	1	BLOCK208	10	150
24	8	9	21	300
25	9	FH2	2	200
28	Albert	3	22	200
1	3	2	89	300
2	2	1	20	300
3	29	3	75	300
4	FH3	Albert	5	200

Node Results:

Node ID	Demand LPM	Head m	Pressure m	Quality hours	
29	0.00	115.10	62.35	0.00	
1	0.00	115.10	63.99	0.00	
8	0.00	115.10	62.45	0.00	
FH1	0.00	115.10	61.14	0.00	
11	0.00	115.10	62.70	0.00	
BLOCK205-A	29.10	115.10	60.05	0.00	
BLOCK208	4.00	115.10	60.15	0.00	
FH2	0.00	115.10	59.82	0.00	
9	0.00	115.10	62.67	0.00	
Albert	1.60	115.10	61.35	0.00	
3	0.00	115.10	61.35	0.00	
2	0.00	115.10	64.10	0.00	
FH3	0.00	115.10	61.35	0.00	

AVERAGE DAY


		2017-07-10_	_717_slm.rpt	
BOOTH_CONNECTION	-34.70	115.10	0.00	1.00 Reservoir

	▲	
,	T	

Page	2
1 480	-
Link	Results:

Link ID	Flow LPM	VelocityUni m/s	t Headloss. m/km	Status
43	-34.70	0.01	0.00	Open
9	0.00	0.00	0.00	0pen
10	-29.10	0.01	0.00	Open
12	0.00	0.00	0.00	Open
19	29.10	0.03	0.02	0pen
21	4.00	0.00	0.00	Open
24	0.00	0.00	0.00	Open
25	0.00	0.00	0.00	0pen
28	-1.60	0.00	0.00	Open
1	33.10	0.01	0.00	0pen
2	33.10	0.01	0.00	Open
3	34.70	0.01	0.00	Open
4	0.00	0.00	0.00	Open

MAX DAY + FIRE FLOW



	2017-07-10_717_slm.rpt	
Page 1	8/9/20	17 10:38:05 AM
*************	*************	******
*	ΕΡΑΝΕΤ	*
*	Hydraulic and Water Quality	*
*	Analysis for Pipe Networks	*
*	Version 2.0	*
******	*************	******

Input File: 2017-07-10_717_slm.net

Link - No	ode T	able	:
-----------	-------	------	---

Link	Start	End	Length	Diameter
ID	Node	Node	m	mm
43	29	BOOTH_CONNECTION	3	300
9	11	8	20	300
10	11	1	70	300
12	FH1	1	2.2	200
19	11	BLOCK205-A	10	150
21	1	BLOCK208	10	150
24	8	9	21	300
25	9	FH2	2	200
28	Albert	3	22	200
1	3	2	89	300
2	2	1	20	300
3	29	3	75	300
4	FH3	Albert	5	200

Node Results:

Node	Demand	Head		Quality	
ID	LPM	m	m	hours	
29	0.00	104.04	51.29	0.00	
1	0.00	85.63	34.52	0.00	
8	0.00	83.81	31.16	0.00	
FH1	8500.00	79.46	25.50	0.00	
11	0.00	84.26	31.86	0.00	
BLOCK205-A	138.10	84.26	29.21	0.00	
BLOCK208	6.00	85.63	30.68	0.00	
FH2	8500.00	77.25	21.97	0.00	
9	0.00	83.39	30.96	0.00	
Albert	2.30	93.14	39.39	0.00	
3	0.00	93.14	39.39	0.00	
2	0.00	88.17	37.17	0.00	
FH3	0.00	93.14	39.39	0.00	

MAX DAY + FIRE FLOW


		2017-07-10	_717_slm.rpt	
BOOTH_CONNECTION	-17146.40	104.20	0.00	1.00 Reservoir

4		١.	
,	н		

Page 2 Link Results:

Link	Flow	VelocityUr	nit Headloss	Status
ID	LPM	m/s	m/km	
43	-17146.40	4.04	52.11	Open
9	8500.00	2.00	22.39	Open
10	-8638.10	2.04	19.61	Open
12	-8500.00	4.51	2804.03	Open
L9	138.10	0.13	0.46	Open
1	6.00	0.01	0.00	Open
4	8500.00	2.00	20.05	Open
5	8500.00	4.51	3072.40	Open
.8	-2.30	0.00	0.00	Open
	17144.10	4.04	55.83	0pen
	17144.10	4.04	127.01	0pen
	17146.40	4.04	145.36	Open
Ļ	0.00	0.00	0.00	Open

PEAK HOUR



	2017-07-10_717_slm.rpt					
Page 1	8/9/20	017 10:41:20 AM				
*************	<*************************************	******				
*	EPANET	*				
*	Hydraulic and Water Quality	*				
*	Analysis for Pipe Networks	*				
*	Version 2.0	*				

Input File: 2017-07-10_717_slm.net

Link - No	ode T	able	:
-----------	-------	------	---

Link	Start	End	Length	Diameter
ID	Node	Node	m	mm
43	29	BOOTH_CONNECTION	3	300
9	11	8	20	300
10	11	1	70	300
12	FH1	1	2.2	200
19	11	BLOCK205-A	10	150
21	1	BLOCK208	10	150
24	8	9	21	300
25	9	FH2	2	200
28	Albert	3	22	200
1	3	2	89	300
2	2	1	20	300
3	29	3	75	300
4	FH3	Albert	5	200

Node Results:

Node ID	Demand LPM	Head m	Pressure m	Quality hours	
29	0.00	108.10	55.35	0.00	
1	0.00	108.10	56.99	0.00	
8	0.00	108.09	55.44	0.00	
FH1	0.00	108.10	54.14	0.00	
11	0.00	108.09	55.69	0.00	
BLOCK205-A	209.20	108.08	53.03	0.00	
BLOCK208	10.80	108.10	53.15	0.00	
FH2	0.00	108.09	52.81	0.00	
9	0.00	108.09	55.66	0.00	
Albert	4.20	108.10	54.35	0.00	
3	0.00	108.10	54.35	0.00	
2	0.00	108.10	57.10	0.00	
FH3	0.00	108.10	54.35	0.00	

PEAK HOUR

		2017-07-10	717_slm.rpt	
BOOTH_CONNECTION	-224.20	108.10	0.00	1.00 Reservoir

♠

Page 2 Link Results:

link	Flow	VelocityUni	t Headloss	Status
ID	LPM	m/s	m/km	
.3	-224.20	0.05	0.02	Open
)	0.00	0.00	0.00	0pen
0	-209.20	0.05	0.02	Open
.2	0.00	0.00	0.00	Open
.9	209.20	0.20	1.01	0pen
1	10.80	0.01	0.00	0pen
4	0.00	0.00	0.00	Open
5	0.00	0.00	0.00	Open
8	-4.20	0.00	0.00	Open
	220.00	0.05	0.02	Open
	220.00	0.05	0.03	Open
	224.20	0.05	0.03	0pen
Ļ	0.00	0.00	0.00	Open

APPENDIX C

Wastewater Collection

Windmill Zibi - Ontario Phase 1

Wastewater Design Flows per Unit Count City of Ottawa Sewer Design Guidelines, 2012



Peak Flow

0.3

Extraneous Flow Allowances

Site Area 1.09 ha

Phase	Block	Туре	Unit	Rate	No. of Units	Average Flow	Peaking Factor	Peak Flow	
						(L/s)	(-)	(L/s)	
1	208	Office	75	L/p/d	140	0.1	1.5	0.2	
1	208	Retail	5	L/m²/d	1457	0.1	1.5	0.1	
1	208	Restaurant	125	L/seat/d	8	0.0	1.5	0.0	
1	205.5A	Res	563.5	L/unit/d	71	0.5	4.0	1.9	
1	205.5A	Retail	5	L/m²/d	768	0.1	1.5	0.1	
Temp	209	Office	75	L/p/d	30	0.03	1.50	0.04	
					Total	0.8		2.4	
	Total Wetweather Flow Estimate								

Notes:

* Development stats per Windmill schedule dated 2016-02-01 and additional information received via email 2016-02-08.

* Office unit rate per Ontario Building Code 8.2.1.3.B. assuming 9.3m²/p

* Residential Unit rate assuming 70% one bedroom (1.4p/unit), 30% two bedroom (2.1 p/unit)

* Number of residential units from Site Plan by Hobin Architecture dated August 9, 2017

* Retail unit rate per City of Ottawa sewer design guidelines and assumes a 12 hour commercial operation

* Special Event area washrooms only per Windmill email 2016-02-08.

P.F. Estimated Total Residential Population 115 4.0



15 Allstate Parkway, Suite 300 Markham, Ontario, Canada L3R 5B4 Tel: +1 (905) 943 9600 Fax: +1 (905) 940 5848 www.hatch.ca

April 25, 2016

Mr. Adam Fobert, P.Eng. Senior Design Engineer David Schaeffer Engineering Ltd. 120 Iber Road, Unit 103 Stittsville, ON K2S 1E9

Dear Adam:

Subject: Conceptual Design for a Temporary Pumping Station to Service the Zibi / Windmill Development on Chaudière Island - City of Ottawa

Hatch is pleased to present Draft #1 of the Conceptual Design Report for the Zibi / Windmill Temporary Pumping Station in the City of Ottawa. We understand that the ultimate discharge location is located in Gatineau, QC, and that approvals for the pumping station may be required from multiple agencies in Ontario and Quebec.

We trust this report is sufficient for your review and approval. Should you have any further questions, please do not hesitate to contact us.

Very truly yours,

Peter Rüsch, M.Eng., P.Eng., PMP Senior Project Manager T 905.940.5497 F 905.940.5848 peter.rusch@hatch.ca

Zibi / Windmill Development, Chaudière Island, City of Ottawa Conceptual Design Report



Copyright © 2016, all rights reserved Hatch Ltd 15 Allstate Parkway Suite 300 Markham, ON L3R 5B4 CANADA T 905.943.9600

Revision and Version Tracking

Report Title: Zibi / Windmill Development, Chaudière Island, City of Ottawa – Conceptual Design Report Submission Date: April 25, 2016

Version #	Filename:	Author	Checker	Approver	Date:
V0.50	Zibi_Temp_PS-Draft-1 Report	P. Rüsch	J. Black	P. Rüsch	April 25, 2016

This document has been formatted for double side printing.

This document has been prepared for the titled project or named part thereof and should not be relied upon or used for any other project without an independent check being carried out as to its suitability and prior written authorization of Hatch being obtained. Hatch accepts no responsibility or liability for the consequence of this document being used for a purpose other than the purposes for which it was commissioned. Any person using or relying on the document for such other purpose agrees, and will by such use or reliance be taken to confirm their agreement to indemnify Hatch for all loss or damage resulting there from. Hatch accepts no responsibility or liability for this document to any party other than the person by whom it was commissioned. To the extent that this report is based on information supplied by other parties, Hatch accepts no liability for any loss or damage suffered by the client, whether through contract or tort, stemming from any conclusions based on data supplied by parties other than Hatch and used by Hatch in preparing this report.

Table of Contents

Cov	ver Let	tter	i
1	Intro	duction	1
2	Meth	odology	1
	2.1 2.2	Background Information Capacity of the Pumping Station	
3	Desig	gn of the Pumping Station	2
	3.1	Design Parameters	2
	3.2	Sizing of the Wet Well	
	3.3	Float Control Levels	3
	3.4	Sizing and Pressure Class of the Forcemain, and System Curve	3
	3.5	Pump Selection and Maximum Achievable Capacity	4
	3.6	Emergency Backup Times and Emergency Overflow	4
4	Elect	rical Works	4
	4.1	Power Supply	4
		Control Panel	
5	Conf	ined Space Entry Requirements	6

Appendices:

Appendix 1: Figures

List of Figures: FIGURE 1: SYSTEM CURVE

Appendix 2: Calculations

Appendix 3: Flygt Pump Data Sheet

Appendix 4: E-mail from DSEL (S. Merrick, August4, 2015 5:00pm)

1 Introduction

This report has been prepared for David Schaeffer Engineering Ltd. (DSEL) for the conceptual design of a temporary sewage pumping station on Chaudière Island in the City of Ottawa that will utilize as much as possible of the existing pumping station. The pumping station will service an initial part of the planned development on Chaudière Island.

The existing pumping station is located in an old paper mill building on Chaudière Island in Ottawa. Hatch staff visited the Pumping Station on June 30, 2015, in the presence of Steve Merrick from DSEL and Kristen Jorgensen from Windmill Development Group Ltd. For the purpose of this report the proposed pumping station will be called the Temporary Zibi Sanitary Pumping Station (TZSPS). The analysis in this report is in part based on the information gathered during the site visit and from additional sources as indicated.

The internal collection system will collect sewage by gravity to the existing wet well. The proposed pumps / forcemain combination will lift the collected sewage to a manhole located in Gatineau, QC, to be treated elsewhere.

The purpose of this report is to:

- Provide the design criteria and rational used to provide a conceptual design for the sewage pumping station;
- List specific requirements incorporated in the design;
- Confirm the hydraulic size and material assumed for the forcemain used to complete the hydraulic design for coordination with the forcemain design.

This report is to be submitted to the owner, and as required, to the Cities of Ottawa and Gatineau for review and comments for inclusion into the final design.

It is assumed that the pumping station will be owned and operated by Windmill, the developer of the Zibi Development. Should the ownership / operating authority be different, Hatch will require clarification prior to detailed design.

2 Methodology

2.1 Background Information

The pumping station will utilize the existing wet well in an existing building. It is understood that the sewage will be conveyed by gravity to the wet well. Phasing of the development will be in accordance with the Functional Servicing Report, however, due to the small size of the temporary pumping station, no phasing is proposed.

2.2 Capacity of the Pumping Station

The capacity of the pumping station is based on the total estimated peak wet weather flow rate of 11.9 L/s, provided by David Schaeffer Engineering Ltd. via e-mail (Appendix 4). However, DSEL also requested an estimate of the maximum flow that can be achieved with the forcemain / existing wet well combination. It was assumed that this was to mean that the aim of the pump selection should be to optimise the utilization of the existing facilities, and to achieve a maximum reasonable flow utilizing the existing wet well, while keeping the operating costs at a reasonable level.

3 Design of the Pumping Station

3.1 Design Parameters

The City of Ottawa Design Guidelines call for a minimum forcemain diameter of 100 mm. The MOE Design Guidelines (2008) call for a flow velocity of at least 0.6 m/s in forcemains, however Hatch's preference is for a velocity of above 1.0m/s (ideally 1.25 to 1.5 m/s) to maintain adequate self-cleaning of the forcemain. However this preference has to be balanced with friction losses to ensure economic operation of the system. It may be noted here that at any given velocity smaller forcemains will transport grit better than larger forcemains (all other things being equal) as result of the shear stress.

The existing pumping station has limited to no storage capacity to cater for emergency overflow conditions. During detailed design, the time to emergency overflow will be finalized with the operating authority and the Cities of Ottawa and Gatineau. It is expected that a Time-to-Overflow of up to 30 minutes will be required at minimum. It is understood that there are options to have emergency storage in the existing building by re-purposing existing holding facilities.

Access for maintenance personnel to the wet well will be reviewed during detailed design to ensure that it meets legal requirements.

3.2 Sizing of the Wet Well

The existing wet well is proposed to be used for the temporary pumping. The flow of the pumping station (11.9 L/s) will be accommodated by 1 duty and 1 standby pump, each of which will be able to handle the nominal inflow individually. For conceptual design purposes a flow rate of 12 L/s was taken. The wet well capacity required to achieve a given pump cycle time can be calculated as follows:

$$V = \frac{T_c \cdot Q}{4}$$

Where:

V = wet well volume in L;

 T_c = Pump Cycle Time in seconds;

Q = Pump discharge rate, in L/s

For a pump cycle time of 5 minutes (i.e. a combined 12 starts per hour) the wet well volume can be calculated as:

$$V = \frac{T_c \cdot Q}{4} = \frac{180s \cdot 12 L/s}{4} = 900L$$

It is noted that Hatch has used a reduced cycle time from what is usually used since this is a temporary pumping station and pump rotation for longevity is not as much of an issue as in permanent pumping stations.

In addition there is an option to use the lower flow rates, based on using Variable Speed Drives. In this case the live storage could be reduced to \sim 500 L, having a live storage depth of 0.2 m. As such the existing wet well is sufficient to have adequate pump cycle times to avoid overloading the pump motors.

The existing wet well is roughly 1.8 m x 1.3 m, which does not meet the minimum size requirement from the MOECC. Hatch is of the opinion that the wet well may be used for the temporary pumping station; the proposed pumps will fit into the wet well. Since the pumps will not normally operate at the same time, we have no major concerns that we

believe cannot be dealt with in detailed design. However, there is a remaining risk that the MOECC may not approve of this option.

3.3 Float Control Levels

The selected pumps (refer to Section 3.5) require a minimum water depth of 260 mm, as per the specification sheet. Hatch will review the suction conditions in detailed design to ensure that the required submergence is maintained and to maximise storage utilization. For the purpose of this report it is assumed that satisfactory suction conditions can be maintained with a minimum water depth of 500 mm. As shown in Section 3.2 above, the live depth required will be less than 0.5 m. With a wet well depth of \sim 3.7 m, there will be adequate live volume available for pump operation and alarm levels. Operating levels will be set during detailed design.

For the purpose of system head calculations, a suction depth of 0.5m and live well depth of 0.5 m were assumed.

3.4 Sizing and Pressure Class of the Forcemain, and System Curve

The velocity of sewage in the forcemain during normal operation should be in the range of 0.9m/s to 1.5m/s, as recommended in section 7.2.5.2 of the "Ottawa Sewer Design Guidelines". The forcemain should have a minimum nominal diameter of 100mm, as specified in section 7.2.5.1 of the "Ottawa Sewer Design Guidelines".

The static head of this pumping station will range between 3.9 and 4.4 m during normal operation (up to the "Alarm" level), based on the operating levels as defined in Section 3.3 above and the forcemain discharge elevation of 49.9 m (pipe obvert).

The forcemain material has not been finalised, therefor the calculations were based on a nominal diameter of 100 mm, using part stainless steel and HDPE. A flow rate of 12 L/s achieves a velocity of 1.5 m/s, which satisfies the MOE requirements and the City of Ottawa requirements. The following friction losses have been calculated for the forcemain, in accordance with City of Ottawa and MOE requirements, for a nominal flow of 12.0L/s:

- Hazen Williams C (HW-C) = 100: 20.1 m;
- HW-C = 110: 16.9 m
- HW-C = 120: 14.4 m.

Since the forcemain has not been finalised, it will be possible to select the pipe material for the remaining sections of the forcemain to ensure that the selected pumps will work within a good operating range. Hatch has assumed that a Hazen Williams C value of 110 (representing an average between the MOE design guidelines and HDPE design values) is likely to be more representative of the actual hydraulic conditions.

A system curve has been calculated from 2 L/s to 22.0 L/s using the HW-C factors above for the 100mm forcemain. Minor losses were estimated by allowing for a 'k' value of 15 for fittings and pipework inside the pumping station. This 'k' value results in an additional dynamic head of 1.8 m at a flow rate of 12.0L/s. A graph of the system curve is attached. (Appendix 1: Figure 3). The following lines have been plotted:

- Maximum static head, and friction losses based on a HW-C of 100, along with minor losses;
- Intermediate static head, and friction losses based on a HW-C of 110, along with minor losses;
- Minimum static head, and friction losses based on a HW-C of 120, along with minor losses.

The intermediate head represents the most likely system curve, and this was used as the basis for the pump selection. The full calculations are shown in Appendix 2.

ΗΔΤCΗ

3.5 Pump Selection and Maximum Achievable Capacity

From the hydraulic system curve, two identical pumps have been selected for the proposed pumping station; these are Flygt NP 3127 SH 3 ~ Adaptive 248.

Each pump is a submersible wastewater pump with a 155 mm diameter impeller. It operates with a 60 Hz, 3 phase motor with an output rating of 8.2 kW at 3495 rpm. These pumps require a minimum water level of 260 mm, therefore the floor level proposed in Section 3.3, 0.5 m below the lead pump stop level, is suitable. Hatch proposes that one pump is to be equipped with a mix-flush valve.

The flow velocity in the forcemain for the nominal flow of 12.0 L/s is at the upper limit of the desired forcemain velocity based on the City of Ottawa design requirements. Based on the current pump selection, the pump will require to be equipped with Variable Speed Drives (VSD) to ensure that the existing wet well can be utilized. Using VSDs increases the number of allowable starts per hour per pump, and at the same time reduces the critical flow rate. In this case VSDs will also save some energy, which over the life of the pumping station will likely more than offset the additional capital costs.

Running at full speed, the selected pump will result in a pumpage of approximately 14.5 L/individually This flow rate would result in a flow velocity of 1.8 m/s, which is higher than the preferred range of the City of Ottawa, but below the MOECC maximum flow velocity criterion.

The data sheet for the Flygt NP 3127 SH 3 ~ Adaptive 248 pumps is attached in Appendix 3.

The system curve / pump curve attached in Appendix 1 shows the flow range that the pump can handle, given the hydraulic design parameters.

3.6 Emergency Backup Times and Emergency Overflow

The existing pumping station wet well only has an emergency storage capacity of ~ 6000 L; with an inflow rate of 12.0 L/s this will only provide emergency storage for 500 s, or just over 8 minutes. This will likely not be approved without additional storage for emergencies. The existing storage will be sufficient for an initial period, until such time that the incoming peak flows exceeds 3.33 L/s, based on the general requirement form the MOECC to have at least 30 minutes of emergency storage.

Once this low flow rate is exceeded, additional emergency overflow storage will very likely be required for continued approval.

4 Electrical Works

4.1 Power Supply

The existing pumping station is equipped with a 600 V power supply panel, however this was based on lower power pumps. It should be assumed that the panels will require at least a full upgrade, but it would be prudent to assume that the panels are to be replaced.

Depending on the power supply options available, the pumps may be either equipped with 600 V or 208 V three phase motors. The latter motors may be supplied from a 240/120 V single phase supply if desirable. In this case, the VSDs will have to be de-rated to suit the conditions.

ΗΔΤϹΗ

Standby power will be required for the pumping station; this may be in the form of a mobile generator. This may factor into the overall power supply arrangement. The generator shall be breaker protected to suit the system layout. For reliability a diesel generator is recommended.

4.2 Control Panel

The control panel will contain the control schematic (3-position mode selector switch, push-buttons and any other ancillary equipment required to provide a safe pump control). These components will be supplied as loose equipment, in the same package as the submersible pumps. The general contractor will install, commission and start-up the control system as per the pump control supplier documentation.

4.2.1 Operation

The pump control shall be based on the "Lead-Lag" principle. The operator can select three modes of operation from 2 selector switches:

- MANUAL mode: Each pump can be started and stopped individually, from push-buttons;
- AUTO mode: Pumps start and stop as per the "LEAD-LAG" principle. At the first start pump P-1 will be the lead pump and will start at the LWL level. Should the level reach the HWL level, then the lag pump P-2 starts. The lag pump will stop once the LWL is reached. The lead pump stop once the LLWL level is reached. Once both pumps are stopped, pump P-2 becomes the "lead" pump and P-1 the "lag" pump. After each operation, the "lead" position alternates.
- OFF position: Both pumps are stopped.

The control panel will include the LIT-1 ultrasonic level transducer. This transducer will provide the level inputs, (LLWL, LWL, HWL, HHWL) to be used to control the pumps.

The controls for the submersible pumps will be provided by the pump manufacturer (Flygt).

Each pump circuit is fitted with a thermomagnetic circuit breaker with instantaneous magnetic trip and adjustable overload relay.

Control power for pump schematic is to be provided from a Un-interruptible Power Supply (UPS). The UPS will power the level transmitter and auto-dialer.

A heating element with a thermostat will control the temperature of the control panel.

The following items shall also be included in the motor control panel:

- duplex receptacle with ground fault protection;
- lightning arrester;
- motor temperature surveillance;
- intrinsically safe relays for level switches installed in classified area;
- MINICAS relays for submersible motor protection;
- smoke detector for smoke alarm;
- manual transfer switch for generator operation of the station;

ΗΔΤCΗ

• dry contacts for the alarm function of high-high water level, pump faults, power failure, smoke alarm, diesel generator fault, illegal entry is to be wired to the alarm control panel.

The time totalizer and event counter will enable staff to monitor the performance of pumps. A flow meter can be provided if required, or a system curve can be provided to allow for the calculation of volume of sewage being pumped based on the running times of the pumping units.

Each pump will be monitored for failing to respond to a "start" command. The pump failing to respond will be locked out and the lag pump will assume the lead duty position.

A separate "Alarm Control Panel" (ACP) will be provided on the outside of the pumping station main control panel. The ACP will house the alarming control logic required and a programmable auto-dialer to relay alarms. The dialer will store at least 4 pre-set emergency numbers and will dial in case of an alarm until the dialed call is acknowledged. As a backup, an industrial outdoor strobe/audible alarm unit will also be mounted on the outside of the ACP that will be activated only in case of an auto-dialer failure, or if the auto-dialer alarm is not acknowledged within an adjustable short period of time. Alarm notifications instructions will also be added near the strobe light/audible alarm for manual alarming.

5 Confined Space Entry Requirements

The proposed wet well pumping station is classified as a "confined space" similar to any underground maintenance hole or chamber.

Entry to the wet well is subject to the following requirements:

- Ontario Regulation 632/05 (Confined Spaces)
 <u>http://www.elaws.gov.on.ca/html/regs/english/elaws_regs_050632_e.htm</u>
- Confined Spaces Guidelines prepared by the Ontario Ministry of Labour


http://www.labour.gov.on.ca/english/hs/pdf/gl_confined.pdf

Entry procedures shall be developed by the owner of the Pumping Station in accordance with the above noted regulations and laws, and safety equipment shall meet legal requirements and be maintained in strict accordance with manufacturer's requirements.



Appendix 1: Figures System Graph





Flow (L/s)



Appendix 2: System Curve and Calculations

Spreadsheet to calculate the Sytem Curve for a temporary Zibi / Windmill PS on Chaudiere Island in Ottawa, pumping to Gatineau

prepared by Peter Rüsch, April 19, 2016		
Elevation at discharge Location:	49.90 m (obvert)	(At the discharge location)
Forcemain Length:	465 m	
Forcemain Inner Diameter:	100.0 mm	(Nominal Diameter=100 mm: to be confirm in detail design)
Sump Max level:	46.00 m	3.90
Sump Min level:	45.50 m	4.40
Sump Intermediate level:	45.75 m	

		Friction Losses: HW-C		L	Local Losses: k=		System Curve	
Flow (I/s):	Velocity (m/s):	100	110	120	15	Max	Ave	Min
2.0	0.25	0.73	0.61	0.52	0.05	5.18	4.81	4.47
2.2	0.28	0.87	0.73	0.62	0.06	5.33	4.94	4.58
2.4	0.31	1.02	0.86	0.73	0.07	5.49	5.08	4.70
2.6 2.8	0.33 0.36	1.18 1.36	0.99 1.14	0.84 0.97	0.08 0.10	5.67 5.85	5.23 5.38	4.83 4.97
3.0	0.38	1.54	1.29	1.10	0.10	6.05	5.55	5.11
3.2	0.41	1.74	1.46	1.24	0.13	6.26	5.73	5.27
3.4	0.43	1.94	1.63	1.39	0.14	6.49	5.92	5.43
3.6 3.8	0.46 0.48	2.16 2.39	1.81 2.00	1.54 1.70	0.16 0.18	6.72 6.97	6.12 6.33	5.60 5.78
4.0	0.48	2.63	2.20	1.87	0.10	7.23	6.55	5.97
4.2	0.53	2.88	2.41	2.05	0.22	7.49	6.78	6.17
4.4	0.56	3.13	2.63	2.24	0.24	7.77	7.02	6.38
4.6 4.8	0.59 0.61	3.40 3.68	2.85 3.09	2.43 2.63	0.26 0.29	8.07 8.37	7.27 7.52	6.59 6.81
5.0	0.64	3.97	3.33	2.83	0.31	8.68	7.79	7.04
5.2	0.66	4.27	3.58	3.05	0.34	9.01	8.07	7.28
5.4	0.69	4.58	3.84	3.27	0.36	9.34	8.35	7.53
5.6 5.8	0.71 0.74	4.90 5.23	4.11 4.38	3.50 3.73	0.39 0.42	9.69 10.05	8.65 8.95	7.78 8.05
6.0	0.76	5.57	4.67	3.97	0.45	10.00	9.26	8.32
6.2	0.79	5.92	4.96	4.22	0.48	10.79	9.59	8.60
6.4	0.81	6.27	5.26	4.48	0.51	11.18	9.92	8.88
6.6 6.8	0.84 0.87	6.64 7.02	5.57 5.88	4.74 5.01	0.54 0.57	11.58 11.99	10.26 10.61	9.18 9.48
7.0	0.89	7.41	6.21	5.28	0.61	12.41	10.01	9.79
7.2	0.92	7.80	6.54	5.57	0.64	12.85	11.33	10.11
7.4	0.94	8.21	6.88	5.86	0.68	13.29	11.71	10.44
7.6 7.8	0.97 0.99	8.63 9.05	7.23 7.59	6.15 6.46	0.72 0.75	13.74 14.20	12.10 12.49	10.77 11.11
8.0	1.02	9.49	7.95	6.77	0.79	14.68	12.49	11.46
8.2	1.04	9.93	8.32	7.08	0.83	15.16	13.31	11.82
8.4	1.07	10.38	8.70	7.41	0.87	15.66	13.73	12.18
8.6 8.8	1.09 1.12	10.84 11.32	9.09 9.49	7.74 8.07	0.92 0.96	16.16 16.68	14.16 14.59	12.55 12.93
9.0	1.12	11.80	9.89	8.42	1.00	17.20	15.04	13.32
9.2	1.17	12.29	10.30	8.77	1.05	17.74	15.50	13.72
9.4	1.20	12.79	10.72	9.12	1.10	18.28	15.96	14.12
9.6 9.8	1.22 1.25	13.29 13.81	11.14 11.58	9.49 9.85	1.14 1.19	18.84 19.40	16.44 16.92	14.53 14.94
10.0	1.27	14.34	12.02	10.23	1.24	19.98	17.41	15.37
10.2	1.30	14.87	12.47	10.61	1.29	20.56	17.91	15.80
10.4	1.32	15.42	12.92	11.00	1.34	21.16	18.41	16.24
10.6	1.35	15.97	13.39	11.40	1.39	21.77	18.93	16.69
10.8 11.0	1.38 1.40	16.54 17.11	13.86 14.34	11.80 12.20	1.45 1.50	22.38 23.01	19.46 19.99	17.14 17.60
11.2	1.43	17.69	14.83	12.62	1.55	23.64	20.53	18.07
11.4	1.45	18.28	15.32	13.04	1.61	24.29	21.08	18.55
11.6 11.8	1.48 1.50	18.88 19.48	15.82 16.33	13.47 13.90	1.67 1.73	24.94 25.61	21.64 22.21	19.03 19.53
12.0	1.53	20.10	16.85	14.34		26.28	22.78	20.02
12.2	1.55	20.72	17.37	14.78	1.84	26.97	23.36	20.53
12.4	1.58	21.36	17.90	15.24	1.91	27.66	23.96	21.04
12.6	1.60	22.00	18.44	15.69	1.97	28.37	24.56	21.56
12.8 13.0	1.63 1.66	22.65 23.31	18.99 19.54	16.16 16.63	2.03 2.09	29.08 29.80	25.17 25.78	22.09 22.62
13.2	1.68	23.98	20.10	17.11	2.16	30.54	26.41	23.17
13.4	1.71	24.66	20.67	17.59	2.23	31.28	27.04	23.72
13.6 13.8	1.73 1.76	25.34 26.04	21.24 21.82	18.08 18.58	2.29 2.36	32.03 32.80	27.68 28.33	24.27 24.84
14.0	1.78	26.74	22.41	19.08	2.43	33.57	28.99	25.41
14.2	1.81	27.45	23.01	19.58	2.50	34.35	29.66	25.98
14.4	1.83	28.17	23.61	20.10	2.57	35.14	30.33	26.57
14.6 14.8	1.86 1.88	28.90	24.22 24.84	20.62 21.14	2.64 2.71	35.94 36.75	31.02 31.71	27.16
15.0	1.00	29.64 30.38	25.47	21.68	2.79	37.57	32.41	27.76 28.37
15.2	1.94	31.14	26.10	22.22	2.86	38.40	33.11	28.98
15.4	1.96	31.90	26.74	22.76	2.94	39.24	33.83	29.60
15.6 15.8	1.99 2.01	32.67 33.45	27.39 28.04	23.31 23.87	3.02 3.09	40.09 40.95	34.55 35.28	30.23 30.86
16.0	2.04	34.24	28.70	24.43	3.17	41.81	36.02	31.50
16.2	2.06	35.04	29.37	25.00	3.25	42.69	36.77	32.15
16.4 16.6	2.09 2.11	35.84 36.66	30.04 30.73	25.57	3.33 3.42	43.58 44.47	37.53 38.29	32.81 33.47
16.8	2.11	36.66	30.73	26.15 26.74	3.42	44.47	38.29	33.47 34.14
17.0	2.14	38.31	32.11	27.33	3.58	46.29	39.84	34.81
17.2	2.19	39.15	32.81	27.93	3.67	47.22	40.63	35.50
17.4	2.22	40.00	33.52	28.53	3.75	48.15	41.43	36.19
17.6 17.8	2.24 2.27	40.85 41.72	34.24 34.97	29.14 29.76	3.84 3.93	49.09 50.04	42.23 43.04	36.88 37.59
18.0	2.29	42.59	35.70	30.38	4.02	51.00	43.86	38.30
18.2	2.32	43.47	36.43	31.01	4.11	51.97	44.69	39.02
18.4 18.6	2.34 2.37	44.36 45.25	37.18 37.93	31.65 32.29	4.20 4.29	52.95 53.94	45.53 46.37	39.74 40.47
18.8	2.37	45.25 46.16	37.93	32.29	4.29	53.94 54.94	46.37 47.22	40.47 41.21
19.0	2.42	47.07	39.46	33.58	4.47	55.95	48.08	41.96
19.2	2.44	47.99	40.23	34.24	4.57	56.96	48.95	42.71
19.4 19.6	2.47 2.50	48.92 49.86	41.01 41.79	34.90 35.57	4.66 4.76	57.99 59.02	49.82 50.71	43.47 44.24
19.6	2.50	49.86 50.81	41.79 42.59	35.57	4.76	59.02 60.07	50.71	44.24 45.01
20.0	2.55	51.76	43.39	36.93	4.96	61.12	52.50	45.79
20.2	2.57	52.73	44.19	37.62	5.06	62.18	53.40	46.57
20.4 20.6	2.60 2.62	53.70 54.68	45.01 45.83	38.31 39.01	5.16 5.26	63.26 64.34	54.32 55.24	47.37 48.17
20.8	2.65	55.66	46.66	39.71	5.36	65.43	56.17	48.97
21.0	2.67	56.66	47.49	40.42	5.47	66.52	57.11	49.79
21.2 21.4	2.70 2.72	57.66 58.67	48.33 49.18	41.14 41.86	5.57 5.68	67.63 68.75	58.05 59.01	50.61 51.44
21.4	2.72	58.67	49.18 50.03	41.86	5.08	69.88	59.01	51.44
21.8	2.78	60.72	50.90	43.32	5.89	71.01	60.94	53.11
22.0	2.80	61.76	51.76	44.06	6.00	72.16	61.91	53.96

Wet Well Analysis and Storage requirements for the existing Windmill PS:

prepared by Peter Rüsch, April 19, 2016	-		-	
Input Flow Rate:	12	.00 L/s		
Output Flow Rate:	12	.00 L/s		
Storage Time:	3	600 s	(at a combined 12 start per hour)	
Storage Volume:	ç	00 L		
Storage Volume of 2400 MH:				
Destas and an		L	W 1 20 m	
Rectangular:		.83 m	1.30 m	
Storage / m:		.38 m³ /m		
Storage / m (less equipment):	2	.14 m ³ /m	(at 90% effectiveness)	
Donth of Storage (Live Storage)	0	40		
Depth of Storage (Live Storage):	0	.42 m		
Incoming Pipe Invert:	N/A	m		
meening ripe invert.	11/7			
HHWL (Alarm on):	N/A	m	Level Unknown, if any.	
HWL (Lag Pump on):	N/A	m		
LWL (Lead Pump on):		.00 m	Approximately, based on lid level and measurement	~ 2.6 m below lid
LLWL (Lead Pump off):	45	.50 m	Approximately, based on lid level and measurement	~ 3.0 m below lid
Sump Invert:	45	.00 m	Not measured, however pumps were visible.	
Storage in PS:				
Overflow Invert:		.70 m		
HHWL:		.20	Assumed Alarm Level to determine time-to-overflow	
		.50 m		
Emergency Storage Required:	18	800 s		
Inflow Rate:		12		
Volume:		600 L		
Less Volume in PS (Overflow-HHWL):		48 L		
Time to overflow:	2	96 s		
		8 min		
Additional Storage required for Time-to-				
Overflow of 30 minutes:	~ 156	53 L		
Overnow of so minutes.	~ 156	55 L		




Appendix 3: Flygt Pump Curve


xylem

NP 3127 SH 3~ Adaptive 248

Technical specification



Installation: P - Semi permanent, Wet





FLYGT

Note: Picture might not correspond to the current configuration.

General Patented self cleaning semi-open channel impeller, ideal for pumping in most waste water applications. Possible to be upgraded with Guide-pin® for even better clogging resistance. Modular based design with high adaptation grade.

Impeller

Impeller material Discharge Flange Diameter Inlet diameter Impeller diameter Number of blades

Grey cas	t iron
80 mm	
80 m m	
155 mm	
2	

Motor

Motor # Stator variant Frequency Rated voltage Number of poles Phases Rated power Rated current Starting current	N3127.160 21-11-2AL-W 11hp 40 60 Hz 400 V 2 3~ 8.2 kW 15 A 128 A
Rated speed	3495 1/min
Power factor 1/1 Load 3/4 Load 1/2 Load	0.92 0.90 0.85
Efficiency 1/1 Load 3/4 Load 1/2 Load	87.7 % 88.4 % 87.7 %

Configuration

Project	Project ID	Created by	Created on	Last update
			2016-04-25	



NP 3127 SH 3~ Adaptive 248

Performance curve

Pump


Discharge Flange Diameter	80 mm
Inlet diameter	80 mm
Impeller diameter	155 mm
Number of blades	2

Motor
Motor #
Stator variant
Frequency
Rated voltage
Number of poles
Phases
Rated power
Rated current

Starting current

N3127.160 21-11-2AL-W 11hp 40 60 Hz 400 V 2	Power fac 1/1 Load 3/4 Load 1/2 Load
3~ 8.2 kW 15 A 128 A 3495 1/min	Efficiency 1/1 Load 3/4 Load 1/2 Load

ower factor /1 Load /4 Load /2 Load	0.92 0.90 0.85
fficiency /1 Load /4 Load	87.7 % 88.4 %



Project	Project ID	Created by	Created on	Last update
			2016-04-25	




87.7 %



NP 3127 SH 3~ Adaptive 248

Duty Analysis




FLYGT



NP 3127 SH 3~ Adaptive 248

VFD Curve




FLYGT



NP 3127 SH 3~ Adaptive 248

VFD Analysis




FLYGT

Pumps running /System	Frequency	Flow	Head	Shaft power	Flow	Head	Shaft power	Hyd eff.	Specific energy	NPSHre
1	60 Hz	14.3 l/s	31 m	7.54 kW	14.3 l/s	31 m	7.54 kW	57.4 %	0.000167 kWh/l	5.43 m
1	60 Hz	14.2 l/s	30.8 m	7.5 kW	14.2 l/s	30.8 m	7.5 kW	57.4 %	0.000166 kWh/l	5.42 m
1	54 Hz	12.6 l/s	25.2 m	5.45 kW	12.6 l/s	25.2 m	5.45 kW	57 %	0.000136 kWh/l	4.58 m
1	48 Hz	10.9 l/s	20.1 m	3.81 kW	10.9 l/s	20.1 m	3.81 kW	56.5 %	0.000111 kWh/l	3.81 m

Project	Project ID	Created by	Created on	Last update
			2016-04-25	



NP 3127 SH 3~ Adaptive 248 Dimensional drawing



 Project ID
 Created by
 Created on
 Last update

 2016-04-25





Appendix 4: E-mail re System Flow

Rusch, Peter

From:Adam Fobert <afobert@dsel.ca>Sent:Tuesday, March 22, 2016 4:00 PMTo:Peter RüschCc:Steven MerrickSubject:717: Windmill Zibi - Interim and Ultimate PSAttachments:san-2016-03-03_717-zibi_master-plan_adf.xlsx; 2016-03-22_windmill-zibi-
hatch_coord.dwg

Hello Peter,

As discussed yesterday, please find the following and attached:

Interim Pump Station:

- 1) Estimated inflow: 11.9L/s (see attached calc sheet tab for Phase 1A)
- 2) Estimated Length of new forcemain to be extended from temp PS to existing 100mm dia stainless steel = 206m
- 3) Estimated Length of new forcemain to be extended from existing 100mm dia stainless to outlet = 22m
- 4) Estimated Length of existing 100mm dia stainless steel = 237m
- 5) Total Forcemain length = 465m
- 6) Forcemain elevations: The forcemain should exit the existing building at 1.8m below the existing grade, which would put it at 51.29m. We could go lower, but I'd rather avoid as much rock as possible for the interim line. If the forcemain continues along these lines, we'll encounter a high point of 52.49m. Then it will be downhill to the bridge where is will maintain a relatively constant elevation of ~50.50m. The receiving invert of our outlet in Gatineau is at ~49.9m. This means it could almost be a gravity line if it weren't for the 240m of flat run on the bridge.

**** Please note that the client is looking to see how they can maximize the use of the interim facility. Can you provide a sense of the maximum flow that the 100mm diameter forcemain could handle? We would have to discuss what the resulting wet well storage is.

Ultimate Pump Station:

- 1) Estimated Inflow = 49.2L/s (see attached calc sheet tab for Master Servicing)
- 2) Incoming invert = 46.51m
- 3) Total Forcemain Length ~560m

I have also attached a CAD of our plans to date that show the forcemain routing.

Let me know if you need anything else.

I suspect we'll need to have a discussion about the interim forcemain elevations.

Adam Fobert, P.Eng. Manager of Site Plan Design

DSEL

david schaeffer engineering ltd.

APPENDIX D

Stormwater Management

													:	Sewer Data	1			
Area ID	Up	Down	Area	С	Indiv AxC	Acc AxC	Тc	I	Q	DIA	Slope	Length	A _{hydraulic}	R	Velocity	Qcap	Time Flow	Q / Q full
			(ha)	(-)			(min)	(mm/hr)	(L/s)	(mm)	(%)	(m)	(m²)	(m)	(m/s)	(L/s)	(min)	(-)
104B			0.846	0.85	0.72	0.72												
207			0.033	0.90	0.03	0.03												
104A	BLDG	STM104	0.257	0.80	0.21	0.95	10.0	104.2	276.2	525	1.00	48.9	0.216	0.131	1.99	430.1	0.4	0.64
FUT.			0.099	0.90	0.09	0.09												
104C	STM104	STM103	0.032	0.85	0.03	1.07	10.4	102.1	303.6	525	1.50	26.8	0.216	0.131	2.43	526.7	0.2	0.58
	STM103	STM102	0.000	0.00	0.00	1.07	10.6	101.2	300.9	525	1.00	26.7	0.216	0.131	1.99	430.1	0.2	0.70
	STM102	STM101	0.000	0.00	0.00	1.07	10.8	100.1	297.6	600	0.50	7.0	0.283	0.150	1.54	434.2	0.1	0.69
	STM101	HW100	0.000	0.00	0.00	1.07	10.9	99.7	296.5	600	0.50	33.6	0.283	0.150	1.54	434.2	0.4	0.68



Stormceptor Sizing Detailed Report PCSWMM for Stormceptor

Project Information

Date	27/04/2016
Project Name	Zibi Ontario
Project Number	717
Location	N/A

Stormwater Quality Objective

This report outlines how Stormceptor System can achieve a defined water quality objective through the removal of total suspended solids (TSS). Attached to this report is the Stormceptor Sizing Summary.

Stormceptor System Recommendation

The Stormceptor System model STC 4000 achieves the water quality objective removing 80% TSS for a City of Toronto (clay, silt and sand) particle size distribution.

The Stormceptor System

The Stormceptor oil and sediment separator is sized to treat stormwater runoff by removing pollutants through gravity separation and flotation. Stormceptor's patented design generates positive TSS removal for all rainfall events, including large storms. Significant levels of pollutants such as heavy metals, free oils and nutrients are prevented from entering natural water resources and the re-suspension of previously captured sediment (scour) does not occur.

Stormceptor provides a high level of TSS removal for small frequent storm events that represent the majority of annual rainfall volume and pollutant load. Positive treatment continues for large infrequent events, however, such events have little impact on the average annual TSS removal as they represent a small percentage of the total runoff volume and pollutant load.

Stormceptor is the only oil and sediment separator on the market sized to remove TSS for a wide range of particle sizes, including fine sediments (clays and silts), that are often overlooked in the design of other stormwater treatment devices.



Small storms dominate hydrologic activity, US EPA reports

"Early efforts in stormwater management focused on flood events ranging from the 2-yr to the 100-yr storm. Increasingly stormwater professionals have come to realize that small storms (i.e. < 1 in. rainfall) dominate watershed hydrologic parameters typically associated with water quality management issues and BMP design. These small storms are responsible for most annual urban runoff and groundwater recharge. Likewise, with the exception of eroded sediment, they are responsible for most pollutant washoff from urban surfaces. Therefore, the small storms are of most concern for the stormwater management objectives of ground water recharge, water quality resource protection and thermal impacts control."

"Most rainfall events are much smaller than design storms used for urban drainage models. In any given area, most frequently recurrent rainfall events are small (less than 1 in. of daily rainfall)."

"Continuous simulation offers possibilities for designing and managing BMPs on an individual site-by-site basis that are not provided by other widely used simpler analysis methods. Therefore its application and use should be encouraged."

– US EPA Stormwater Best Management Practice Design Guide, Volume 1 – General Considerations, 2004

Design Methodology

Each Stormceptor system is sized using PCSWMM for Stormceptor, a continuous simulation model based on US EPA SWMM. The program calculates hydrology from up-to-date local historical rainfall data and specified site parameters. With US EPA SWMM's precision, every Stormceptor unit is designed to achieve a defined water quality objective.

The TSS removal data presented follows US EPA guidelines to reduce the average annual TSS load. Stormceptor's unit process for TSS removal is settling. The settling model calculates TSS removal by analyzing (summary of analysis presented in Appendix 2):

- Site parameters
- Continuous historical rainfall, including duration, distribution, peaks (Figure 1)
- Interevent periods
- Particle size distribution
- Particle settling velocities (Stokes Law, corrected for drag)
- TSS load (Figure 2)
- Detention time of the system

The Stormceptor System maintains continuous positive TSS removal for all influent flow rates. Figure 3 illustrates the continuous treatment by Stormceptor throughout the full range of storm events analyzed. It is clear that large events do not significantly impact the average annual TSS removal. There is no decline in cumulative TSS removal, indicating scour does not occur as the flow rate increases.






Figure 1. Runoff Volume by Flow Rate for OTTAWA MACDONALD-CARTIER INT'L A – ON 6000, 1967 to 2003 for 1.34 ha, 90% impervious. Small frequent storm events represent the majority of annual rainfall volume. Large infrequent events have little impact on the average annual TSS removal, as they represent a small percentage of the total annual volume of runoff.




Figure 2. Long Term Pollutant Load by Flow Rate for OTTAWA MACDONALD-CARTIER INT'L A – 6000, 1967 to 2003 for 1.34 ha, 90% impervious. The majority of the annual pollutant load is transported by small frequent storm events. Conversely, large infrequent events carry an insignificant percentage of the total annual pollutant load.






Figure 3. Cumulative TSS Removal by Flow Rate for OTTAWA MACDONALD-CARTIER INT'L A – 6000, 1967 to 2003. Stormceptor continuously removes TSS throughout the full range of storm events analyzed. Note that large events do not significantly impact the average annual TSS removal. Therefore no decline in cumulative TSS removal indicates scour does not occur as the flow rate increases.



Appendix 1 Stormceptor Design Summary

Project Information

Designer Information					
Location	N/A				
Project Number	717				
Project Name	Zibi Ontario				
Date	27/04/2016				

Designer Information

Company	N/A
Contact	N/A

Notes

N/A

Drainage Area

Total Area (ha)	1.34
Imperviousness (%)	90

The Stormceptor System model STC 4000 achieves the water quality objective removing 80% TSS for a City of Toronto (clay, silt and sand) particle size distribution.

Rainfall

Name	OTTAWA MACDONALD-CARTIER INT'L A
State	ON
ID	6000
Years of Records	1967 to 2003
Latitude	45°19'N
Longitude	75°40'W

Water Quality Objective

TSS Removal (%)	80

Upstream Storage

Storage (ha-m)	Discharge
(ha-m)	(L/s)
0	0
-	-

Stormceptor Sizing Summary

Stormceptor Model	TSS Removal
	%
STC 300	58
STC 750	69
STC 1000	69
STC 1500	70
STC 2000	75
STC 3000	76
STC 4000	80
STC 5000	81
STC 6000	83
STC 9000	87
STC 10000	87
STC 14000	89



Particle Size Distribution

Removing silt particles from runoff ensures that the majority of the pollutants, such as hydrocarbons and heavy metals that adhere to fine particles, are not discharged into our natural water courses. The table below lists the particle size distribution used to define the annual TSS removal.

	City of Toronto (clay, silt and sand)										
Particle Size	Distribution	Specific Gravity	Settling Velocity		Particle Size	Distribution	Specific Gravity	Settling Velocity			
μm	%	,	m/s ์		μm	%	5	m/s ์			
10	20	2.65	0.0004								
30	10	2.65	0.0008								
50	10	2.65	0.0022								
95	20	2.65	0.0063								
265	20	2.65	0.0366								
1000	20	2.65	0.1691								

Stormceptor Design Notes

- Stormceptor performance estimates are based on simulations using PCSWMM for Stormceptor version 1.0
- Design estimates listed are only representative of specific project requirements based on total suspended solids (TSS) removal.
- Only the STC 300 is adaptable to function with a catch basin inlet and/or inline pipes.
- Only the Stormceptor models STC 750 to STC 6000 may accommodate multiple inlet pipes.
- Inlet and outlet invert elevation differences are as follows:

Inlet and Outlet Pipe Invert Elevations Differences

Inlet Pipe Configuration	STC 300	STC 750 to STC 6000	STC 9000 to STC 14000
Single inlet pipe	75 mm	25 mm	75 mm
Multiple inlet pipes	75 mm	75 mm	Only one inlet pipe.

- Design estimates are based on stable site conditions only, after construction is completed.
- Design estimates assume that the storm drain is not submerged during zero flows. For submerged applications, please contact your local Stormceptor representative.
- Design estimates may be modified for specific spills controls. Please contact your local Stormceptor representative for further assistance.
- For pricing inquiries or assistance, please contact Imbrium Systems Inc., 1-800-565-4801.



Appendix 2 **Summary of Design Assumptions**

SITE DETAILS

Site Drainage Area

Sile Dialilaye Alea			
Total Area (ha)	1.34	Imperviousness (%)	90
Surface Characteristics		Infiltration Parameters	
Width (m)	232	Horton's equation is used to estimate	infiltration
Slope (%)	2	Max. Infiltration Rate (mm/h)	61.98
Impervious Depression Storage (mm)	0.508	Min. Infiltration Rate (mm/h)	10.16
Pervious Depression Storage (mm)	5.08	Decay Rate (s ⁻¹)	0.00055
Impervious Manning's n	0.015	Regeneration Rate (s ⁻¹)	0.01
Pervious Manning's n	0.25		
		Evaporation	
Maintenance Frequency		Daily Evaporation Rate (mm/day)	2.54
Sediment build-up reduces the storage v			1
sedimentation. Frequency of maintenan assumed for TSS removal calculations.	ce is	Dry Weather Flow	
Maintenance Frequency (months)	12	Dry Weather Flow (L/s)	No

Upstream Attenuation

Maintenance Frequency (months)

Stage-storage and stage-discharge relationship used to model attenuation upstream of the Stormceptor System is identified in the table below.

12

Storage ha-m	Discharge L/s
0	0




PARTICLE SIZE DISTRIBUTION

Particle Size Distribution

Removing fine particles from runoff ensures the majority of pollutants, such as heavy metals, hydrocarbons, free oils and nutrients are not discharged into natural water resources. The table below identifies the particle size distribution selected to define TSS removal for the design of the Stormceptor System.

	City of Toronto (clay, silt and sand)							
Particle Size	Distribution	Specific Gravity	Settling Velocity		Particle Size	Distribution	Specific Gravity	Settling Velocity
μm	%	-	m/s		μm	%	-	m/s
10	20	2.65	0.0004					
30	10	2.65	0.0008					
50	10	2.65	0.0022					
95	20	2.65	0.0063					
265	20	2.65	0.0366					
1000	20	2.65	0.1691					



PCSWMM for Stormceptor Grain Size Distributions

Figure 1. PCSWMM for Stormceptor standard design grain size distributions.



TSS LOADING

TSS Loading Parameters

TSS Loading Function

Buildup / Washoff

Parameters

Target Event Mean Concentration (EMC) (mg/L)	125
Exponential Buildup Power	0.4
Exponential Washoff Exponential	0.2

HYDROLOGY ANALYSIS

PCSWMM for Stormceptor calculates annual hydrology with the US EPA SWMM and local continuous historical rainfall data. Performance calculations of the Stormceptor System are based on the average annual removal of TSS for the selected site parameters. The Stormceptor System is engineered to capture fine particles (silts and sands) by focusing on average annual runoff volume ensuring positive removal efficiency is maintained during all rainfall events, while preventing the opportunity for negative removal efficiency (scour).

Smaller recurring storms account for the majority of rainfall events and average annual runoff volume, as observed in the historical rainfall data analyses presented in this section.

Rainfall Station


Rainfall Station	OTTAWA MAC	OTTAWA MACDONALD-CARTIER INT'L A		
Rainfall File Name	ON6000.NDC	Total Number of Events	4537	
Latitude	45°19'N	Total Rainfall (mm)	20978.1	
Longitude	75°40'W	Average Annual Rainfall (mm)	567.0	
Elevation (m)	371	Total Evaporation (mm)	1821.2	
Rainfall Period of Record (y)	37	Total Infiltration (mm)	2089.3	
Total Rainfall Period (y)	37	Percentage of Rainfall that is Runoff (%)	81.8	



Rainfall Event Analysis

Rainfall Depth	No. of Events	Percentage of Total Events	Total Volume	Percentage of Annual Volume
mm		%	mm	%
6.35	3564	78.6	5671	27.0
12.70	508	11.2	4533	21.6
19.05	223	4.9	3434	16.4
25.40	102	2.2	2244	10.7
31.75	60	1.3	1704	8.1
38.10	33	0.7	1145	5.5
44.45	28	0.6	1165	5.6
50.80	9	0.2	416	2.0
57.15	5	0.1	272	1.3
63.50	1	0.0	63	0.3
69.85	1	0.0	64	0.3
76.20	1	0.0	76	0.4
82.55	0	0.0	0	0.0
88.90	1	0.0	84	0.4
95.25	0	0.0	0	0.0
101.60	0	0.0	0	0.0
107.95	0	0.0	0	0.0
114.30	1	0.0	109	0.5
120.65	0	0.0	0	0.0
127.00	0	0.0	0	0.0
133.35	0	0.0	0	0.0
139.70	0	0.0	0	0.0
146.05	0	0.0	0	0.0
152.40	0	0.0	0	0.0
158.75	0	0.0	0	0.0
165.10	0	0.0	0	0.0
171.45	0	0.0	0	0.0
177.80	0	0.0	0	0.0
184.15	0	0.0	0	0.0
190.50	0	0.0	0	0.0
196.85	0	0.0	0	0.0
203.20	0	0.0	0	0.0
209.55	0	0.0	0	0.0
>209.55	0	0.0	0	0.0


Frequency of Occurence by Rainfall Depths






Pollutograph

Flow Rate	Cumulative Mass
L/s	%
1	33.4
4	65.5
9	83.7
16 25	91.8 95.4
36	95.4 97.3
49	98.4
64	99.0
81	99.4
100	99.7
121	99.9
144	99.9
169	100.0
196	100.0
225 256	100.0 100.0
230	100.0
324	100.0
361	100.0
400	100.0
441	100.0
484	100.0
529	100.0
576	100.0
625	100.0
676 729	100.0 100.0
729 784	100.0
841	100.0
900	100.0



DRAWINGS / FIGURES



LOCATION PLAN

LEGEND

L

-	PROPERTY LINE
_	EXTENT OF PHASE 1A DEVELOPMENT
	EXTENT OF PHASE 1A BELOW GRADE
	EXISTING BUILDING TO BI RETAINED
	PROPOSED BUILDING FOOTPRINTS
Ļ	TEMPORARY EXIT-PHASE

EXTENT OF 6m WIDE FIRE ROUTE ALTERNATE EMERGENCY ROUTE

OPEN WATER COMMON AMENITY SPACE - CONDO TEMPORARY ASPHALT CURB ROLL CURB

н	PROPOSED FIRE HYDRANT LOCATION
Ħ	TEMPORARY FIRE HYDRANT LOCATION
	PROPOSED SIAMESE CONNECTION LOCATION
SAN.	SANITARY MANHOLE
STR.	STORM MANHOLE
3	CATCH BASIN
	TRENCH DRAIN
	EXISTING LIGHT POLE
<i>b.</i>	CAR SHARE PARKING SPACE
.S.	ACCESSIBLE PUBLIC PARKING SPACE
5.	PUBLIC PARKING SPACE
R	PUBLIC BIKE PARKING
·	EXSTING BUILDING TO BE DEMOLISHED

CURRENT ZONING	MD5 [2172] S332				
TOTAL PHASE 1A SITE AREA	10,938 m ²				
TEMPORARY OVERFLOW PARKING AREA - PHASE 1A	1,747 m²				
PHASE 1A No. OF DWELLING UNITS	71 DWELLING UNITS				
PHASE 1A RESIDENTIAL - 205A	6,250 m²				
PHASE 1A RETAIL AREA - 205A	768 m²				
PHASE 1A RETAIL AREA - 208	1,457 m²				
PHASE 1A OFFICE AREA - 208	1,298 m ²				
PHASE 1A Restaurant - 208	100 m²				
PHASE 1 GROSS FLOOR AREA	9,873 m²				
SETBACKS	ALL SIDES : NO MINIMU	MS	REFER TO SITE PLAN		
BUILDING HEIGHTS	73m, maximum 4 buildings o storeys within Area A o 332	ver nine(9) n Schedule	Block 208: 3 Store Block 301: under	eys - 18.5m eys -15m ground parking gara	
AMENITY AREA	REQUIRED TOTAL: 402m		PROVIDED TOTAL:	1056m²	
6m ² PER UNIT 50% TO BE COMMUNAL (201m ²) 402m ² Required	COMMON: 201n		private balconies/terrao Total communal: Indoor (fitness roo Outdoor (part of hea	222.7m ²	
PARKING	MIN. REQUIRED:	11 SPACES	PARKING FOR PHASE 1A		
<u>RESIDENTIAL + VISITOR:</u> MINIMUM: NONE	OFFICE:	11 SPACES	BLOCK 301 P1:	64 SPACES	
MAXIMUM: 1.5/DWELLING UNIT			BLOCK 205A - P1:	36 SPACES	
RETAIL:			SURFACE: TOTAL PROPOSED:	97 SPACES 197 SPACES	
MINIMUM: NONE			IOTAL PROPOSED.	197 SFACES	
MAXIMUM: 1.0/100M2 OF GFA	MAX. PERMITTED:		PARKING FOR PHASE 1A	- BY USE	
OFFICE:	RETAIL:	22 SPACES	RETAIL:	22 SPACES	
<u>OFFICE:</u> MINIMUM: 0.75/100M2 OF GFA	OFFICE:	14 SPACES	OFFICE:	11 SPACES	
MAXIMUM: 1.0/100M2 OF GFA	RESIDENTIAL + VISITOR:		RESIDENTIAL + VISITOR:	67 SPACES	
	TOTAL MAX PERMITED:	143 SPACES	RESTAURANT:	97 SPACES	
RESTAURANT:			TOTAL PROPOSED:	197 SPACES	
MINIMUM: NONE MAXIMUM: NONE			**NOTE : PARKING LEVEL PARKING SPACES) OF BL AVAILABLE IN PHASE 1B Y	OCK 301 WILL ONLY	
BICYCLE PARKING	TOTAL REQUIREMENT:	44 SPACES	TOTAL REQUIREMENT:	84 SPACES	
RESIDENTIAL:	RESIDENTIAL:	34 SPACES	RESIDENTIAL INTERIOR:	34 SPACES	
0.5/DWELLING UNIT RETAIL/OFFICE: 1/250M2 OF	RETAIL:	4 SPACES	PUBLIC EXTERIOR:	50 SPACES	
GFA	OFFICE:	6 SPACES			
RESTAURANT: 1/1,500M2 OF GFA					
50% CAN BE VERTICAL					

PROJECT TEAM

PLANING FOTENN CONSULTANTS INC. PAUL BLACK MIGUEL TREMBLAY T 613.730.5709

ARCHITECT BARRY J. HOBIN & ASSOCIATES ARCHITECTS INC. GORD LORIMER 613.238.7200

STRUCTURAL WSP / HALSALL SCOTT FUNNELL 613.907.7532

CIVIL DAVID SHAEFFER ENGINEERING LTD ADAM FOBERT, 613.836.0856 x231

LANDSCAPE ARCHITECT PROJET PAYSAGE SERGE GALLANT 514.849.7700

TRANSPORTATION PARSONS RONALD JACK 613.738.4160

SITE WIDE ELECTRICAL CROSSEY ENGINEERING LTD. DUANE WAITE T 613.497.3111 x228

SITE WIDE MECHANICAL GOODKEY WEEDMARK & ASSOCIATES LIMITED. ROBERT LEFEBVRE 613.727.5111 x234

GEOTECHNICAL PATERSONS GROUP CARLOS DASILVA 613.226.7381

LAND SURVEYOR STANTEC GEOMATICS LTD. CHARLES TAILLEFER / BRIAN WEBSTER 613.722.4420

NOTE: ALL ENERGY OTTAWA RELATED LANDSCAPE INFORMATION OUTSIDE OUR PROPERTY LIMITS ARE BASED ON CSW LANDSCAPE ARCHITECTS LIMITED ISSUED FOR CONSTRUCTION SET DATED 17.05.17 NOTE: ALL EXISTING SITE INFORMATION AS PER SITE SURVEY PLAN DATED XX.XX.XX AND PREPARED BY

"STANTEC GEOMATICS LTD." APPROVED REFUSED

THIS DAY OF ,20 DOUGLAS JAMES, MCIP, RPP, ACTING MANAGER, DEVELOPMENT REVIEW

CENTRAL PLANNING, INFRASTRUCTURE AND ECONOMIC DEVELOPMENT DEPARTMENT, CITY OF OTTAWA

10	17.08.XX	S.P.C PHASE 1A RESUB. 1	
9	17.08.18	ISSUED FOR COORDINATION	
2	16.04.05	ISSUED FOR S.P.C. PHASE 1A	
1	15.08.14	ISSUED FOR S.P.C. PHASE 1A	
no.	date	revision	
It is the responsibility of the appropriate			

contractor to check and verify all dimer sions on site and report all errors and/ or omissions to the architect. All contractors must comply with all pertinent codes and by-laws.

Do not scale drawings.

This drawing may not be used for construction until signed.

Copyright reserved.



Hobin Architecture Incorporated 63 Pamilla Street

Ottawa, Ontario Canada K1S 3K7 T: 613-238-7200 F: 613-235-2005 E: mail@hobinarc.com hobinarc.com




project ZIBI

drawing title ZIBI ONTARIO - MASTER PLAN CHADIERE WEST PHASE 1A

drawn date scale 17-02-02 1:300 project 1508 drawing no.

.\07-Logos\Barry J Hobin EAA Stamp.jpg


revision no.



LOCATION PLAN



LEGEND



EXTENT OF PHASE 1A DEVELOPMENT EXTENT OF PHASE 1A BELOW GRADE EXISTING BUILDING TO BE RETAINED PROPOSED BUILDING

TEMPORARY EXIT-PHASE 1 EXTENT OF 6m WIDE FIRE ROUTE ALTERNATE EMERGENCY ROUTE OPEN WATER COMMON AMENITY

FOOTPRINTS

SPACE - CONDO TEMPORARY ASPHALT CURB ROLL CURB



PROJECT TEAM

PLANING FOTENN CONSULTANTS INC. PAUL BLACK MIGUEL TREMBLAY T 613.730.5709

ARCHITECT BARRY J. HOBIN & ASSOCIATES ARCHITECTS INC. GORD LORIMER T 613.238.7200

STRUCTURAL WSP / HALSALL SCOTT FUNNELL 613.907.7532

CIVIL DAVID SHAEFFER ENGINEERING LTD ADAM FOBERT,

T 613.836.0856 x231 LANDSCAPE ARCHITECT PROJET PAYSAGE SERGE GALLANT T 514.849.7700

TRANSPORTATION PARSONS Ronald Jack б 613.738.4160

SITE WIDE ELECTRICAL CROSSEY ENGINEERING LTD. DUANE WAITE T 613.497.3111 x228

SITE WIDE MECHANICAL GOODKEY WEEDMARK & ASSOCIATES LIMITED. ROBERT LEFEBVRE T 613.727.5111 x234

GEOTECHNICAL PATERSONS GROUP CARLOS DASILVA T 613.226.7381

LAND SURVEYOR STANTEC GEOMATICS LTD. CHARLES TAILLEFER / BRIAN WEBSTER f 613.722.4420

NOTE: ALL ENERGY OTTAWA RELATED LANDSCAPE INFORMATION OUTSIDE OUR PROPERTY LIMITS ARE BASED ON CSW LANDSCAPE ARCHITECTS LIMITED ISSUED FOR CONSTRUCTION SET DATED 17.05.17

NOTE: ALL EXISTING SITE INFORMATION AS PER SITE SURVEY PLAN DATED XX.XX.XX AND PREPARED BY "STANTEC GEOMATICS LTD."

APPROVED REFUSED THIS DAY OF ,20 DOUGLAS JAMES, MCIP, RPP, ACTING MANAGER, DEVELOPMENT REVIEW CENTRAL PLANNING, INFRASTRUCTURE AND ECONOMIC DEVELOPMENT DEPARTMENT, CITY OF OTTAWA

10 17.08.XX S.P.C PHASE 1A RESUB. 1 9 17.08.18 ISSUED FOR COORDINATION 2 16.04.05 ISSUED FOR S.P.C. PHASE 1A 1 15.08.14 ISSUED FOR S.P.C. PHASE 1A no. date revision It is the responsibility of the appropriate contractor to check and verify all dimen-

sions on site and report all errors and/ or omissions to the architect.

All contractors must comply with all pertinent codes and by-laws.

Do not scale drawings.

This drawing may not be used for construction until signed. Copyright reserved.



Hobin Architecture Incorporated

63 Pamilla Street Ottawa, Ontario Canada K1S3K7 T: 613-238-7200 F: 613-235-2005 E: mail@hobinarc.com hobinarc.com

477 HOBIN ARCHITECTURE

project ZIBI

drawing title ZIBI ONTARIO - MASTER PLAN CHAUDIERE WEST PHASE 1A

drawn	date	scale
РВ	17-02-02	1:500
		project
		1508
		drawing no.
VI7-Logos/Jerry J	Holdin DAA Steep,jpg	

|A004|j

revision no.

🔹 °e

