

SANITARY SEWER CALCULATION SHEET




Manning's n=0.013

LOCATION			RESIDENTIAL AREA AND POPULATION								COMM		INSTIT		PARK		C+H		INFILTRATION			PIPE							
STREET	FROM M.H.	TO M.H.	AREA (ha)	UNITS	UNITS Singles	UNITS Townhouse	POP.	CUMULATIVE		PEAK FLOW (l/s)	PEAK FLOW (l/s)	AREA (ha)	ACCU. AREA (ha)	AREA (ha)	ACCU. AREA (ha)	AREA (ha)	ACCU. AREA (ha)	PEAK FLOW (l/s)	TOTAL AREA (ha)	ACCU. AREA (ha)	INFILT. FLOW (l/s)	TOTAL FLOW (l/s)	DIST (m)	DIA (mm)	SLOPE (%)	CAP. (FULL) (l/s)	RATIO Q act/Q cap	VEL.	
								AREA (ha)	POP.																			(FULL) (m/s)	(ACT.) (m/s)
	31A	32A	0.34	9	9		31	0.71	65	3.63	0.77		0.00		0.00		0.00	0.00	0.34	0.71	0.23	1.00	64.0	250	0.25	29.73	0.03	0.61	0.28
To Sapling Grove, Pipe 32A - 37A								0.71	65				0.00		0.00		0.00			0.71									
	30A	33A	0.13	2	2		7	0.13	7	3.74	0.08		0.00		0.00		0.00	0.13	0.13	0.04	0.13	9.5	200	0.65	26.44	0.00	0.84	0.22	
	33A	34A	0.16	3	3		11	0.29	18	3.71	0.22		0.00		0.00		0.00	0.16	0.29	0.10	0.31	43.5	250	0.25	29.73	0.01	0.61	0.19	
	34A	35A	0.12	1	1		4	0.41	22	3.70	0.26		0.00		0.00		0.00	0.12	0.41	0.14	0.40	11.5	250	0.25	29.73	0.01	0.61	0.21	
	35A	36A	0.44	11	11		38	0.85	60	3.64	0.71		0.00		0.00		0.00	0.44	0.85	0.28	0.99	68.5	250	0.25	29.73	0.03	0.61	0.27	
	36A	37A	0.31	9	9		31	1.16	91	3.60	1.06		0.00		0.00		0.00	0.31	1.16	0.38	1.45	61.5	250	0.25	29.73	0.05	0.61	0.31	
To Mineral Street, Pipe 37A - 39A								1.16	91				0.00		0.00		0.00			1.16									
Pollination Place																													
	250A	26A	0.11	2	2		7	0.11	7	3.74	0.08		0.00		0.00		0.00	0.11	0.11	0.04	0.12	24.5	200	0.65	26.44	0.00	0.84	0.20	
	26A	27A	0.09	1	1		4	0.20	11	3.73	0.13		0.00		0.00		0.00	0.09	0.20	0.07	0.20	11.0	200	0.65	26.44	0.01	0.84	0.24	
	27A	28A	0.39	10	10		34	0.59	45	3.66	0.53		0.00		0.00		0.00	0.39	0.59	0.19	0.73	63.5	250	0.25	29.73	0.02	0.61	0.25	
	28A	29A	0.34	10	10		34	0.93	79	3.62	0.93		0.00		0.00		0.00	0.34	0.93	0.31	1.23	62.5	250	0.25	29.73	0.04	0.61	0.29	
To Sapling Grove, Pipe 29A - 32A								0.93	79				0.00		0.00		0.00			0.93									
	250A	25A	0.09	2	2		7	0.09	7	3.74	0.08		0.00		0.00		0.00	0.09	0.09	0.03	0.11	20.5	200	0.65	26.44	0.00	0.84	0.20	
	25A	19A	0.04				0	0.13	7	3.74	0.08		0.00		0.00		0.00	0.04	0.13	0.04	0.13	8.0	250	0.25	29.73	0.00	0.61	0.15	
	19A	20A	0.28	5	5		17	0.41	24	3.70	0.29		0.00		0.00		0.00	0.28	0.41	0.14	0.42	71.0	250	0.25	29.73	0.01	0.61	0.21	
	20A	21A	0.19	4	4		14	0.60	38	3.67	0.45		0.00		0.00		0.00	0.19	0.60	0.20	0.65	54.5	250	0.25	29.73	0.02	0.61	0.24	
To Sapling Grove, Pipe 21A - 29A								0.60	38				0.00		0.00		0.00			0.60									
Sapling Grove																													
Contribution From Pollination Place, Pipe 20A - 21A								0.60	38				0.00		0.00		0.00	0.60	0.60										
	21A	29A	0.23	3	3		11	0.83	49	3.65	0.58		0.00		0.00		0.00	0.23	0.83	0.27	0.85	59.0	250	0.25	29.73	0.03	0.61	0.27	
Contribution From Pollination Place, Pipe 28A - 29A								0.93	79				0.00		0.00		0.00	0.93	1.76										
	29A	32A	0.25	5	5		17	2.01	145	3.56	1.67		0.00		0.00		0.00	0.25	2.01	0.66	2.33	58.5	250	0.25	29.73	0.08	0.61	0.36	
Contribution From Gallium Crescent, Pipe 31A - 32A								0.71	65				0.00		0.00		0.00	0.71	2.72										
	32A	37A	0.19	4	4		14	2.91	224	3.50	2.54		0.00		0.00		0.00	0.19	2.91	0.96	3.50	58.5	250	0.25	29.73	0.12	0.61	0.40	
To Mineral Street, Pipe 37A - 39A								2.91	224				0.00		0.00		0.00			2.91									
	510A	51A	0.18	3	3		11	0.18	11	3.73	0.13		0.00		0.00		0.00	0.18	0.18	0.06	0.19	48.5	200	0.65	26.44	0.01	0.84	0.24	
Contribution From Syringa Court, Pipe 50A - 51A								1.03	87				0.00		0.00		0.00	1.03	1.21										
	51A	58A	0.25	5	5		17	1.46	115	3.58	1.33		0.00		0.00		0.00	0.25	1.46	0.48	1.82	58.5	250	0.25	29.73	0.06	0.61	0.33	
Contribution From Syringa Court, Pipe 57A - 58A								0.90	79				0.00		0.00		0.00	0.90	2.36										
	58A	61A	0.19	4	4		14	2.55	208	3.51	2.37		0.00		0.00		0.00	0.19	2.55	0.84	3.21	58.5	250	0.25	29.73	0.11	0.61	0.39	
Contribution From Ainsworth Crescent, Pipe 60A - 61A								0.93	83				0.00		0.00		0.00	0.93	3.48										
	61A	82A	0.22	4	4		14	3.70	305	3.46	3.42		0.00		0.00		0.00	0.22	3.70	1.22	4.64	60.0	250	0.25	29.73	0.16	0.61	0.44	
Contribution From Ainsworth Crescent, Pipe 81A - 82A								0.89	72				0.00		0.00		0.00	0.89	4.59										
	82A	85A	0.18	4	4		14	4.77	391	3.42	4.34		0.00		0.00		0.00	0.18	4.77	1.57	5.91	58.5	250	0.25	29.73	0.20	0.61	0.47	
Contribution From Meander Way, Pipe 84A - 85A								0.50	45				0.00		0.00		0.00	0.50	5.27										
	85A	88A	0.21	5	5		17	5.48	453	3.40	4.99		0.00		0.00		0.00	0.21	5.48	1.81	6.79	58.5	250	0.25	29.73	0.23	0.61	0.49	
To Ecology Lane, Pipe 88A - 91A								5.48	453				0.00		0.00		0.00			5.48									

DESIGN PARAMETERS

Park Flow =	9300	L/ha/da	0.10764	I/s/ha
Average Daily Flow =	280	l/p/day		
Comm/Inst Flow =	28000	L/ha/da	0.3241	
Industrial Flow =	35000	L/ha/da	0.40509	
Max Res. Peak Factor =	4.00			
Commercial/Inst./Park Peak Factor =	1.50			
Institutional =	0.32	I/s/ha		



Industrial Peak Factor = as per MOE Graph
 Extraneous Flow = 0.330 L/s/ha
 Minimum Velocity = 0.600 m/s
 Manning's n = (Conc) 0.013 (Pvc) 0.013
 Townhouse coeff= 2.7
 Single house coeff= 3.4

Designed: A.K.
 Checked: W.L.
 Dwg. Reference: Sanitary Drainage Plan, Dwgs. No. 110-112

PROJECT: **BARRHAVEN CONCERNANCY EAST PH2, 3, AND JOCK RIVER**
 LOCATION: **City of Ottawa**
 File Ref: 20-1180
 Date: **Aug 2022**
 Sheet No. **2** of **6**

SANITARY SEWER CALCULATION SHEET



Manning's n=0.013

LOCATION			RESIDENTIAL AREA AND POPULATION								COMM		INSTIT		PARK		C+H		INFILTRATION			PIPE							
STREET	FROM M.H.	TO M.H.	AREA (ha)	UNITS	UNITS Singles	UNITS Townhouse	POP.	CUMULATIVE		PEAK FACT.	PEAK FLOW (l/s)	AREA (ha)	ACCU. AREA (ha)	AREA (ha)	ACCU. AREA (ha)	AREA (ha)	ACCU. AREA (ha)	PEAK FLOW (l/s)	TOTAL AREA (ha)	ACCU. AREA (ha)	INFILT. FLOW (l/s)	TOTAL FLOW (l/s)	DIST (m)	DIA (mm)	SLOPE (%)	CAP. (FULL) (l/s)	RATIO Q act/Q cap	VEL.	
								AREA (ha)	POP.																			(FULL) (m/s)	(ACT.) (m/s)
Deciduous Crescent																													
	8A	9A	0.44	17		17	46	0.44	46	3.66	0.55		0.00		0.00	0.00	0.00	0.44	0.44	0.15	0.69	62.0	200	0.65	26.44	0.03	0.84	0.36	
	9A	11A	0.26	10		10	27	0.70	73	3.62	0.86		0.00		0.00	0.00	0.00	0.26	0.70	0.23	1.09	66.0	250	0.25	29.73	0.04	0.61	0.29	
To Conservancy Drive, Pipe 11A - 15A								0.70	73				0.00		0.00					0.70									
	12A	13A	0.09	2		2	6	0.09	6	3.75	0.07		0.00		0.00	0.00	0.00	0.09	0.09	0.03	0.10	7.5	200	0.65	26.44	0.00	0.84	0.20	
	13A	14A	0.38	15		15	41	0.47	47	3.66	0.56		0.00		0.00	0.00	0.00	0.38	0.47	0.16	0.71	66.0	250	0.25	29.73	0.02	0.61	0.25	
	14A	15A	0.30	11		11	30	0.77	77	3.62	0.90		0.00		0.00	0.00	0.00	0.30	0.77	0.25	1.16	69.5	250	0.25	29.73	0.04	0.61	0.29	
To Conservancy Drive, Pipe 15A - 18A								0.77	77				0.00		0.00					0.77									
Ephemeral Crescent																													
	2A	3A	0.16	1	1		4	0.16	4	3.76	0.05		0.00		0.00	0.00	0.00	0.16	0.16	0.05	0.10	13.0	200	0.70	27.44	0.00	0.87	0.19	
			0.25	5	5		17	0.41	21				0.00		0.00	0.00	0.00	0.25	0.41										
	3A	4A	0.31	13		13	36	0.72	57	3.64	0.67		0.00		0.00	0.00	0.00	0.31	0.72	0.24	0.91	107.5	250	0.25	29.73	0.03	0.61	0.27	
	4A	15A	0.35	9		9	25	1.07	82	3.61	0.96		0.00		0.00	0.00	0.00	0.35	1.07	0.35	1.31	112.0	250	0.25	29.73	0.04	0.61	0.30	
To Conservancy Drive, Pipe 15A - 18A								1.07	82				0.00		0.00					1.07									
	5A	500A	0.14	6		6	17	0.14	17	3.71	0.20		0.00		0.00	0.00	0.00	0.14	0.14	0.05	0.25	21.0	200	0.65	26.44	0.01	0.84	0.26	
	500A	6A	0.45	22		22	60	0.59	77	3.62	0.90		0.00		0.00	0.00	0.00	0.45	0.59	0.19	1.10	78.5	250	0.25	29.73	0.04	0.61	0.29	
	6A	11A	0.48	21		21	57	1.07	134	3.57	1.55		0.00		0.00	0.00	0.00	0.48	1.07	0.35	1.90	104.5	250	0.25	29.73	0.06	0.61	0.34	
To Conservancy Drive, Pipe 11A - 15A								1.07	134				0.00		0.00					1.07									
Borrisokane Road																													
	1002A	1001A	0.18	4		4	11	0.18	11	3.73	0.13		0.00		0.00	0.00	0.00	0.18	0.18	0.06	0.19	40.0	200	0.65	26.44	0.01	0.84	0.24	
	1001A	10A	0.40	12		12	33	0.58	44	3.66	0.52		0.00		0.00	0.00	0.00	0.40	0.58	0.19	0.71	100.0	250	0.25	29.73	0.02	0.61	0.25	
To Conservancy Drive, Pipe 10A - 11A								0.58	44				0.00		0.00					0.58									
	1004A	1003A	0.50	14		14	38	0.50	38	3.67	0.45		0.00		0.00	0.00	0.00	0.50	0.50	0.17	0.62	98.5	200	0.65	26.44	0.02	0.84	0.35	
	1003A	10A	0.41	13		13	36	0.91	74	3.62	0.87		0.00		0.00	0.00	0.00	0.41	0.91	0.30	1.17	100.0	250	0.25	29.73	0.04	0.61	0.29	
To Conservancy Drive, Pipe 10A - 11A								0.91	74				0.00		0.00					0.91									
Conservancy Drive																													
			12.88				1182	12.88	1182			4.21	4.21		0.00	0.58	0.58		17.67	17.67									
	PLUG	10A	36.45				3771	49.33	4953	2.80	44.93	13.70	17.91	0.00	3.47	4.05	9.36	53.62	71.29	23.53	77.81	20.5	525	0.10	136.00	0.57	0.63	0.65	
Contribution From Borrisokane Road, Pipe 1001A - 10A								0.58	44				0.00		0.00				0.58	71.87									
Contribution From Borrisokane Road, Pipe 1003A - 10A								0.91	74				0.00		0.00				0.91	72.78									
	10A	11A	0.15				0	50.97	5071	2.79	45.87		17.91	0.00	4.05	9.36	0.15	72.93	24.07		79.30	71.5	525	0.10	136.00	0.58	0.63	0.65	
Contribution From Ephemeral Crescent, Pipe 6A - 11A								1.07	134				0.00		0.00				1.07	74.00									
Contribution From Deciduous Crescent, Pipe 9A - 11A								0.70	73				0.00		0.00				0.70	74.70									
	11A	15A	0.30	6	6		21	53.04	5299	2.78	47.69		17.91	0.00	4.05	9.36	0.30	75.00	24.75		81.80	59.0	525	0.10	136.00	0.60	0.63	0.66	
Contribution From Deciduous Crescent, Pipe 14A - 15A								0.77	77				0.00		0.00				0.77	75.77									
Contribution From Ephemeral Crescent, Pipe 4A - 15A								1.07	82				0.00		0.00				1.07	76.84									
	15A	18A	0.12				0	55.00	5458	2.77	48.95		17.91	0.00	4.05	9.36	0.12	76.96	25.40		83.71	58.5	525	0.10	136.00	0.62	0.63	0.66	
Contribution From Les Emmerson Drive (N), Pipe 17A - 18A								0.83	75				0.00		0.00				0.83	77.79									
Contribution From Park (Block 773), Pipe 210A - 18A								0.00	0.00				0.00		0.00	3.22			3.22	81.01									
	18A	23A	0.31	5	5		17	56.14	5550	2.76	49.68		17.91	0.00	4.05	9.36	0.31	81.32	26.84		85.88	76.5	525	0.10	136.00	0.63	0.63	0.66	
	23A	24A	0.49	11	11		38	56.63	5588	2.76	49.98		17.91	0.00	4.05	9.36	0.49	81.81	27.00		86.34	71.0	525	0.10	136.00	0.63	0.63	0.66	
	24A	47A	0.61	15	15		51	57.24	5639	2.76	50.38		17.91	0.00	4.05	9.36	0.61	82.42	27.20		86.94	106.0	525	0.10	136.00	0.64	0.63	0.67	

DESIGN PARAMETERS			
Park Flow =	9300	L/ha/da	0.10764
Average Daily Flow =	280	l/p/day	
Comm/Inst Flow =	28000	L/ha/da	0.3241
Industrial Flow =	35000	L/ha/da	0.40509
Max Res. Peak Factor =	4.00		
Commercial/Inst./Park Peak Factor =	1.50		
Institutional =	0.32	l/s/ha	



Industrial Peak Factor = as per MOE Graph
 Extraneous Flow = 0.330 L/s/ha
 Minimum Velocity = 0.600 m/s
 Manning's n = (Conc) 0.013 (Pvc) 0.013
 Townhouse coeff= 2.7
 Single house coeff= 3.4

Designed:	A.K.	PROJECT:	BARRHAVEN CONCERNANCY EAST PH2, 3, AND JOCK RIVER		
Checked:	W.L.	LOCATION:	City of Ottawa		
Dwg. Reference:	Sanitary Drainage Plan, Dwg. No. 110-112	File Ref:	20-1180	Date:	Aug 2022
				Sheet No.	4 of 6

SANITARY SEWER CALCULATION SHEET




Manning's n=0.013

LOCATION			RESIDENTIAL AREA AND POPULATION							COMM		INSTIT		PARK		C+H		INFILTRATION			PIPE					VEL.						
STREET	FROM M.H.	TO M.H.	AREA (ha)	UNITS	UNITS Singles	UNITS Townhouse	POP.	AREA (ha)	POP.	PEAK FACT.	PEAK FLOW (l/s)	AREA (ha)	ACCU. AREA (ha)	AREA (ha)	ACCU. AREA (ha)	AREA (ha)	ACCU. AREA (ha)	PEAK FLOW (l/s)	TOTAL AREA (ha)	ACCU. AREA (ha)	INFILT. FLOW (l/s)	TOTAL FLOW (l/s)	DIST (m)	DIA (mm)	SLOPE (%)	CAP. (FULL) (l/s)	RATIO Q act/Q cap	(FULL) (m/s)	(ACT.) (m/s)			
Contribution From Mineral Street, Pipe 39A - 47A							5.28	398					0.00		0.00		0.00		5.28	87.70												
Contribution From Mineral Street, Pipe 46A - 47A							1.45	137					0.00		0.00		0.00		1.45	89.15												
	47A	48A	0.56	14	14		48	64.53	6222	2.72	54.94		17.91		0.00		4.05	9.36	0.56	89.71	29.60	93.90	99.0	525	0.10	136.00	0.69	0.63	0.68			
	48A	75A	0.42	10	10		34	64.95	6256	2.72	55.20		17.91		0.00		4.05	9.36	0.42	90.13	29.74	94.30	76.5	525	0.10	136.00	0.69	0.63	0.68			
Contribution From Anemone Mews, Pipe 63A - 75A							1.30	104					0.00		0.00		0.00		1.30	91.43												
Contribution From Anemone Mews, Pipe 750A - 75A							5.89	565					0.00		0.00		0.00		5.89	97.32												
	75A	76A	0.31	7	7		24	72.45	6949	2.69	60.53		17.91		0.00		4.05	9.36	0.31	97.63	32.22	102.11	62.0	525	0.10	136.00	0.75	0.63	0.69			
	76A	77A	0.39	11	11		38	72.84	6987	2.69	60.82		17.91		0.00		4.05	9.36	0.39	98.02	32.35	102.52	60.0	525	0.10	136.00	0.75	0.63	0.69			
	77A	92A	0.33	9	9		31	73.17	7018	2.68	61.05		17.91		0.00		4.05	9.36	0.33	98.35	32.46	102.87	53.0	525	0.10	136.00	0.76	0.63	0.69			
Contribution From Ecology Lane, Pipe 91A - 92A							6.96	580					0.00		0.00		0.00		6.96	105.31												
	92A	93A	0.51	12	12		41	80.64	7639	2.66	65.75		17.91		0.00		4.05	9.36	0.51	105.82	34.92	110.03	90.5	525	0.10	136.00	0.81	0.63	0.70			
	93A	119A	0.37	6	6		21	81.01	7660	2.65	65.91		17.91		0.00	0.52	4.57	9.44	0.89	106.71	35.21	110.56	88.0	525	0.10	136.00	0.81	0.63	0.70			
To Canoe Street, Pipe 119A - 120A							81.01	7660					17.91		0.00		4.57			106.71												
Meander Way																																
	84A	85A	0.50	13	13		45	0.50	45	3.66	0.53		0.00		0.00		0.00	0.00	0.50	0.50	0.17	0.70	92.5	200	0.65	26.44	0.03	0.84	0.36			
To Sapling Grove, Pipe 85A - 88A							0.50	45					0.00		0.00		0.00			0.50												
	84A	86A	0.16	1	1		4	0.16	4	3.76	0.05		0.00		0.00		0.00	0.00	0.16	0.16	0.05	0.10	13.0	200	0.65	26.44	0.00	0.84	0.20			
	86A	87A	0.22	4	4		14	0.38	18	3.71	0.22		0.00		0.00		0.00	0.00	0.22	0.38	0.13	0.34	50.5	250	0.65	47.94	0.01	0.98	0.28			
	87A	114A	0.23	5	5		17	0.61	35	3.67	0.42		0.00		0.00		0.00	0.00	0.23	0.61	0.20	0.62	58.0	250	0.25	29.73	0.02	0.61	0.24			
	114A	115A	0.07	1	1		4	0.68	39	3.67	0.46		0.00		0.00		0.00	0.00	0.07	0.68	0.22	0.69	10.0	250	0.25	29.73	0.02	0.61	0.25			
	115A	116A	0.63	17	17		58	1.31	97	3.60	1.13		0.00		0.00		0.00	0.00	0.63	1.31	0.43	1.56	110.5	250	0.25	29.73	0.05	0.61	0.32			
To Peninsula Road, Pipe 116A - 117A							1.31	97					0.00		0.00		0.00			1.31												
Peninsula Road																																
	89A	63A	0.17	4	4		14	0.17	14	3.72	0.17		0.00		0.00		0.00	0.00	0.17	0.17	0.06	0.22	41.0	200	0.65	26.44	0.01	0.84	0.26			
To Anemone Mews, Pipe 63A - 75A							0.17	14					0.00		0.00		0.00			0.17												
	380A	38A	0.45	8	8		28	0.45	28	3.69	0.33		0.00		0.00		0.00	0.00	0.45	0.45	0.15	0.48	57.0	200	0.65	26.44	0.02	0.84	0.32			
	38A	39A	0.60	16	16		55	1.05	83	3.61	0.97		0.00		0.00		0.00	0.00	0.60	1.05	0.35	1.32	108.5	250	0.25	29.73	0.04	0.61	0.30			
To Mineral Street, Pipe 39A - 47A							1.05	83					0.00		0.00		0.00			1.05												
	620A	62A	0.50	13	13		45	0.50	45	3.66	0.53		0.00		0.00		0.00	0.00	0.50	0.50	0.17	0.70	83.0	200	0.65	26.44	0.03	0.84	0.36			
	62A	63A	0.45	13	13		45	0.95	90	3.60	1.05		0.00		0.00		0.00	0.00	0.45	0.95	0.31	1.36	82.0	250	0.25	29.73	0.05	0.61	0.31			
To Anemone Mews, Pipe 63A - 75A							0.95	90					0.00		0.00		0.00			0.95												
	89A	90A	0.41	13	13		45	0.41	45	3.66	0.53		0.00		0.00		0.00	0.00	0.41	0.41	0.14	0.67	67.0	200	0.65	26.44	0.03	0.84	0.35			
	90A	91A	0.37	10	10		34	0.78	79	3.62	0.93		0.00		0.00		0.00	0.00	0.37	0.78	0.26	1.18	68.5	250	0.75	51.50	0.02	1.05	0.42			
To Ecology Lane, Pipe 91A - 92A							0.78	79					0.00		0.00		0.00			0.78												
	91A	116A	0.18	4	4		14	0.18	14	3.72	0.17		0.00		0.00		0.00	0.00	0.18	0.18	0.06	0.23	58.5	200	0.65	26.44	0.01	0.84	0.26			
Contribution From Meander Way, Pipe 115A - 116A							1.31	97					0.00		0.00		0.00			1.31	1.49											
	116A	117A	0.23	6	6		21	1.72	132	3.57	1.53		0.00		0.00		0.00	0.00	0.23	1.72	0.57	2.09	58.5	250	0.25	29.73	0.07	0.61	0.34			
Contribution From Elation Heights, Pipe 109A - 117A							0.74	55					0.00		0.00		0.00			0.74	2.46											
	117A	118A	0.18	3	3		11	2.64	198	3.52	2.26		0.00		0.00		0.00	0.00	0.18	2.64	0.87	3.13	59.0	250	0.25	29.73	0.11	0.61	0.39			
To Canoe Street, Pipe 118A - 1180A							2.64	198					0.00		0.00		0.00			2.64												

DESIGN PARAMETERS

Park Flow =	9300	L/ha/da	0.10764	I/s/ha
Average Daily Flow =	280	l/p/day		
Comm/Inst Flow =	28000	L/ha/da	0.3241	I/s/ha
Industrial Flow =	35000	L/ha/da	0.40509	I/s/ha
Max Res. Peak Factor =	4.00			
Commercial/Inst./Park Peak Factor =	1.50			
Institutional =	0.32	I/s/ha		



Industrial Peak Factor = as per MOE Graph
 Extraneous Flow = 0.330 L/s/ha
 Minimum Velocity = 0.600 m/s
 Manning's n = 0.013 (Pvc) 0.013
 Inhouse coeff= 2.7
 Inlet house coeff= 3.4

Designed:	A.K.	PROJECT:	BARRHAVEN CONCERNANCY EAST PH2, 3, AND JOCK RIVER		
Checked:	W.L.	LOCATION:	City of Ottawa		
Dwg. Reference:	Sanitary Drainage Plan, Dwgs. No. 110-112	File Ref:	20-1180	Date:	Aug 2022
				Sheet No.	5 of 6

