



Engineers, Planners & Landscape Architects

Engineering

Land / Site
Development
Municipal
Infrastructure
Environmental /
Water Resources
Traffic /
Transportation
Structural
Recreational

Planning

Land / Site
Development
Planning Application
Management
Municipal Planning
Documents &
Studies
Expert Witness
(OMB)
Wireless Industry

Landscape Architecture

Urban Design &
Streetscapes
Open Space, Parks &
Recreation Planning
Community &
Residential
Developments
Commercial &
Institutional Sites
Environmental
Restoration



Adelaide Apartments Tower Expansion

Stormwater Management and Servicing Brief

Engineering excellence. Planning precision. Inspired landscapes.

STORMWATER MANAGEMENT AND SERVICING BRIEF

Adelaide Apartments Tower Expansion

Prepared By:

NOVATECH

Suite 200, 240 Michael Cowpland Drive
Ottawa, Ontario
K2M 1P6

January 5th, 2016

September 20th, 2016

Revised: January 25th, 2019

Novatech File: 116070

Ref No. R-2016-076

January 25th, 2019

City of Ottawa
Planning and Growth Management Department
Development Review (Urban Services)
110 Laurier Avenue West
Ottawa, Ontario
K1P 1J1

Attention: Mark Fraser

Re: Adelaide Apartments Tower Expansion – Stormwater and Servicing Brief

Enclosed is a copy of the revised 'Stormwater Management and Servicing Brief' for the proposed development at Preston Square in the City of Ottawa. This brief is submitted in support of the site plan application and demonstrates how the site will be serviced with sanitary, storm, and water infrastructure.

Should you have any questions, please contact me.

NOVATECH

Greg MacDonald, P.Eng.
Director, Land Development and Public Sector Infrastructure

TABLE OF CONTENTS

1.0 INTRODUCTION.....	1
1.1 PURPOSE	1
2.0 SANITARY SEWER.....	1
2.1 DESIGN CRITERIA	1
2.2 PROPOSED SANITARY FLOWS	2
3.0 STORMWATER MANAGEMENT	2
3.1 EXISTING SITE STORMWATER MANAGEMENT	2
3.2 STORMWATER MANAGEMENT DESIGN CRITERIA AND METHODOLOGY	3
3.3 ALLOWABLE RELEASE RATES.....	3
3.4 POST-DEVELOPMENT SITE CONDITIONS	4
3.4.1 Drainage Area 1	4
3.4.2 Drainage Area 2	6
3.5 SUMMARY OF SITE POST-DEVELOPMENT FLOWS	7
3.6 MAJOR OVERLAND DRAINAGE	7
4.0 WATERMAIN.....	7
4.1 DESIGN CRITERIA	7
4.2 AVERAGE, MAXIMUM DAY AND PEAK HOUR DEMANDS	7
4.3 WATER SUPPLY FOR FIRE-FIGHTING	8
4.4 BOUNDARY CONDITIONS AND SUMMARY OF WATERMAIN ANALYSIS RESULTS	8
5.0 EROSION & SEDIMENT CONTROL.....	9
6.0 CONCLUSIONS	10

LIST OF FIGURES

Figure 1 – Key Plan

Figure 2 – Existing Conditions

APPENDICES

Appendix A – Servicing Report Checklist

Appendix B – Sanitary Design Sheet

Appendix C – Stormwater Design Sheets and Roof Drain and ICD Information

Appendix D – Watermain and Fire Demand Information

PLANS

116070-GP – General Plan of Services

116070-GR – Grading Plan

116070-STM – Storm Drainage Area Plan

1.0 INTRODUCTION

The proposed development is located at Preston Square which is a 2.1 hectare (ha) urban mixed-use development located north of Aberdeen Street, between Preston Street and Rochester Street, as shown in **Figure 1 – Key Plan**.

The proposed development will consist of a 30-storey, 228-unit residential tower, located on top of four existing underground parking levels within Preston Square. The proposed tower will connect to the existing 8-storey Adelaide residential building. An additional floor will be added to the existing Adelaide building, which will include 24 units. In addition to the Adelaide building (referred to as Block B), the property also contains three existing commercial towers, referred to as Blocks A, C and D. See **Figure 2 – Existing Conditions** for illustration.

A Stormwater Management and Servicing Brief was previously submitted in support of a Site Plan application for the proposed development in 2016. The concept for the proposed development has since been revised and is presented in this revised report.

1.1 Purpose

This servicing brief addresses the approach to site servicing and stormwater management for the proposed development and is being submitted in support of a site plan control application.

The objective of the site servicing design is to conform to the requirements of the City of Ottawa, to provide suitable sewage outlets and to ensure that a domestic water supply and appropriate fire protection are provided for the proposed development.

Servicing criteria, expected sewage flows and water demands for the proposed development have been established using the City of Ottawa design guidelines for sewer systems and water distribution.

The City of Ottawa Servicing Study Guidelines for Development Applications requires that a Development Servicing Study Checklist be included to confirm that each applicable item is deemed complete and ready for review by City of Ottawa Infrastructure Approvals. A completed checklist is enclosed in **Appendix A**.


2.0 SANITARY SEWER

The proposed development will be serviced by a new 200mm dia. sanitary service that will outlet to an existing 1200mm dia. municipal sewer on Aberdeen Street. This sewer flows west on Aberdeen Street before discharging into the existing 1650mm dia. combined trunk sewer on Preston Street which flows north.

2.1 Design Criteria

The City of Ottawa design criteria were used to calculate the theoretical proposed sanitary flows. The following design criteria were taken from Section 4 – ‘Sanitary Sewer Systems’ of the City of Ottawa Sewer Design Guidelines, incorporating the revisions as per Technical Bulletin ISTB-2018-01.

M:\2016\116070\CAD\Design\Figures\Design Brief\Fig1-Keyplan.dwg, Fig1 Keyplan, Jul 13, 2016 - 3:48pm, mlinton



Engineers, Planners & Landscape Architects

Suite 200, 240 Michael Cowpland Drive
Ottawa, Ontario, Canada K2M 1P6

Telephone (613) 254-9643
Facsimile (613) 254-5867
Website www.novatech-eng.com

KEY PLAN


PROPOSED ADELAIDE TOWER

DATE
NOV 2018

JOB
115090

FIGURE
FIGURE 1

M:\2016\116070\CAD\Design\Figures\Design Brief\Fig2-EXConditions.dwg, 11x17 landscape, Nov 30, 2018 - 8:59am, lbolam



PRESTON STREET

ROCHESTER STREET

BLOCK "D"

BLOCK "C"

BLOCK "A"

BLOCK "B"

"THE ADELAIDE APARTMENTS"

ABERDEEN STREET

NOVATECH

Engineers, Planners & Landscape Architects
Suite 200, 240 Michael Cowpland Drive
Ottawa, Ontario, Canada K2M 1P6

Telephone (613) 254-9643
Facsimile (613) 254-5867
Website www.novatech-eng.com

PRESTON SQUARE

EXISTING CONDITIONS

SCALE N.T.S.

DATE NOV 2018

JOB 116070

FIGURE FIGURE 2

Residential Population Densities

- Residential Units (1-bedroom Apartment): 1.4 people / unit
- Residential Units (2-bedroom Apartment): 2.1 people / unit

Residential Flows

- Average Daily Residential Sewage Flow: 280 L / person / day
- Residential Peaking Factor: Per Harmon Equation
(Max. 4.0, Correction Factor=0.8)

Extraneous Flows

N/A

The proposed development is located within an existing development as described in Section 1.0 above. The proposed sanitary service is solely dedicated to the new Tower. The proposed development will not increase the extraneous flows currently generated by the site and therefore its value has been omitted from the proposed sanitary flow calculations. Therefore, the following sanitary flow calculations represent the net increase in sanitary flows from the site.

2.2 Proposed Sanitary Flows

Table 2.2 details the sanitary design flows for the proposed development.

Table 2.2: Theoretical Sanitary Design Flows for Proposed Development

Building	Use	Unit Count	Design Population (people)	Average Flow (L/s)	Peak Flow (L/s)
New Tower	Residential	216 x 1-bdrm 12 x 2-bdrm	328	1.06	3.54 ¹
1-storey Addition		22 x 1-bdrm 2 x 2-bdrm	35	0.11	0.38 ¹
Total		252 Units	363	1.17	3.92

¹ Excluding extraneous flow.

Based on Manning's Equation, a 200mm dia. sanitary gravity service at a minimum slope of 1.0% has a full flow conveyance capacity of approximately 34.2 L/s, which is sufficient to convey the theoretical sanitary design flows calculated above. Refer to the Sanitary Sewer Design Sheet in **Appendix B** for detailed calculations.

3.0 STORMWATER MANAGEMENT**3.1 Existing Site Stormwater Management**

Stormwater flows from the Preston Square site are currently split into two drainage areas, as described in the *Stormwater Management Report Tower C and Block D City Gate Corporation*, dated October 2005 (R-2005-116) by Novatech, summarized as follows:

- Drainage Area 1 (northern part of the site): Flows are conveyed to the existing 1650mm dia. combined sewer on Preston Street via an on-site 1200mm diameter super pipe. The on-site super pipe utilizes a 250mm diameter orifice at its outlet to control the flows. Flows from the roofs of Buildings A and C are controlled by roof drains.
- Drainage Area 2 (southern part of the site): Flows are conveyed to the existing 1200mm dia. combined sewer on Aberdeen Street. Flows from the roofs of Buildings B (The Adelaide Apartments) and D are controlled by roof drains.

3.2 Stormwater Management Design Criteria and Methodology

The stormwater management criteria and objectives for the site (as per the above referenced 2005 report) are as follows:

- Provide a dual drainage system (i.e. minor and major system flows).
- Control the post-development flows from the site to allowable release rates corresponding to the 5-year and 100-year peak flows using a runoff coefficient of 0.4 and a 20-minute rainfall intensity derived from City of Ottawa IDF curves, as specified by the City of Ottawa. Post-development peak flows will be controlled for storms up to and including the 100-year design event, prior to being released into the municipal combined sewers in Aberdeen Street and Preston Street.
- Provide guidelines to ensure that site preparation and construction is in accordance with the current best management practices for erosion and sediment control.

The stormwater management design for the proposed development is based on the methodology implemented in the above referenced 2005 report.

The Modified Rational Method was used to determine the storage volume(s) required to control the post-development runoff flows to the allowable release rates and to determine the size of the control structure(s).

3.3 Allowable Release Rates

The allowable release rates for the site for the 5-year and the 100-year design events were calculated using the Rational Method and are summarized in **Table 3.3**.

Table 3.3: Allowable Release Rates

Area	Allowable Release Rate (L/s)	
	5-year	100-year
Area 1 (1.304 ha)	101.5 L/s	174.0 L/s
Area 2 (0.802 ha)	62.4 L/s	107.0 L/s
Total (Site)	163.9 L/s	281.0 L/s

Refer to **Appendix C** for detailed calculations.

3.4 Post-Development Site Conditions

The area of the site to be developed will be split between the two drainage areas as shown on attached drawing **116070-STM**. A brief description of the various sub-catchment areas is as follows:

- Drainage Area 1: Runoff from the street-level areas around the exterior of the new Tower will drain uncontrolled via podium drains and catchbasins to the existing 1200mm dia. superpipe. Flows from this superpipe to the combined sewer on Preston Street will continue to be controlled by an orifice at the outlet of the pipe.
- Drainage Area 2: Runoff from the proposed Tower roof (Area B-2) and the new roof on the proposed 9th floor addition to the Adelaide Apartment building (Area B-1) will be controlled by roof drains. There will be 10 roof drains on the new roof of the Adelaide Apartment building and 12 roof drains on the roof of the new Tower. These roof drains will outlet to the combined sewer in Aberdeen Street.

The rest of the site is unchanged.

3.4.1 Drainage Area 1

Controlled Flow from Block A and C Roofs (Area 1-R)

The flows from the roof areas in Area 1 are attenuated by controlled flow roof drains. There are 14 existing roof drains in Area 1 (6 and 8 roof drains for Blocks A and C respectively). The roof drains on average discharge 1.0 L/s, so flows from the roofs of existing buildings A (Area 1-“A”) and C (Area 1-“C”) are controlled to approximately 14 L/s for the 5-year and 100-year design events.

Refer to the *Stormwater Management Report Tower C And Block D City Gate Corporation*, (R-2005-116) dated October 2005 by Novatech for details.

Controlled Surface Flow (Area 1-A)

The flows from surface areas in Area 1 are currently attenuated by a 250mm dia. orifice plug type ICD installed within the 300mm dia. outlet pipe of MH1. Stormwater runoff from this drainage area is temporarily stored in an underground superpipe prior to being discharged into the municipal storm sewer system. Additional storage is available in the existing catchbasins and manholes. **Table 3.4-A** summarizes the existing available storage volumes for Area 1.

Table 3.4-A – Area 1 Available Existing Storage Volumes

Item	Area (m ²)	Depth (m)	Length (m)	Approximate Storage Volume (m ³)
1200mm dia. superpipe	1.17	N/A	99.80	116.8
CB 3 (600mmx600mm)	0.36	= 60.35 - 59.37 = 0.98	N/A	0.4
CB 1 (600mmx600mm)	0.36	= 60.35 - 58.98 = 1.37	N/A	0.5
MH1 (2440mm dia.)	4.67	= 60.35 - 58.50 = 1.85	N/A	8.6

STM 1 (1300mm dia.)	1.32	= 60.35 - 58.46 = 1.89	N/A	2.5
STM 2 (1200mm dia.)	1.13	= 60.35 - 58.65 = 1.70	N/A	1.9
Total				130.7 m³

The design release rate for flows from the surface areas of Area 1 was set to meet the allowable release rate for Area 1, taking into account the existing controlled flows from the roof areas. The Modified Rational Method was used to determine the storage volume required for this catchment area.

Table 3.4-B summarizes the post-development flows and the required storage volumes for runoff from the surface areas for the 5-year and the 100-year design events for Area 1.

Table 3.4-B: Summary of Area 1 Post-Development Flows and Required Storage Volume

Design Event	Roof Areas	Surface Areas			Total Flow for Area 1 (L/s)
	Controlled Flow (L/s)	Uncontrolled Flow (L/s)	Design Release Rate (L/s)	Storage Volume Required (m ³)	
5-year	14	135.6	87.5	69 m ³	101.5
100-year	14	232.5	160.0	112 m ³	174.0

The existing available storage volume is greater than the storage volume required for the 100-year design event, therefore there is adequate existing storage available to meet the required storage volumes for Area 1.

Inlet Control Device (ICD) Sizing

To achieve the design release rate to the combined sewer on Preston Street, a new orifice will need to be installed. This orifice has been sized using the following orifice equation:

$$Q = CA(2gh)^{0.5}$$

Where:

- Q = Discharge (m³/s) = 100-year design release rate (0.160 m³/s)
- C = 0.61 (circular hole)
- h = head required (m) = 1.88m (value chosen for no ponding)
- g = 9.81 m/s²
- A = Area of Orifice (m²)

$$0.160 = 0.61 \cdot A(2 \cdot 9.81 \cdot 1.88)^{0.5}$$

$$\therefore A = 0.0432 \text{ m}^2$$

$$\therefore D = 0.234 \text{ m}$$

To achieve the design release rate to the combined sewer, a new Tempest MHF ICD SQ 234mm orifice will be installed at the connection to the 2440mm diameter manhole. Shop drawing has been attached in **Appendix C**.

3.4.2 Drainage Area 2

Controlled Flow from Block D (Area 2-“D”)

Runoff from the roof of Building D is currently controlled by roof drains. There are 8 existing roof drains on Building D, which will remain. These existing controlled flow roof drains discharge on average 1.0 L/s. Therefore, there is a total controlled flow of approximately 8 L/s for the 5-year and 100-year design events from the roof of Building D.

Controlled Flow from Building B and New Tower (Areas 2-“B1” and 2-“B2”)

The post-development flows from roof areas 2-“B1” (the Adelaide) and 2-“B2” (the new Tower) will be attenuated by the use of controlled flow roof drains. Watts Adjustable Flow Control Roof Drains set at ¼ weir opening exposed are proposed.

A total of ten (10) roof drains are proposed on the Adelaide building and fourteen (14) roof drains are proposed on the new Tower. The controlled release rate, ponding depth, required and maximum storage volumes for both the 5-year and 100-year design events are summarized in the **Table 3.4-C** below.

Table 3.4-C: Areas 2-“B1” and 2-“B2” Controlled Flow Building Roof Drains

Roof Drain ID	Controlled Flow (L/s)		Ponding Depth (m)		Storage Vol. Required (m³)		Max. Storage Available (m³)
	5-year	100-year	5-year	100-year	5-year	100-year	
2-“B1” (RD1 – RD10)	7.9	8.7	0.07-0.11	0.13-0.14	31.7	64.6	74.8
2-“B2” (RD11-RD24)	9.8	11.1	0.05-0.08	0.10-0.14	2.5	7.4	8.9

Refer to **Appendix C** for Modified Rational Method calculations and Watts adjustable flow control roof drain information.

Uncontrolled Surface Flow (Area 2-A)

The post-development flows from the surface areas of Area 2 will remain uncontrolled. **Table 3.4-D** summarizes the post-development flows for Area 2.

Table 3.4-D: Summary of Area 2 Post-Development Flows

Design Event	Roof Areas	Surface Areas	Total Flow for Area 2 (L/s)	
	Controlled Flow (L/s)	Uncontrolled Flow (L/s)		
5-year	25.7 L/s	33.9 L/s	59.6 L/s	< Allowable Rate of 62.4 L/s
100-year	27.8 L/s	58.1 L/s	85.9	< Allowable Rate of 107.0 L/s

3.5 Summary of Site Post-Development Flows

Table 3.5 summarizes the total post-development flows from the site.

Table 3.5: Site Post-Development Stormwater Flows

Area	Post-Development Flows (L/s)	
	5-year	100-year
1	101.5	174.0
2	59.6	85.9
Total Site	161.1 L/s	259.9 L/s
	< 163.9 L/s Site Allowable Release Rate	< 281.0 L/s Site Allowable Release Rate

As the 100-year total site post-development stormwater flow is less than the 100-year site allowable release rate to the municipal combined sewer system, there is remaining capacity for the net increase of approximately 3.9 L/s in peak sanitary flow from the proposed development.

3.6 Major Overland Drainage

The site was originally designed to direct major overland drainage flows in excess of the 100-year event flow overland towards Preston and Aberdeen Street. The proposed development will maintain the existing overland flow patterns.

4.0 WATERMAIN

The proposed development will be serviced with twin 150 mm dia. PVC DR 18 services that will connect to the existing 200mm dia. watermain on Aberdeen Street.

4.1 Design Criteria

The City of Ottawa design criteria were used to calculate the theoretical water demands for the proposed development. The following design criteria were taken from Section 4 of the Ottawa Design Guidelines – Water Distribution:

Residential

- Residential Units (1-bedroom apartment): 1.4 people / unit
- Residential Units (2-bedroom apartment): 2.1 people / unit
- Average Day Demand Residential: 350 L / person / day
- Residential Maximum Day Demand: 2.5 x Avg. Day Demand
- Residential Peak Hour Demand: 2.2 x Max Day Demand

4.2 Average, Maximum Day and Peak Hour Demands

The theoretical water demands for the proposed development are given in **Table 4.2**, based on the design criteria above.

Table 4.2: Theoretical Design Water Demands for Proposed Development

Building	Use	Average Water Demand (L/s)	Maximum Day Demand (L/s)	Peak Hour Demand (L/s)
New Tower	Residential	1.33	3.32	7.31
1-storey Addition		0.14	0.35	0.78
Total		1.47 L/s	3.68 L/s	8.09 L/s

Refer to **Appendix D** for detailed calculations.

4.3 Water Supply for Fire-Fighting

The Fire Underwriters Survey (FUS) was used to estimate fire flow requirements for the proposed Tower. In the absence of detailed architectural information, some assumptions were made regarding the building construction. A fire-resistive construction was assumed due to the large size and type of occupancy for the proposed building. Also, the proposed Tower will be fully sprinklered and supplied with a fire department siamese connection(s), located within 45m of the existing on-site fire hydrant adjacent to Tower A.

The fire flow requirements include both sprinkler system and hose allowances in accordance with the OBC and NFPA 13. The sprinkler system will be designed by the fire protection (sprinkler) contractor at the detailed design stage as this process involves detailed hydraulic calculations based on building layout, pipe runs, head losses, fire pump requirements, etc. Booster pumps will be required to provide adequate service pressure on the upper floors.

It should be noted that fire flow requirements calculated using the FUS method tend to generate higher values when compared to flows being calculated using the OBC and NFPA.

In the previous 2016 version of this report, the fire flow required for the proposed Tower was calculated using OBC to be 550 US gpm, or 35 L/s. Since then the building design has been updated.

The calculated fire flow demand for the updated proposed Tower using FUS is 67 L/s (4,000 L/min). Refer to **Appendix D** for detailed FUS calculations.

4.4 Boundary Conditions and Summary of Watermain Analysis Results

Preliminary water demands and fire flow requirements for the proposed development were provided to the City of Ottawa in 2016. These values were used to generate the municipal watermain network boundary conditions. **Table 4.4-A** summarizes the boundary conditions provided by the City of Ottawa for the existing municipal watermain network.

Table 4.4-A: Hydraulic Boundary Condition Provided by the City

Municipal Watermain Boundary Condition	Aberdeen St Watermain
Minimum HGL	106.1 m
Maximum HGL	117.5 m
Max Day + Fire Flow	104.2 m

Refer to **Appendix D** for a copy of the previous correspondence from the City of Ottawa.

Table 4.4-B summarizes the theoretical water demands for the Tower under the various operating conditions and compares the anticipated operating pressures at the watermain to the normal operating pressures outlined in the City of Ottawa Design Guidelines. It is assumed that hydraulic losses in the 150mm water services are negligible. Furthermore, the proposed Tower will be equipped with booster pumps to increase pressure for the upper floors.

Table 4.4-B: Water Analysis Results Summary

Condition	Water Service Connection Location	Total Water Demand (L/s)	Approximate Design Operating Pressures (psi) / Relative Head (m) ¹	Normal Municipal Operating Pressures (psi)
Average Demand	Aberdeen Street	1.33	85 psi (60.05 m)	50-70 psi
Max Day + Fire Flow Demand		70.33	66 psi (46.75 m)	20 psi (Min.)
Peak Hour Demand		7.33	69 psi (48.65 m)	40-70 psi

1 - Assuming top of watermain elevation to be 57.45 m

As the approximate design operating pressure for the Average Demand condition is higher than the normal municipal operating pressure range, a pressure check will be completed at completion of construction to determine if pressure control is required.

As indicated in the summary table above, the existing watermain in Aberdeen Street should have sufficient water supply for the proposed Tower.

5.0 Erosion & Sediment Control

To mitigate erosion and to prevent sediment from entering the storm sewer system, temporary erosion and sediment control measures will be implemented on-site during construction in accordance with the Best Management Practices for Erosion and Sediment Control. This includes the following temporary measures:

- Filter bags will be placed under the grates of nearby catchbasins, manholes and will remain in place until construction is completed.
- Silt fencing will be placed per OPSS 577 and OPSD 219.110 along the surrounding construction limits, where applicable.
- Mud mats will be installed at the site entrances.
- Street sweeping and cleaning will be performed, as required, to suppress dust and to provide safe and clean roadways adjacent to the construction site.
- On-site dewatering is to be directed to a sediment trap and/or gravel splash pad and discharged safely to an approved outlet as directed by the engineer.

The temporary erosion and sediment control measures will be implemented prior to construction and will remain in place during all phases of construction. Regular inspection and maintenance of the erosion control measures will be undertaken.

6.0 CONCLUSIONS

This report has been prepared in support of a site plan control application for the proposed development at Preston Square. The proposed development will consist of a new 30-storey residential Tower and the addition of a single storey to the existing 8-storey Adelaide Apartments residential building.

The conclusions are as follows:

- The proposed development will include a total of ± 252 residential units.
- The new residential Tower will be serviced by extending new services to the municipal watermain and combined sewer in Aberdeen Street.
- On-site stormwater quantity control will be provided by using controlled roof drains and the existing stormwater management infrastructure, which includes controlled outlets. The existing inlet control device will be adapted. A new 234mm dia. orifice plug type ICD will be installed at the Preston Street stormwater outlet to the combined municipal sewer.
- As total combined stormwater and sanitary flows to the municipal combined sewer system will meet the allowable site flows, the municipal combined sewers in the adjacent streets are estimated to have adequate capacity to accommodate the proposed development.
- The proposed Tower will be sprinklered and supplied with a fire department Siamese connection. The Siamese connection will be located within 45m of an existing private fire hydrant in Preston Square. Based on hydraulic boundary conditions provided by the City of Ottawa, the existing municipal water system has adequate capacity to accommodate the proposed development.
- On-site stormwater quality control is not required, nor being provided.
- Temporary erosion and sediment controls will be provided during construction.

It is recommended that this Stormwater Management and Servicing Brief be approved for implementation.

NOVATECH

Prepared by:



Lydia Bolam, B.Eng.
E.I.T.

Reviewed By:



Greg MacDonald, P.Eng.
Director, Land Development and Public
Sector Infrastructure

APPENDIX A

Development Servicing Study Checklist

Development Servicing Study Checklist

4.1 General Content	Addressed (Y/N/NA)	Section	Comments
Executive Summary (for larger reports only).	NA		
Date and revision number of the report.	Y	Cover	
Location map and plan showing municipal address, boundary, and layout of proposed development.	Y		Figure 1 & Dwgs.
Plan showing the site and location of all existing services.	Y		Dwg. 116070-GP
Development statistics, land use, density, adherence to zoning and official plan, and reference to applicable subwatershed and watershed plans that provide context to which individual developments must adhere.	Y	1.0	
Summary of Pre-consultation Meetings with City and other approval agencies.	N/A		
Reference and confirm conformance to higher level studies and reports (Master Servicing Studies, Environmental Assessments, Community Design Plans), or in the case where it is not in conformance, the proponent must provide justification and develop a defensible design criteria.	Y	1.1	
Statement of objectives and servicing criteria.	Y	1.1	
Identification of existing and proposed infrastructure available in the immediate area.	Y	2.0 - 4.0	Dwg. 116070-GP
Identification of Environmentally Significant Areas, watercourses and Municipal Drains potentially impacted by the proposed development (Reference can be made to the Natural Heritage Studies, if available).	N/A		
Concept level master grading plan to confirm existing and proposed grades in the development. This is required to confirm the feasibility of proposed stormwater management and drainage, soil removal and fill constraints, and potential impacts to neighboring properties. This is also required to confirm that the proposed grading will not impede existing major system flow paths.	Y		Dwg. 116070-GR

Development Servicing Study Checklist

4.1 General Content	Addressed (Y/N/NA)	Section	Comments
Identification of potential impacts of proposed piped services on private services (such as wells and septic fields on adjacent lands) and mitigation required to address potential impacts.	N/A		
Proposed phasing of the development, if applicable.	N/A		
Reference to geotechnical studies and recommendations concerning servicing.	N/A		
All preliminary and formal site plan submissions should have the following information:	Y		
Metric scale	Y		
North arrow (including construction North)	Y		
Key plan	Y		
Name and contact information of applicant and property owner	Y		
Property limits including bearings and dimensions	Y		
Existing and proposed structures and parking areas	Y		
Easements, road widening and rights-of-way	Y		
Adjacent street names	Y		

Development Servicing Study Checklist

4.2 Water	Addressed (Y/N/NA)	Section	Comments
Confirm consistency with Master Servicing Study, if available.	N/A		
Availability of public infrastructure to service proposed development.	Y		
Identification of system constraints.	Y	4.0	
Identify boundary conditions.	Y	4.0	
Confirmation of adequate domestic supply and pressure.	Y	4.0	
Confirmation of adequate fire flow protection and confirmation that fire flow is calculated as per the Fire Underwriter's Survey. Output should show available fire flow at locations throughout the development.	Y	4.0	
Provide a check of high pressures. If pressure is found to be high, an assessment is required to confirm the application of pressure reducing valves.	Y	4.0	
Definition of phasing constraints. Hydraulic modeling is required to confirm servicing for all defined phases of the project including the ultimate design.	N/A		
Address reliability requirements such as appropriate location of shut-off valves.	N		Detailed Design Requirement
Check on the necessity of a pressure zone boundary modification.	N/A		
Reference to water supply analysis to show that major infrastructure is capable of delivering sufficient water for the proposed land use. This includes data that shows that the expected demands under average day, peak hour and fire flow conditions provide water within the required pressure range.	N		Fire Demand Checked Only
Description of the proposed water distribution network, including locations of proposed connections to the existing system, provisions for necessary looping, and appurtenances (valves, pressure reducing valves, valve chambers, and fire hydrants) including special metering provisions.	Y	4.0	
Description of off-site required feeder mains, booster pumping stations, and other water infrastructure that will be ultimately required to service proposed development, including financing, interim facilities, and timing of implementation.	N/A		
Confirmation that water demands are calculated based on the City of Ottawa Design Guidelines.	Y	4.0	
Provision of a model schematic showing the boundary conditions locations, streets, parcels, and building locations for reference.	N		

Development Servicing Study Checklist

4.3 Wastewater	Addressed (Y/N/NA)	Section	Comments
Summary of proposed design criteria (Note: Wet-weather flow criteria should not deviate from the City of Ottawa Sewer Design Guidelines. Monitored flow data from relatively new infrastructure cannot be used to justify capacity requirements for proposed	Y	2.0	
Confirm consistency with Master Servicing Study and/or justifications for deviations.	N/A		
Consideration of local conditions that may contribute to extraneous flows that are higher than the recommended flows in the guidelines. This includes groundwater and soil conditions, and age and condition of sewers.	N/A		
Description of existing sanitary sewer available for discharge of wastewater from proposed development.	Y	2.0	
Verify available capacity in downstream sanitary sewer and/or identification of upgrades necessary to service the proposed development. (Reference can be made to previously completed Master Servicing Study if applicable)	Y	2.0	
Calculations related to dry-weather and wet-weather flow rates from the development in standard MOE sanitary sewer design table (Appendix 'C') format.	N/A		
Description of proposed sewer network including sewers, pumping stations, and forcemains.	Y	2.0	Dwg. 116070-GP
Discussion of previously identified environmental constraints and impact on servicing (environmental constraints are related to limitations imposed on the development in order to preserve the physical condition of watercourses, vegetation, soil cover, as well as protecting against water quantity and quality).	N/A		
Pumping stations: impacts of proposed development on existing pumping stations or requirements for new pumping station to service development.	N/A		
Forcemain capacity in terms of operational redundancy, surge pressure and maximum flow velocity.	N/A		
Identification and implementation of the emergency overflow from sanitary pumping stations in relation to the hydraulic grade line to protect against basement flooding.	N/A		
Special considerations such as contamination, corrosive environment etc.	N/A		

Development Servicing Study Checklist

4.4 Stormwater	Addressed (Y/N/NA)	Section	Comments
Description of drainage outlets and downstream constraints including legality of outlet (i.e. municipal drain, right-of-way, watercourse, or private property).	Y	3.0	
Analysis of the available capacity in existing public infrastructure.	Y	3.0	
A drawing showing the subject lands, its surroundings, the receiving watercourse, existing drainage patterns and proposed drainage patterns.	Y		116070-STM
Water quantity control objective (e.g. controlling post-development peak flows to pre-development level for storm events ranging from the 2 or 5 year event (dependent on the receiving sewer design) to 100 year return period); if other objectives are being applied, a rationale must be included with reference to hydrologic analyses of the potentially affected subwatersheds, taking into account long-term cumulative effects.	Y	3.0	
Water Quality control objective (basic, normal or enhanced level of protection based on the sensitivities of the receiving watercourse) and storage requirements.	Y	3.0	
Description of stormwater management concept with facility locations and descriptions with references and supporting information.	Y	3.0	
Set-back from private sewage disposal systems.	N/A		
Watercourse and hazard lands setbacks.	N/A		
Record of pre-consultation with the Ontario Ministry of Environment and the Conservation Authority that has jurisdiction on the affected watershed.	N/A		
Confirm consistency with sub-watershed and Master Servicing Study, if applicable study exists.	N/A		
Storage requirements (complete with calcs) and conveyance capacity for minor (5 yr) and major (100 yr) events.	Y	3.0	
Identification of watercourse within the proposed development and how watercourses will be protected, or, if necessary, altered by the proposed development with applicable approvals.	N/A		
Calculate pre and post development peak flow rates including a description of existing site conditions and proposed impervious areas and drainage catchments in comparison to existing conditions.	Y	3.0	
Any proposed diversion of drainage catchment areas from one outlet to another.	N/A		

Development Servicing Study Checklist

4.4 Stormwater	Addressed (Y/N/NA)	Section	Comments
Proposed minor and major systems including locations and sizes of stormwater trunk sewers, and SWM	Y	3.0	Dwgs. 116070-GP, -GR and - STM
If quantity control is not proposed, demonstration that downstream system has adequate capacity for the post-development flows up to and including the 100-year return period storm event.	Y	3.0	
Identification of potential impacts to receiving watercourses.	N/A		
Identification of municipal drains and related approval requirements.	N/A		
Description of how the conveyance and storage capacity will be achieved for the development.	Y	3.0	
100 year flood levels and major flow routing to protect proposed development from flooding for establishing minimum building elevations (MBE) and overall grading.	Y	3.0	100 Year HGL not available
Inclusion of hydraulic analysis including HGL elevations.	N		
Description of approach to erosion and sediment control during construction for the protection of receiving watercourse or drainage corridors.	Y	5.0	
Identification of floodplains – proponent to obtain relevant floodplain information from the appropriate Conservation Authority. The proponent may be required to delineate floodplain elevations to the satisfaction of the Conservation Authority if such information is not available or if information does not match current conditions.	N/A		
Identification of fill constraints related to floodplain and geotechnical investigation.	N/A		

Development Servicing Study Checklist

4.5 Approval and Permit Requirements	Addressed (Y/N/NA)	Section	Comments
Conservation Authority as the designated approval agency for modification of floodplain, potential impact on fish habitat, proposed works in or adjacent to a watercourse, cut/fill permits and Approval under Lakes and Rivers Improvement Act. The Conservation Authority is not the approval authority for the Lakes and Rivers Improvement Act. Where there are Conservation Authority regulations in place, approval under the Lakes and Rivers Improvement Act is not required, except in cases of dams as defined in the Act.	N/A		
Application for Certificate of Approval (CofA) under the Ontario Water Resources Act.	N		
Changes to Municipal Drains.	N		
Other permits (National Capital Commission, Parks Canada, Public Works and Government Services Canada, Ministry of Transportation etc.)	N/A		

4.6 Conclusion	Addressed (Y/N/NA)	Section	Comments
Clearly stated conclusions and recommendations.	Y	6.0	
Comments received from review agencies including the City of Ottawa and information on how the comments were addressed. Final sign-off from the responsible reviewing agency.	N/A		
All draft and final reports shall be signed and stamped by a professional Engineer registered in Ontario.	Y		

APPENDIX B
Sanitary Design Sheet

LOCATION			RESIDENTIAL FLOW						EXTRANEOUS FLOW		TOTAL FLOWS		
Area ID	Use		Number of Units		Design Population	Avg Flow	Peak Factor	Res. Peak Flow	Infiltration Allowance		Average Dry Weather Flow (ADWF)	Peak Dry Weather Flow (PDWF)	Peak Wet Weather Flow (PWWW)
		Total Area	1-bdrm	2-bdrm					Dry Weather (l/l dry)	Wet Weather (l/l wet)			
		(ha)	-	-	(persons)	(l/s)	-	(l/s)	(l/s)	(l/s)	(l/s)	(l/s)	(l/s)
THEORETICAL POST-DEVELOPMENT													
Existing Building	Residential	N/A	79	79	277	0.90	3.33	2.99			0.90	2.99	2.99
New 1-storey addition	Residential	N/A	22	2	35	0.11	3.33	0.38			0.11	0.38	0.38
Subtotal			101	81	312	1.01	3.33	3.37			1.01	3.37	3.37
New Tower	Residential	N/A	216	12	328	1.06	3.33	3.54			1.06	3.54	3.54
Total			317	93	640	2.07	3.33	6.91			2.07	6.91	6.91
Design Parameters:									Designed: LGB Checked: GJM				
Residential Population Densities													
1-bedroom Apartment		1.40	people / unit										
2-bedroom Apartment		2.10	people / unit										
Average Sanitary Flows													
Residential		280	L/c/d										
Peak Extraneous Flows									Date: January 16, 2019				
N/A - Refer to SWM and Servicing brief													
Peaking Factors		Harmon Equation, K=0.8											
Residential													

APPENDIX C

Stormwater Design Sheets and Roof Drain and ICD Information

Post - Development : Uncontrolled Site Flows									
Area	Description	A (ha)	A imp (ha) C=0.9	A grav (ha) C=0.6	A perv (ha) C=0.2	C _s	C ₁₀₀	Uncontrolled Flow (L/s)	
								5 year	100 year
1-R	Controlled roof drains - Buildings C and A	0.240	0.240	0	0	0.90	0.90	42.0	72.1
1-A	Surface runoff	1.064	0.692	0	0.3724	0.66	0.66	135.6	232.5
	Sub-Total	1.304	0.932	0.00	0.37	0.70	0.70	177.7	304.6
2-D	Controlled roof drains - Building D	0.322	0.322	0	0	0.90	0.90	56.4	96.7
2-B1	Controlled roof drains - Adelaide Building (B1)	0.198	0.198	0	0	0.90	0.90	34.6	59.3
2-B2	Controlled roof drains - New Tower (B2)	0.072	0.072	0	0	0.90	0.90	12.5	21.5
2-R	<i>Sub-total: (Area 2 roof areas)</i>	<i>0.591</i>	<i>0.591</i>	<i>0</i>	<i>0</i>	<i>0.90</i>	<i>0.90</i>	<i>103.5</i>	<i>177.4</i>
2-A	Surface runoff	0.211	0.189	0	0.0225	0.83	0.83	33.9	58.1
	Sub-Total	0.802	1.371	0.00	0.02	1.54	1.54	137.4	235.5

Post - Development : Total Flows for Controlled Site						
Area	Description	Flow (L/s)		Storage Required (m³)		Provided (m³)
		5 year	100 year	5 year	100 year	
1-R	Controlled roof drains - Buildings C and A	14.0	14.0	33.9	74.7	Assume >75
1-A	Surface runoff	87.5	160.0	68.6	111.6	
	Sub-Total (Area 1)	101.5	174.0	102.5	186.3	186.6
2-D	Controlled roof drains - Building D	8.0	8.0	Refer to 'Tower C and Block D' SWM Report		
2-B1	Controlled roof drains - Adelaide Building (B1)	7.9	8.7	31.7	64.6	74.8
2-B2	Controlled roof drains - New Tower (B2)	9.8	11.1	2.5	7.4	8.9
2-R	<i>Sub-Total (Area 2 roof areas)</i>	25.7	27.8	34.3	71.9	83.7
2-A	Surface runoff	33.9	58.1	-	-	-
	Sub-Total (Area 2)	59.6	85.9	34.3	71.9	83.7
	TOTAL (SITE - AREA 1 + AREA 2)	161.1	259.9			

ADELAIDE TOWER EXPANSION					
PROJECT NO: 116070					
REQUIRED STORAGE - 1:5 YEAR EVENT					
AREA 1-A Controlled Flow-Surface Area					
OTTAWA IDF CURVE					
Area = 1.064 ha		Qallow = 87.5 L/s			
C = 0.66		Vol(max) = 68.6 m3			
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)	
5	141.18	273.52	186.02	55.81	
10	104.19	201.87	114.37	68.62	
15	83.56	161.89	74.39	66.95	
20	70.25	136.11	48.61	58.33	
25	60.90	117.98	30.48	45.72	
30	53.93	104.48	16.98	30.57	
35	48.52	94.00	6.50	13.65	
40	44.18	85.60	-1.90	-4.55	
45	40.63	78.72	-8.78	-23.72	
50	37.65	72.95	-14.55	-43.65	
55	35.12	68.05	-19.45	-64.19	
60	32.94	63.83	-23.67	-85.23	
65	31.04	60.15	-27.35	-106.68	
70	29.37	56.91	-30.59	-128.49	
75	27.89	54.03	-33.47	-150.61	
90	24.29	47.06	-40.44	-218.39	
105	21.58	41.81	-45.69	-287.82	
120	19.47	37.72	-49.78	-358.44	
135	17.76	34.42	-53.08	-429.96	
150	16.36	31.70	-55.80	-502.20	

ADELAIDE TOWER EXPANSION					
PROJECT NO: 116070					
REQUIRED STORAGE - 1:100 YEAR EVENT					
AREA 1-A Controlled Flow-Surface Area					
OTTAWA IDF CURVE					
Area = 1.064 ha		Qallow = 160.0 L/s			
C = 0.66		Vol(max) = 111.6 m3			
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)	
5	242.70	470.22	310.23	93.07	
10	178.56	345.95	185.96	111.57	
15	142.89	276.85	116.86	105.17	
20	119.95	232.40	72.41	86.89	
25	103.85	201.20	41.21	61.81	
30	91.87	177.99	18.00	32.40	
35	82.58	159.99	0.00	0.00	
40	75.15	145.59	-14.40	-34.56	
45	69.05	133.78	-26.21	-70.76	
50	63.95	123.91	-36.08	-108.25	
55	59.62	115.52	-44.47	-146.76	
60	55.89	108.29	-51.70	-186.11	
65	52.65	102.00	-57.99	-226.16	
70	49.79	96.46	-63.53	-266.81	
75	47.26	91.55	-68.44	-307.96	
90	41.11	79.65	-80.34	-433.84	
105	36.50	70.71	-89.28	-562.45	
120	32.89	63.73	-96.26	-693.06	
135	30.00	58.12	-101.87	-825.17	
150	27.61	53.49	-106.50	-958.46	

Structures	Size (mm)	Area (m²)	T/G	Inv IN	Inv OUT
STM MH2	1200	1.13	60.50	58.65	58.65
STM MH1	1300	1.33	60.50	58.46	58.46
MH1	2440	4.68	60.65	58.55	58.50
CB 1	600 x 600	0.36	60.50	58.98	58.98
CB 3	600 x 600	0.36	60.50	59.37	59.37

PI = 3.14159265
pipe I.D.= 1220 (1200 nominal)
U/G Pipe Volume
End Area 1.169 (m²)
Total Length 99.8 (m)
Pipe Volume 116.7 (m³)

U/G Pipe Size	1200MM
Pipe Segment	
Centre-Centre Length	
Inside Structure	1.2
U/G Storage Length	99.8

Area A-1: Storage Table													
Elevation (m)	System Head (m)	Underground Storage							Surface Storage				Total Storage
		STM MH2 Volume (m³)	STM MH1 Volume (m³)	MH1 Volume (m³)	CB 1 Volume (m³)	CB 3 Volume (m³)	1200mm dia. Pipe Storage (m³)	Total U/G Volume (m³)					Volume (m³)
58.46													0.0
58.50	-0.15		0.00				0.00	0.00					0.0
58.65	0.00		0.25	0.70			26.95	27.52					27.5
58.98	0.33	0.37	0.69	2.24	0.00		45.91	49.08					49.1
59.00	0.35	0.40	0.72	2.34	0.01		51.90	55.22					55.2
59.37	0.72	0.81	1.21	4.07	0.14	0.00	59.88	66.11					66.1
59.50	0.85	0.96	1.38	4.68	0.19	0.05	116.66	123.92					123.9
59.75	1.10	1.24	1.71	5.84	0.28	0.14	116.66	125.88					125.9
60.00	1.35	1.53	2.04	7.01	0.37	0.23	116.66	127.84					127.8
60.25	1.60	1.81	2.38	8.18	0.46	0.32	116.66	129.81					129.8
60.50	1.85	2.09	2.71	9.35	0.55	0.41	116.66	131.77					131.8

Inlet Control Device - Circular Plug
1:100 Yr
Flow (L/s) = 160.0
Head (m) = 1.85
Elevation (m) = 60.35
Outlet Pipe Dia.(mm) = 300
Volume (m3) = 111.6
1:5 Yr
Flow (L/s) = 87.5
Head (m) = 0.55
Elevation (m) = 59.05
Outlet Pipe Dia.(mm) = 300
Volume (m3) = 68.6

Maximum Ponding Depth (cm)
1:100 Yr
0
1:5 Yr
0

Orifice Size - 1:100 yr Flow Check
Q=0.62xAx(2gh) ^{0.5}
1:100 yr Flow Check
Q (m³/s) = 0.1600 0.1606
g (m/s²) = 9.81 9.81
h (m) = 1.85 1.85
A (m²) = 0.042831746 0.04301
D (m) = 0.233527457 0.23400
D (mm) = 234 234.0

1:5 yr Flow Check
1:5 yr
Q (m³/s) = 0.0876
g (m/s²) = 9.81
h (m) = 0.55
A (m²) = 0.04301
D (m) = 0.234
D (mm) = 234

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 1-R Controlled Roof Drains				
OTTAWA IDF CURVE				
Area =	0.240	ha	Qallow =	14.00 L/s
C =	0.90		Vol(max) =	33.9 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	84.77	70.77	21.23
10	104.19	62.57	48.57	29.14
15	83.56	50.17	36.17	32.56
20	70.25	42.18	28.18	33.82
25	60.90	36.57	22.57	33.85
30	53.93	32.38	18.38	33.09
35	48.52	29.13	15.13	31.78
40	44.18	26.53	12.53	30.08
45	40.63	24.40	10.40	28.07
50	37.65	22.61	8.61	25.83
55	35.12	21.09	7.09	23.40
60	32.94	19.78	5.78	20.81
65	31.04	18.64	4.64	18.10
70	29.37	17.64	3.64	15.28
75	27.89	16.75	2.75	12.36
90	24.29	14.58	0.58	3.16
105	21.58	12.96	-1.04	-6.55
120	19.47	11.69	-2.31	-16.63

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 1-R Controlled Roof Drains				
OTTAWA IDF CURVE				
Area =	0.240	ha	Qallow =	14.00 L/s
C =	0.90		Vol(max) =	74.7 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	145.74	131.74	39.52
10	178.56	107.22	93.22	55.93
15	142.89	85.81	71.81	64.62
20	119.95	72.03	58.03	69.63
25	103.85	62.36	48.36	72.54
30	91.87	55.17	41.17	74.10
35	82.58	49.59	35.59	74.73
40	75.15	45.12	31.12	74.70
45	69.05	41.46	27.46	74.15
50	63.95	38.40	24.40	73.21
55	59.62	35.80	21.80	71.95
60	55.89	33.56	19.56	70.43
65	52.65	31.61	17.61	68.69
70	49.79	29.90	15.90	66.77
75	47.26	28.38	14.38	64.69
90	41.11	24.69	10.69	57.71
105	36.50	21.92	7.92	49.87
120	32.89	19.75	5.75	41.42

Watts Accutrol Flow Control Roof Drains:		RD-100-A-ADJ set to 1/4 Exposed			
Design Event	Flow/Drain (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m ³) Required	Storage (m ³) Provided
1:5 Year	1.00	14.00	10	33.9	39.0
1:100 Year	1.00	14.00	15	74.7	126.0

Roof Drain Storage Table for AVERAGE RD		
Elevation	Area RD 1	Total Volume
m	m ²	m ³
0.00	0	0
0.05	17	0.4
0.10	77	2.8
0.15	171	9.0


APPROXIMATE ONLY

ADELAIDE TOWER EXPANSION					
116070					
REQUIRED STORAGE - 1:5 YEAR EVENT					
AREA 2-R		Controlled Roof Drain			#1
OTTAWA IDF CURVE					
Area = 0.023 ha		Qallow = 0.80 L/s			
C = 0.90		Vol(max) = 4.3 m3			
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)	
5	141.18	8.29	7.49	2.25	
10	104.19	6.12	5.32	3.19	
15	83.56	4.91	4.11	3.70	
20	70.25	4.13	3.33	3.99	
25	60.90	3.58	2.78	4.16	
30	53.93	3.17	2.37	4.26	
35	48.52	2.85	2.05	4.30	
40	44.18	2.59	1.79	4.31	
45	40.63	2.39	1.59	4.28	
50	37.65	2.21	1.41	4.23	
55	35.12	2.06	1.26	4.17	
60	32.94	1.93	1.13	4.08	
65	31.04	1.82	1.02	3.99	
70	29.37	1.72	0.92	3.88	
75	27.89	1.64	0.84	3.77	
90	24.29	1.43	0.63	3.38	
105	21.58	1.27	0.47	2.94	
120	19.47	1.14	0.34	2.47	

ADELAIDE TOWER EXPANSION					
116070					
REQUIRED STORAGE - 1:100 YEAR EVENT					
AREA 2-R		Controlled Roof Drain			#1
OTTAWA IDF CURVE					
Area = 0.023 ha		Qallow = 0.87		L/s	
C = 0.90		Vol(max) = 8.7		m3	
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)	
5	242.70	14.25	13.38	4.01	
10	178.56	10.49	9.62	5.77	
15	142.89	8.39	7.52	6.77	
20	119.95	7.04	6.17	7.41	
25	103.85	6.10	5.23	7.84	
30	91.87	5.39	4.52	8.14	
35	82.58	4.85	3.98	8.36	
40	75.15	4.41	3.54	8.50	
45	69.05	4.05	3.18	8.60	
50	63.95	3.76	2.89	8.66	
55	59.62	3.50	2.63	8.68	
60	55.89	3.28	2.41	8.68	
65	52.65	3.09	2.22	8.66	
70	49.79	2.92	2.05	8.63	
75	47.26	2.77	1.90	8.57	
90	41.11	2.41	1.54	8.34	
105	36.50	2.14	1.27	8.02	
120	32.89	1.93	1.06	7.64	

Watts Accutrol Flow Control Roof Drains:			RD-100-A-ADJ set to 1/4 Exposed		
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³)	
				Required	Provided
1:5 Year	0.80	0.80	10.6	4.3	4.5
1:100 Year	0.87	0.87	13.0	8.7	8.8

Roof Drain Storage Table for RD #1		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	25.5	0.6
0.10	95.1	3.7
0.15	234.7	11.9




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 2		
OTTAWA IDF CURVE				
Area =	0.022	ha	Qallow =	0.80 L/s
C =	0.90		Vol(max) =	3.9 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	7.69	6.89	2.07
10	104.19	5.68	4.88	2.93
15	83.56	4.55	3.75	3.38
20	70.25	3.83	3.03	3.63
25	60.90	3.32	2.52	3.78
30	53.93	2.94	2.14	3.85
35	48.52	2.64	1.84	3.87
40	44.18	2.41	1.61	3.86
45	40.63	2.21	1.41	3.82
50	37.65	2.05	1.25	3.75
55	35.12	1.91	1.11	3.67
60	32.94	1.79	0.99	3.58
65	31.04	1.69	0.89	3.47
70	29.37	1.60	0.80	3.36
75	27.89	1.52	0.72	3.24
90	24.29	1.32	0.52	2.82
105	21.58	1.18	0.38	2.37
120	19.47	1.06	0.26	1.87

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 2		
OTTAWA IDF CURVE				
Area =	0.022	ha	Gallow =	0.87 L/s
C =	0.90		Vol(max) =	7.8 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	13.22	12.35	3.70
10	178.56	9.73	8.86	5.31
15	142.89	7.78	6.91	6.22
20	119.95	6.53	5.66	6.80
25	103.85	5.66	4.79	7.18
30	91.87	5.00	4.13	7.44
35	82.58	4.50	3.63	7.62
40	75.15	4.09	3.22	7.74
45	69.05	3.76	2.89	7.81
50	63.95	3.48	2.61	7.84
55	59.62	3.25	2.38	7.85
60	55.89	3.04	2.17	7.83
65	52.65	2.87	2.00	7.79
70	49.79	2.71	1.84	7.74
75	47.26	2.57	1.70	7.67
90	41.11	2.24	1.37	7.39
105	36.50	1.99	1.12	7.04
120	32.89	1.79	0.92	6.64

Watts Accutrol Flow Control Roof Drains:			RD-100-A-ADJ set to 1/4 Exposed		
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³)	
				Required	Provided
1:5 Year	0.80	0.80	10.6	3.9	4.3
1:100 Year	0.87	0.87	13.0	7.8	8.4

Roof Drain Storage Table for RD # 2		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	24	0.6
0.10	95.9	3.6
0.15	217.7	11.4




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 3		
OTTAWA IDF CURVE				
Area =	0.027	ha	Qallow =	0.80 L/s
C =	0.90		Vol(max) =	5.2 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	9.43	8.63	2.59
10	104.19	6.96	6.16	3.70
15	83.56	5.58	4.78	4.30
20	70.25	4.69	3.89	4.67
25	60.90	4.07	3.27	4.90
30	53.93	3.60	2.80	5.04
35	48.52	3.24	2.44	5.13
40	44.18	2.95	2.15	5.16
45	40.63	2.71	1.91	5.17
50	37.65	2.52	1.72	5.15
55	35.12	2.35	1.55	5.10
60	32.94	2.20	1.40	5.04
65	31.04	2.07	1.27	4.97
70	29.37	1.96	1.16	4.88
75	27.89	1.86	1.06	4.78
90	24.29	1.62	0.82	4.44
105	21.58	1.44	0.64	4.04
120	19.47	1.30	0.50	3.60

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 3		
OTTAWA IDF CURVE				
Area =	0.027	ha	Qallow =	0.88 L/s
C =	0.90		Vol(max) =	10.3 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	16.21	15.33	4.60
10	178.56	11.93	11.05	6.63
15	142.89	9.55	8.67	7.80
20	119.95	8.01	7.13	8.56
25	103.85	6.94	6.06	9.09
30	91.87	6.14	5.26	9.46
35	82.58	5.52	4.64	9.74
40	75.15	5.02	4.14	9.94
45	69.05	4.61	3.73	10.08
50	63.95	4.27	3.39	10.18
55	59.62	3.98	3.10	10.24
60	55.89	3.73	2.85	10.27
65	52.65	3.52	2.64	10.28
70	49.79	3.33	2.45	10.27
75	47.26	3.16	2.28	10.25
90	41.11	2.75	1.87	10.08
105	36.50	2.44	1.56	9.82
120	32.89	2.20	1.32	9.49

Watts Accutrol Flow Control Roof Drains:			RD-100-A-ADJ set to 1/4 Exposed		
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³)	
				Required	Provided
1:5 Year	0.80	0.80	10.6	5.2	5.2
1:100 Year	0.88	0.88	13.1	10.3	10.4

Roof Drain Storage Table for RD # 3		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	29.3	0.7
0.10	117.4	4.4
0.15	267	14.0




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 4		
OTTAWA IDF CURVE				
Area =	0.018	ha	Qallow =	0.79 L/s
C =	0.90		Vol(max) =	3.0 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	6.44	5.65	1.70
10	104.19	4.76	3.97	2.38
15	83.56	3.81	3.02	2.72
20	70.25	3.21	2.42	2.90
25	60.90	2.78	1.99	2.98
30	53.93	2.46	1.67	3.01
35	48.52	2.21	1.42	2.99
40	44.18	2.02	1.23	2.94
45	40.63	1.85	1.06	2.87
50	37.65	1.72	0.93	2.79
55	35.12	1.60	0.81	2.68
60	32.94	1.50	0.71	2.57
65	31.04	1.42	0.63	2.44
70	29.37	1.34	0.55	2.31
75	27.89	1.27	0.48	2.17
90	24.29	1.11	0.32	1.72
105	21.58	0.98	0.19	1.23
120	19.47	0.89	0.10	0.71

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 4		
OTTAWA IDF CURVE				
Area =	0.018	ha	Qallow =	0.87 L/s
C =	0.90		Vol(max) =	6.2 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	11.08	10.21	3.06
10	178.56	8.15	7.28	4.37
15	142.89	6.52	5.65	5.09
20	119.95	5.47	4.60	5.52
25	103.85	4.74	3.87	5.80
30	91.87	4.19	3.32	5.98
35	82.58	3.77	2.90	6.09
40	75.15	3.43	2.56	6.14
45	69.05	3.15	2.28	6.16
50	63.95	2.92	2.05	6.15
55	59.62	2.72	1.85	6.11
60	55.89	2.55	1.68	6.05
65	52.65	2.40	1.53	5.98
70	49.79	2.27	1.40	5.89
75	47.26	2.16	1.29	5.79
90	41.11	1.88	1.01	5.43
105	36.50	1.67	0.80	5.01
120	32.89	1.50	0.63	4.54

Watts Accutrol Flow Control Roof Drains:				RD-100-A-ADJ set to 1/4 Exposed	
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³)	
				Required	Provided
1:5 Year	0.79	0.79	10.2	3.0	3.0
1:100 Year	0.87	0.87	13.8	6.2	8.0

Roof Drain Storage Table for RD # 4		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	19.2	0.5
0.10	76.7	2.9
0.15	182.4	9.4




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 5		
OTTAWA IDF CURVE				
Area =	0.007	ha	Qallow =	0.79 L/s
C =	0.90		Vol(max) =	0.7 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	2.59	1.80	0.54
10	104.19	1.91	1.12	0.67
15	83.56	1.53	0.74	0.67
20	70.25	1.29	0.50	0.60
25	60.90	1.12	0.33	0.49
30	53.93	0.99	0.20	0.36
35	48.52	0.89	0.10	0.21
40	44.18	0.81	0.02	0.05
45	40.63	0.75	-0.04	-0.12
50	37.65	0.69	-0.10	-0.30
55	35.12	0.64	-0.15	-0.48
60	32.94	0.60	-0.19	-0.67
65	31.04	0.57	-0.22	-0.86
70	29.37	0.54	-0.25	-1.06
75	27.89	0.51	-0.28	-1.25
90	24.29	0.45	-0.34	-1.86
105	21.58	0.40	-0.39	-2.48
120	19.47	0.36	-0.43	-3.12

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 5		
OTTAWA IDF CURVE				
Area =	0.007	ha	Qallow =	0.87 L/s
C =	0.90		Vol(max) =	1.6 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	4.45	3.58	1.07
10	178.56	3.27	2.40	1.44
15	142.89	2.62	1.75	1.58
20	119.95	2.20	1.33	1.60
25	103.85	1.90	1.03	1.55
30	91.87	1.68	0.81	1.47
35	82.58	1.51	0.64	1.35
40	75.15	1.38	0.51	1.22
45	69.05	1.27	0.40	1.07
50	63.95	1.17	0.30	0.91
55	59.62	1.09	0.22	0.74
60	55.89	1.03	0.16	0.56
65	52.65	0.97	0.10	0.37
70	49.79	0.91	0.04	0.18
75	47.26	0.87	0.00	-0.02
90	41.11	0.75	-0.12	-0.63
105	36.50	0.67	-0.20	-1.26
120	32.89	0.60	-0.27	-1.92

Watts Accutrol Flow Control Roof Drains:			RD-100-A-ADJ set to 1/4 Exposed		
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³)	
				Required	Provided
1:5 Year	0.79	0.79	10.2	0.7	1.1
1:100 Year	0.87	0.87	12.7	1.6	2.5

Roof Drain Storage Table for RD # 5		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	7.3	0.2
0.10	29.4	1.1
0.15	73.3	3.7




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 6		
OTTAWA IDF CURVE				
Area =	0.010	ha	Qallow =	0.79 L/s
C =	0.90		Vol(max) =	1.1 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	3.41	2.62	0.79
10	104.19	2.52	1.73	1.04
15	83.56	2.02	1.23	1.11
20	70.25	1.70	0.91	1.09
25	60.90	1.47	0.68	1.02
30	53.93	1.30	0.51	0.92
35	48.52	1.17	0.38	0.80
40	44.18	1.07	0.28	0.67
45	40.63	0.98	0.19	0.52
50	37.65	0.91	0.12	0.36
55	35.12	0.85	0.06	0.19
60	32.94	0.80	0.01	0.02
65	31.04	0.75	-0.04	-0.15
70	29.37	0.71	-0.08	-0.34
75	27.89	0.67	-0.12	-0.52
90	24.29	0.59	-0.20	-1.10
105	21.58	0.52	-0.27	-1.69
120	19.47	0.47	-0.32	-2.30

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 6		
OTTAWA IDF CURVE				
Area =	0.010	ha	Qallow =	0.87 L/s
C =	0.90		Vol(max) =	2.5 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	5.87	5.00	1.50
10	178.56	4.32	3.45	2.07
15	142.89	3.45	2.58	2.33
20	119.95	2.90	2.03	2.43
25	103.85	2.51	1.64	2.46
30	91.87	2.22	1.35	2.43
35	82.58	2.00	1.13	2.36
40	75.15	1.82	0.95	2.27
45	69.05	1.67	0.80	2.16
50	63.95	1.55	0.68	2.03
55	59.62	1.44	0.57	1.88
60	55.89	1.35	0.48	1.73
65	52.65	1.27	0.40	1.57
70	49.79	1.20	0.33	1.40
75	47.26	1.14	0.27	1.22
90	41.11	0.99	0.12	0.67
105	36.50	0.88	0.01	0.08
120	32.89	0.80	-0.07	-0.54

Watts Accutrol Flow Control Roof Drains:			RD-100-A-ADJ set to 1/4 Exposed		
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³)	
				Required	Provided
1:5 Year	0.79	0.79	10.2	1.1	1.4
1:100 Year	0.87	0.87	12.7	2.5	3.1

Roof Drain Storage Table for RD # 6		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	8.6	0.2
0.10	34.3	1.3
0.15	96.6	4.6




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 7		
OTTAWA IDF CURVE				
Area =	0.005	ha	Qallow =	0.71 L/s
C =	0.90		Vol(max) =	0.3 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	1.72	1.01	0.30
10	104.19	1.27	0.56	0.34
15	83.56	1.02	0.31	0.28
20	70.25	0.86	0.15	0.18
25	60.90	0.74	0.03	0.05
30	53.93	0.66	-0.05	-0.10
35	48.52	0.59	-0.12	-0.25
40	44.18	0.54	-0.17	-0.41
45	40.63	0.50	-0.21	-0.58
50	37.65	0.46	-0.25	-0.75
55	35.12	0.43	-0.28	-0.93
60	32.94	0.40	-0.31	-1.11
65	31.04	0.38	-0.33	-1.29
70	29.37	0.36	-0.35	-1.48
75	27.89	0.34	-0.37	-1.67
90	24.29	0.30	-0.41	-2.24
105	21.58	0.26	-0.45	-2.82
120	19.47	0.24	-0.47	-3.40

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 7		
OTTAWA IDF CURVE				
Area =	0.005	ha	Qallow =	0.87 L/s
C =	0.90		Vol(max) =	0.8 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	2.96	2.09	0.63
10	178.56	2.18	1.31	0.78
15	142.89	1.74	0.87	0.78
20	119.95	1.46	0.59	0.71
25	103.85	1.27	0.40	0.59
30	91.87	1.12	0.25	0.45
35	82.58	1.01	0.14	0.29
40	75.15	0.92	0.05	0.11
45	69.05	0.84	-0.03	-0.08
50	63.95	0.78	-0.09	-0.27
55	59.62	0.73	-0.14	-0.47
60	55.89	0.68	-0.19	-0.68
65	52.65	0.64	-0.23	-0.89
70	49.79	0.61	-0.26	-1.11
75	47.26	0.58	-0.29	-1.32
90	41.11	0.50	-0.37	-1.99
105	36.50	0.44	-0.43	-2.68
120	32.89	0.40	-0.47	-3.38

Watts Accutrol Flow Control Roof Drains:			RD-100-A-ADJ set to 1/4 Exposed		
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³)	
				Required	Provided
1:5 Year	0.71	0.71	7.6	0.3	0.4
1:100 Year	0.87	0.87	12.7	0.8	1.8

Roof Drain Storage Table for RD # 7		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	5.4	0.1
0.10	21.7	0.8
0.15	48.7	2.6




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 8		
OTTAWA IDF CURVE				
Area =	0.027	ha	Qallow =	0.82 L/s
C =	0.90		Vol(max) =	5.2 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	9.49	8.67	2.60
10	104.19	7.01	6.19	3.71
15	83.56	5.62	4.80	4.32
20	70.25	4.72	3.90	4.69
25	60.90	4.10	3.28	4.91
30	53.93	3.63	2.81	5.05
35	48.52	3.26	2.44	5.13
40	44.18	2.97	2.15	5.16
45	40.63	2.73	1.91	5.16
50	37.65	2.53	1.71	5.14
55	35.12	2.36	1.54	5.09
60	32.94	2.22	1.40	5.02
65	31.04	2.09	1.27	4.94
70	29.37	1.98	1.16	4.85
75	27.89	1.88	1.06	4.75
90	24.29	1.63	0.81	4.39
105	21.58	1.45	0.63	3.98
120	19.47	1.31	0.49	3.52

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 8		
OTTAWA IDF CURVE				
Area =	0.027	ha	Qallow =	0.87 L/s
C =	0.90		Vol(max) =	10.4 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	16.32	15.45	4.64
10	178.56	12.01	11.14	6.68
15	142.89	9.61	8.74	7.87
20	119.95	8.07	7.20	8.64
25	103.85	6.98	6.11	9.17
30	91.87	6.18	5.31	9.56
35	82.58	5.55	4.68	9.84
40	75.15	5.05	4.18	10.04
45	69.05	4.64	3.77	10.19
50	63.95	4.30	3.43	10.29
55	59.62	4.01	3.14	10.36
60	55.89	3.76	2.89	10.40
65	52.65	3.54	2.67	10.42
70	49.79	3.35	2.48	10.41
75	47.26	3.18	2.31	10.39
90	41.11	2.76	1.89	10.23
105	36.50	2.45	1.58	9.98
120	32.89	2.21	1.34	9.66

Watts Accutrol Flow Control Roof Drains:			RD-100-A-ADJ set to 1/4 Exposed		
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³)	
				Required	Provided
1:5 Year	0.82	0.82	11.0	5.2	6.3
1:100 Year	0.87	0.87	13.8	10.4	12.3

Roof Drain Storage Table for RD # 8		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	30.6	0.8
0.10	122.5	4.6
0.15	268.8	14.4

Stage Storage Curve:
Controlled Roof Drain




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 9		
OTTAWA IDF CURVE				
Area =	0.022	ha	Qallow =	0.80 L/s
C =	0.90		Vol(max) =	3.9 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	7.77	6.97	2.09
10	104.19	5.74	4.94	2.96
15	83.56	4.60	3.80	3.42
20	70.25	3.87	3.07	3.68
25	60.90	3.35	2.55	3.83
30	53.93	2.97	2.17	3.91
35	48.52	2.67	1.87	3.93
40	44.18	2.43	1.63	3.92
45	40.63	2.24	1.44	3.88
50	37.65	2.07	1.27	3.82
55	35.12	1.93	1.13	3.74
60	32.94	1.81	1.01	3.65
65	31.04	1.71	0.91	3.55
70	29.37	1.62	0.82	3.43
75	27.89	1.54	0.74	3.31
90	24.29	1.34	0.54	2.90
105	21.58	1.19	0.39	2.45
120	19.47	1.07	0.27	1.96

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain # 9		
OTTAWA IDF CURVE				
Area =	0.022	ha	Qallow =	0.87 L/s
C =	0.90		Vol(max) =	8.0 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	13.37	12.50	3.75
10	178.56	9.83	8.96	5.38
15	142.89	7.87	7.00	6.30
20	119.95	6.61	5.74	6.88
25	103.85	5.72	4.85	7.27
30	91.87	5.06	4.19	7.54
35	82.58	4.55	3.68	7.72
40	75.15	4.14	3.27	7.84
45	69.05	3.80	2.93	7.92
50	63.95	3.52	2.65	7.96
55	59.62	3.28	2.41	7.96
60	55.89	3.08	2.21	7.95
65	52.65	2.90	2.03	7.91
70	49.79	2.74	1.87	7.86
75	47.26	2.60	1.73	7.80
90	41.11	2.26	1.39	7.53
105	36.50	2.01	1.14	7.18
120	32.89	1.81	0.94	6.78

Watts Accutrol Flow Control Roof Drains:				RD-100-A-ADJ set to 1/4 Exposed	
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³)	
				Required	Provided
1:5 Year	0.80	0.80	10.5	3.9	3.9
1:100 Year	0.87	0.87	13.8	8.0	9.7

Roof Drain Storage Table for RD # 9		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	23.7	0.6
0.10	95	3.6
0.15	220.1	11.4

Stage Storage Curve:
Controlled Roof Drain




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		10
OTTAWA IDF CURVE				
Area =	0.023	ha	Qallow =	0.81 L/s
C =	0.90		Vol(max) =	4.2 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	8.15	7.34	2.20
10	104.19	6.01	5.20	3.12
15	83.56	4.82	4.01	3.61
20	70.25	4.05	3.24	3.89
25	60.90	3.51	2.70	4.06
30	53.93	3.11	2.30	4.14
35	48.52	2.80	1.99	4.18
40	44.18	2.55	1.74	4.18
45	40.63	2.35	1.54	4.14
50	37.65	2.17	1.36	4.09
55	35.12	2.03	1.22	4.02
60	32.94	1.90	1.09	3.93
65	31.04	1.79	0.98	3.83
70	29.37	1.70	0.89	3.72
75	27.89	1.61	0.80	3.60
90	24.29	1.40	0.59	3.20
105	21.58	1.25	0.44	2.75
120	19.47	1.12	0.31	2.26

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		10
OTTAWA IDF CURVE				
Area =	0.023	ha	Gallow =	0.90 L/s
C =	0.90		Vol(max) =	8.4 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	14.01	13.11	3.93
10	178.56	10.31	9.41	5.64
15	142.89	8.25	7.35	6.61
20	119.95	6.92	6.02	7.23
25	103.85	5.99	5.09	7.64
30	91.87	5.30	4.40	7.92
35	82.58	4.77	3.87	8.12
40	75.15	4.34	3.44	8.25
45	69.05	3.99	3.09	8.33
50	63.95	3.69	2.79	8.37
55	59.62	3.44	2.54	8.39
60	55.89	3.23	2.33	8.37
65	52.65	3.04	2.14	8.34
70	49.79	2.87	1.97	8.29
75	47.26	2.73	1.83	8.22
90	41.11	2.37	1.47	7.95
105	36.50	2.11	1.21	7.60
120	32.89	1.90	1.00	7.19

Watts Accutrol Flow Control Roof Drains:			RD-100-A-ADJ set to 1/4 Exposed		
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³)	
				Required	Provided
1:5 Year	0.81	0.81	11.0	4.2	4.8
1:100 Year	0.90	0.90	13.8	8.4	9.8

Roof Drain Storage Table for RD # 10		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	24.9	0.6
0.10	91.5	3.5
0.15	230.7	11.6




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		11+12
OTTAWA IDF CURVE				
Area =	0.004	ha	Qallow =	0.71 L/s
C =	0.90		Vol(max) =	0.2 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	1.48	0.77	0.23
10	104.19	1.09	0.38	0.23
15	83.56	0.87	0.16	0.15
20	70.25	0.73	0.02	0.03
25	60.90	0.64	-0.07	-0.11
30	53.93	0.56	-0.15	-0.26
35	48.52	0.51	-0.20	-0.43
40	44.18	0.46	-0.25	-0.59
45	40.63	0.42	-0.29	-0.77
50	37.65	0.39	-0.32	-0.95
55	35.12	0.37	-0.34	-1.13
60	32.94	0.34	-0.37	-1.32
65	31.04	0.32	-0.39	-1.50
70	29.37	0.31	-0.40	-1.69
75	27.89	0.29	-0.42	-1.88
90	24.29	0.25	-0.46	-2.46
105	21.58	0.23	-0.48	-3.05
120	19.47	0.20	-0.51	-3.65

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		11+12
OTTAWA IDF CURVE				
Area =	0.004	ha	Qallow =	0.79 L/s
C =	0.90		Vol(max) =	0.6 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	2.54	1.75	0.52
10	178.56	1.87	1.08	0.65
15	142.89	1.49	0.70	0.63
20	119.95	1.25	0.46	0.56
25	103.85	1.09	0.30	0.44
30	91.87	0.96	0.17	0.31
35	82.58	0.86	0.07	0.15
40	75.15	0.79	0.00	-0.01
45	69.05	0.72	-0.07	-0.18
50	63.95	0.67	-0.12	-0.36
55	59.62	0.62	-0.17	-0.55
60	55.89	0.58	-0.21	-0.74
65	52.65	0.55	-0.24	-0.93
70	49.79	0.52	-0.27	-1.13
75	47.26	0.49	-0.30	-1.33
90	41.11	0.43	-0.36	-1.94
105	36.50	0.38	-0.41	-2.57
120	32.89	0.34	-0.45	-3.21

Watts Accutrol Flow Control Roof Drains:				RD-100-A-ADJ set to 1/4 Exposed	
Design Event	Flow per RD (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m ³)	
				Required	Provided
1:5 Year	0.71	1.42	7.6	0.7	0.9
1:100 Year	0.79	1.58	10.2	1.9	2.1

Roof Drain Storage Table for RD # 11+12		
Elevation	Area	Total Volume
m	m ²	m ³
0.00	0	0
0.05	4.6	0.1
0.10	18.5	0.7
0.15	41.8	2.2




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		13,15,17
OTTAWA IDF CURVE				
Area =	0.003	ha	Qallow =	0.71 L/s
C =	0.90		Vol(max) =	0.1 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	1.19	0.48	0.14
10	104.19	0.88	0.17	0.10
15	83.56	0.70	-0.01	0.00
20	70.25	0.59	-0.12	-0.14
25	60.90	0.51	-0.20	-0.29
30	53.93	0.45	-0.26	-0.46
35	48.52	0.41	-0.30	-0.63
40	44.18	0.37	-0.34	-0.81
45	40.63	0.34	-0.37	-0.99
50	37.65	0.32	-0.39	-1.18
55	35.12	0.30	-0.41	-1.37
60	32.94	0.28	-0.43	-1.56
65	31.04	0.26	-0.45	-1.75
70	29.37	0.25	-0.46	-1.94
75	27.89	0.24	-0.47	-2.14
90	24.29	0.20	-0.51	-2.73
105	21.58	0.18	-0.53	-3.33
120	19.47	0.16	-0.55	-3.93

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		13,15,17
OTTAWA IDF CURVE				
Area =	0.003	ha	Qallow =	0.79 L/s
C =	0.90		Vol(max) =	0.4 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	2.05	1.26	0.38
10	178.56	1.51	0.72	0.43
15	142.89	1.20	0.41	0.37
20	119.95	1.01	0.22	0.27
25	103.85	0.88	0.09	0.13
30	91.87	0.77	-0.02	-0.03
35	82.58	0.70	-0.09	-0.20
40	75.15	0.63	-0.16	-0.38
45	69.05	0.58	-0.21	-0.56
50	63.95	0.54	-0.25	-0.75
55	59.62	0.50	-0.29	-0.95
60	55.89	0.47	-0.32	-1.15
65	52.65	0.44	-0.35	-1.35
70	49.79	0.42	-0.37	-1.55
75	47.26	0.40	-0.39	-1.76
90	41.11	0.35	-0.44	-2.39
105	36.50	0.31	-0.48	-3.04
120	32.89	0.28	-0.51	-3.69

Watts Accutrol Flow Control Roof Drains:				RD-100-A-ADJ set to 1/4 Exposed	
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³) Required	Provided
1:5 Year	0.71	2.13	7.6	0.4	0.8
1:100 Year	0.79	2.37	10.2	1.3	1.7

Roof Drain Storage Table for RD # 13,15,17		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	3.8	0.1
0.10	15	0.6
0.15	33.7	1.8




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		14,16,18
OTTAWA IDF CURVE				
Area =	0.003	ha	Qallow =	0.71 L/s
C =	0.90		Vol(max) =	0.1 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	1.20	0.49	0.15
10	104.19	0.89	0.18	0.11
15	83.56	0.71	0.00	0.00
20	70.25	0.60	-0.11	-0.13
25	60.90	0.52	-0.19	-0.29
30	53.93	0.46	-0.25	-0.45
35	48.52	0.41	-0.30	-0.62
40	44.18	0.38	-0.33	-0.80
45	40.63	0.35	-0.36	-0.98
50	37.65	0.32	-0.39	-1.17
55	35.12	0.30	-0.41	-1.35
60	32.94	0.28	-0.43	-1.54
65	31.04	0.26	-0.45	-1.74
70	29.37	0.25	-0.46	-1.93
75	27.89	0.24	-0.47	-2.12
90	24.29	0.21	-0.50	-2.71
105	21.58	0.18	-0.53	-3.31
120	19.47	0.17	-0.54	-3.92

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		14,16,18
OTTAWA IDF CURVE				
Area =	0.003	ha	Qallow =	0.79 L/s
C =	0.90		Vol(max) =	0.4 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	2.07	1.28	0.38
10	178.56	1.52	0.73	0.44
15	142.89	1.22	0.43	0.39
20	119.95	1.02	0.23	0.28
25	103.85	0.89	0.10	0.14
30	91.87	0.78	-0.01	-0.01
35	82.58	0.70	-0.09	-0.18
40	75.15	0.64	-0.15	-0.36
45	69.05	0.59	-0.20	-0.54
50	63.95	0.55	-0.24	-0.73
55	59.62	0.51	-0.28	-0.93
60	55.89	0.48	-0.31	-1.13
65	52.65	0.45	-0.34	-1.33
70	49.79	0.42	-0.37	-1.53
75	47.26	0.40	-0.39	-1.74
90	41.11	0.35	-0.44	-2.37
105	36.50	0.31	-0.48	-3.02
120	32.89	0.28	-0.51	-3.67

Watts Accutrol Flow Control Roof Drains:			RD-100-A-ADJ set to 1/4 Exposed		
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³)	
				Required	Provided
1:5 Year	0.71	2.13	7.6	0.4	0.8
1:100 Year	0.79	2.37	10.2	1.3	1.7

Roof Drain Storage Table for RD # 14,16,18		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	3.7	0.1
0.10	14.9	0.6
0.15	34.1	1.8




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		19+20
OTTAWA IDF CURVE				
Area =	0.004	ha	Qallow =	0.71 L/s
C =	0.90		Vol(max) =	0.2 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	1.46	0.75	0.22
10	104.19	1.07	0.36	0.22
15	83.56	0.86	0.15	0.14
20	70.25	0.72	0.01	0.02
25	60.90	0.63	-0.08	-0.12
30	53.93	0.56	-0.15	-0.28
35	48.52	0.50	-0.21	-0.44
40	44.18	0.46	-0.25	-0.61
45	40.63	0.42	-0.29	-0.79
50	37.65	0.39	-0.32	-0.97
55	35.12	0.36	-0.35	-1.15
60	32.94	0.34	-0.37	-1.33
65	31.04	0.32	-0.39	-1.52
70	29.37	0.30	-0.41	-1.71
75	27.89	0.29	-0.42	-1.90
90	24.29	0.25	-0.46	-2.48
105	21.58	0.22	-0.49	-3.07
120	19.47	0.20	-0.51	-3.67

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		19+20
OTTAWA IDF CURVE				
Area =	0.004	ha	Qallow =	0.79 L/s
C =	0.90		Vol(max) =	0.6 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	2.50	1.71	0.51
10	178.56	1.84	1.05	0.63
15	142.89	1.47	0.68	0.61
20	119.95	1.24	0.45	0.54
25	103.85	1.07	0.28	0.42
30	91.87	0.95	0.16	0.28
35	82.58	0.85	0.06	0.13
40	75.15	0.77	-0.02	-0.04
45	69.05	0.71	-0.08	-0.21
50	63.95	0.66	-0.13	-0.39
55	59.62	0.61	-0.18	-0.58
60	55.89	0.58	-0.21	-0.77
65	52.65	0.54	-0.25	-0.96
70	49.79	0.51	-0.28	-1.16
75	47.26	0.49	-0.30	-1.36
90	41.11	0.42	-0.37	-1.98
105	36.50	0.38	-0.41	-2.61
120	32.89	0.34	-0.45	-3.25

Watts Accutrol Flow Control Roof Drains:				RD-100-A-ADJ set to 1/4 Exposed	
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m ³) Required	Storage (m ³) Provided
1:5 Year	0.71	1.42	7.6	0.4	0.6
1:100 Year	0.79	1.58	10.2	1.3	1.4

Roof Drain Storage Table for RD # 19+20		
Elevation	Area	Total Volume
m	m ²	m ³
0.00	0	0
0.05	4.5	0.1
0.10	18.2	0.7
0.15	41.2	2.2




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		21
OTTAWA IDF CURVE				
Area =	0.002	ha	Qallow =	0.63 L/s
C =	0.90		Vol(max) =	0.0 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	0.76	0.13	0.04
10	104.19	0.56	-0.07	-0.04
15	83.56	0.45	-0.18	-0.16
20	70.25	0.38	-0.25	-0.30
25	60.90	0.33	-0.30	-0.46
30	53.93	0.29	-0.34	-0.61
35	48.52	0.26	-0.37	-0.78
40	44.18	0.24	-0.39	-0.94
45	40.63	0.22	-0.41	-1.11
50	37.65	0.20	-0.43	-1.29
55	35.12	0.19	-0.44	-1.46
60	32.94	0.18	-0.45	-1.63
65	31.04	0.17	-0.46	-1.81
70	29.37	0.16	-0.47	-1.99
75	27.89	0.15	-0.48	-2.16
90	24.29	0.13	-0.50	-2.70
105	21.58	0.12	-0.51	-3.24
120	19.47	0.10	-0.53	-3.79

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		21
OTTAWA IDF CURVE				
Area =	0.002	ha	Gallow =	0.79 L/s
C =	0.90		Vol(max) =	0.2 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	1.30	0.51	0.15
10	178.56	0.96	0.17	0.10
15	142.89	0.77	-0.02	-0.02
20	119.95	0.64	-0.15	-0.18
25	103.85	0.56	-0.23	-0.35
30	91.87	0.49	-0.30	-0.54
35	82.58	0.44	-0.35	-0.73
40	75.15	0.40	-0.39	-0.93
45	69.05	0.37	-0.42	-1.13
50	63.95	0.34	-0.45	-1.34
55	59.62	0.32	-0.47	-1.55
60	55.89	0.30	-0.49	-1.77
65	52.65	0.28	-0.51	-1.98
70	49.79	0.27	-0.52	-2.20
75	47.26	0.25	-0.54	-2.42
90	41.11	0.22	-0.57	-3.08
105	36.50	0.20	-0.59	-3.75
120	32.89	0.18	-0.61	-4.42

Watts Accutrol Flow Control Roof Drains:			RD-100-A-ADJ set to 1/4 Exposed		
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³)	
				Required	Provided
1:5 Year	0.63	0.63	5.1	0.04	0.05
1:100 Year	0.79	0.79	10.2	0.2	0.4

Roof Drain Storage Table for RD # 21		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	2.3	0.1
0.10	9.3	0.3
0.15	21.4	1.1




ADELAIDE TOWER EXPANSION					
116070					
REQUIRED STORAGE - 1:5 YEAR EVENT					
AREA 2-R		Controlled Roof Drain #			22
OTTAWA IDF CURVE					
Area =	0.002	ha	Qallow =	0.63	L/s
C =	0.90		Vol(max) =	0.1	m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)	
5	141.18	0.86	0.23	0.07	
10	104.19	0.63	0.00	0.00	
15	83.56	0.51	-0.12	-0.11	
20	70.25	0.43	-0.20	-0.24	
25	60.90	0.37	-0.26	-0.39	
30	53.93	0.33	-0.30	-0.54	
35	48.52	0.29	-0.34	-0.70	
40	44.18	0.27	-0.36	-0.87	
45	40.63	0.25	-0.38	-1.03	
50	37.65	0.23	-0.40	-1.20	
55	35.12	0.21	-0.42	-1.37	
60	32.94	0.20	-0.43	-1.55	
65	31.04	0.19	-0.44	-1.72	
70	29.37	0.18	-0.45	-1.90	
75	27.89	0.17	-0.46	-2.07	
90	24.29	0.15	-0.48	-2.60	
105	21.58	0.13	-0.50	-3.14	
120	19.47	0.12	-0.51	-3.68	

ADELAIDE TOWER EXPANSION					
116070					
REQUIRED STORAGE - 1:100 YEAR EVENT					
AREA 2-R		Controlled Roof Drain #			22
OTTAWA IDF CURVE					
Area =	0.002	ha	Gallow =	0.79	L/s
C =	0.90		Vol(max) =	0.2	m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)	
5	242.70	1.48	0.69	0.21	
10	178.56	1.09	0.30	0.18	
15	142.89	0.87	0.08	0.07	
20	119.95	0.73	-0.06	-0.07	
25	103.85	0.63	-0.16	-0.24	
30	91.87	0.56	-0.23	-0.42	
35	82.58	0.50	-0.29	-0.60	
40	75.15	0.46	-0.33	-0.80	
45	69.05	0.42	-0.37	-1.00	
50	63.95	0.39	-0.40	-1.20	
55	59.62	0.36	-0.43	-1.41	
60	55.89	0.34	-0.45	-1.62	
65	52.65	0.32	-0.47	-1.83	
70	49.79	0.30	-0.49	-2.05	
75	47.26	0.29	-0.50	-2.26	
90	41.11	0.25	-0.54	-2.92	
105	36.50	0.22	-0.57	-3.58	
120	32.89	0.20	-0.59	-4.25	

Watts Accutrol Flow Control Roof Drains:			RD-100-A-ADJ set to 1/4 Exposed		
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m³)	
				Required	Provided
1:5 Year	0.63	0.63	5.1	0.07	0.07
1:100 Year	0.79	0.79	10.2	0.2	0.4

Roof Drain Storage Table for RD # 22		
Elevation	Area	Total Volume
m	m²	m³
0.00	0	0
0.05	2.7	0.1
0.10	10.8	0.4
0.15	24.3	1.3




ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:5 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		23+24
OTTAWA IDF CURVE				
Area =	0.004	ha	Qallow =	0.71 L/s
C =	0.90		Vol(max) =	0.2 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	141.18	1.42	0.71	0.21
10	104.19	1.05	0.34	0.20
15	83.56	0.84	0.13	0.12
20	70.25	0.70	-0.01	-0.01
25	60.90	0.61	-0.10	-0.15
30	53.93	0.54	-0.17	-0.30
35	48.52	0.49	-0.22	-0.47
40	44.18	0.44	-0.27	-0.64
45	40.63	0.41	-0.30	-0.82
50	37.65	0.38	-0.33	-1.00
55	35.12	0.35	-0.36	-1.18
60	32.94	0.33	-0.38	-1.37
65	31.04	0.31	-0.40	-1.55
70	29.37	0.29	-0.42	-1.74
75	27.89	0.28	-0.43	-1.94
90	24.29	0.24	-0.47	-2.52
105	21.58	0.22	-0.49	-3.11
120	19.47	0.20	-0.51	-3.71

ADELAIDE TOWER EXPANSION				
116070				
REQUIRED STORAGE - 1:100 YEAR EVENT				
AREA 2-R		Controlled Roof Drain #		23+24
OTTAWA IDF CURVE				
Area =	0.004	ha	Qallow =	0.79 L/s
C =	0.90		Vol(max) =	0.6 m3
Time (min)	Intensity (mm/hr)	Q (L/s)	Qnet (L/s)	Vol (m3)
5	242.70	2.44	1.65	0.49
10	178.56	1.79	1.00	0.60
15	142.89	1.43	0.64	0.58
20	119.95	1.20	0.41	0.50
25	103.85	1.04	0.25	0.38
30	91.87	0.92	0.13	0.24
35	82.58	0.83	0.04	0.08
40	75.15	0.75	-0.04	-0.09
45	69.05	0.69	-0.10	-0.26
50	63.95	0.64	-0.15	-0.45
55	59.62	0.60	-0.19	-0.63
60	55.89	0.56	-0.23	-0.83
65	52.65	0.53	-0.26	-1.02
70	49.79	0.50	-0.29	-1.22
75	47.26	0.47	-0.32	-1.42
90	41.11	0.41	-0.38	-2.04
105	36.50	0.37	-0.42	-2.67
120	32.89	0.33	-0.46	-3.31

Watts Accutrol Flow Control Roof Drains:				RD-100-A-ADJ set to 1/4 Exposed	
Design Event	Flow (L/s)	Total Flow (L/s)	Ponding (cm)	Storage (m ³) Required	Storage (m ³) Provided
1:5 Year	0.71	1.42	7.6	0.4	0.6
1:100 Year	0.79	1.58	10.2	1.2	1.3

Roof Drain Storage Table for RD # 23+24		
Elevation	Area	Total Volume
m	m ²	m ³
0.00	0	0
0.05	4.4	0.1
0.10	17.2	0.7
0.15	40.1	2.1





Adjustable Accutrol Weir

Tag: _____

Adjustable Flow Control for Roof Drains

ADJUSTABLE ACCUTROL (for Large Sump Roof Drains only)



For more flexibility in controlling flow with heads deeper than 2", Watts Drainage offers the Adjustable Accutrol. The Adjustable Accutrol Weir is designed with a single parabolic opening that can be covered to restrict flow above 2" of head to less than 5 gpm per inch, up to 6" of head. To adjust the flow rate for depths over 2" of head, set the slot in the adjustable upper cone according to the flow rate required. Refer to Table 1 below.

Note: Flow rates are directly proportional to the amount of weir opening that is exposed.

EXAMPLE:

For example, if the adjustable upper cone is set to cover 1/2 of the weir opening, flow rates above 2" of head will be restricted to 2-1/2 gpm per inch of head.

Therefore, at 3" of head, the flow rate through the Accutrol Weir that has 1/2 the slot exposed will be:
[5 gpm (per inch of head) x 2 inches of head] + 2-1/2 gpm (for the third inch of head) = 12-1/2 gpm.



1/2 Weir Opening Exposed Shown Above

TABLE 1. Adjustable Accutrol Flow Rate Settings

Weir Opening Exposed	1"	2"	3"	4"	5"	6"
	Flow Rate (gallons per minute)					
Fully Exposed	5	10	15	20	25	30
3/4	5	10	13.75	17.5	21.25	25
1/2	5	10	12.5	15	17.5	20
1/4	5	10	11.25	12.5	13.75	15
Closed	5	5	5	5	5	5

Job Name _____

Contractor _____

Job Location _____

Contractor's P.O. No. _____

Engineer _____

Representative _____





Watts product specifications in U.S. customary units and metric are approximate and are provided for reference only. For precise measurements, please contact Watts Technical Service. Watts reserves the right to change or modify product design, construction, specifications, or materials without prior notice and without incurring any obligation to make such changes and modifications on Watts products previously or subsequently sold.

USA: Tel: (800) 338-2581 • Fax: (828) 248-3929 • Watts.com
Canada: Tel: (905) 332-4090 • Fax: (905) 332-7068 • Watts.ca
Latin America: Tel: (52) 81-1001-8600 • Fax: (52) 81-8000-7091 • Watts.com



A Watts Water Technologies Company

Tempest MHF ICD SQ Shop Drawing



SECTION A-A



IPEX TECHNOLOGIES INC. 10000 Highway 100, Suite 100 Dallas, TX 75243-1000 (972) 241-1000 FAX: (972) 241-1001 E-MAIL: sales@ipex.com WWW: www.ipex.com		Request for quotation: 200-07-25 2. Quote to customer: 200-07-25 3. Quote to customer: 200-07-25 4. Quote to customer: 200-07-25 5. Quote to customer: 200-07-25 6. Quote to customer: 200-07-25 7. Quote to customer: 200-07-25 8. Quote to customer: 200-07-25 9. Quote to customer: 200-07-25 10. Quote to customer: 200-07-25	
DRAWN BY: J. HARTMAN DATE: 200-07-25		CHECKED BY: J. HARTMAN DATE: 200-07-25	
TITLE: MHF SQUARE CS ASSEMBLY		SHEET: 1 OF 1	



APPENDIX D

Water Demands, Boundary Conditions and FUS Calculation

**Adelaide Apartments Tower
PRELIMINARY WATER
DEMAND
CALCULATIONS**

JOB NO. 116070

Water Demand (Proposed)							
Building	Residential			Commercial	Demands (L/s)		
	Units		Total Pop'n (pers)	Office Employees (pers)	Average Day	Max. Daily	Peak Hour
	1 Bdrm	2 Bdrm					
New Addition	216	12	328	0	1.33	3.32	7.31
	22	2	35	0	0.14	0.35	0.78
Total	238	14	363	0	1.47	3.68	8.09

Notes:

Residential Densities (from City of Ottawa data):

- 1 Bedroom Apartment = 1.4 cap/unit
- 2 Bedroom Apartment = 2.1 cap/unit

Avg. Day Demand:

- Residential = 350 L/cap/day

Max. Daily Demand:

- Residential = 2.5 x Avg. Day

Peak Hour Demand:

- Residential = 2.2 x Max. Day

Greg MacDonald

From: Fraser, Mark <Mark.Fraser@ottawa.ca>
Sent: Friday, August 05, 2016 8:28 AM
To: Matthew Linton
Cc: Greg MacDonald
Subject: RE: Fire Flow Request - Civic Address_333 Preston Street - Closest X-Street_Aberdeen Street
Attachments: 333 Preston Aug 2016.pdf; Fire Flow Calculations-116070.pdf; 116070-GP-toFraser.pdf

Hi Matthew,

Please find below water distribution network boundary conditions for hydraulic analysis as requested based on the provided anticipated water demands and fire flow requirement.

Proposed Water Demands and Fire Flow Requirement:

Proposed Development Location: 333 Preston Street [Proposed Adelaide Tower]

Average Daily Demand = 1.04 L/s

Max Daily Demand = 2.61 L/s

Peak Hour Demand = 5.74 L/s

Fire Flow = 10,000 L/min

City of Ottawa Boundary Conditions:

Specified Service Connection Point: Aberdeen Street

Minimum HGL = 106.1m

Maximum HGL = 117.5 *[Please note that the maximum pressure is estimated to be more than 80 psi. A pressure check at completion of construction is recommended to determine if pressure control is required.]*

MXDY+Fire = 104.2m

Please note that these are for current conditions and are based on computer model simulation.



The above boundary conditions, HGL, for hydraulic analysis at 333 Preston [**Pressure Zone 1W**] assumed to be connected to the 203mm on Aberdeen Street [see attached PDF for connection location].

Please refer to City of Ottawa, *Ottawa Design Guidelines – Water Distribution*, First Edition, July 2010, WDG001 **Clause 4.2.2** for watermain pressure and demand objectives. Also, please refer to Guidelines and **Technical bulletin ISDTB-2014-02** concerning basic day demands greater than 0.5 L/s

***Disclaimer:** The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermain deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation. Fire Flow analysis is a reflection of available flow in the watermain; there may be additional restrictions that occur between the watermain and the hydrant that the model cannot take into account.*

Regards,

Mark Fraser

Junior Infrastructure Engineer, Suburban Services



City of Ottawa | Ville d'Ottawa
Planning and Growth Management Department
110 Laurier Avenue West, 4th Floor, Ottawa ON, K1P 1J1
Tel: 613.580.2424 ext. 27791
Fax: 613-580-2576
Mail: Code 01-14
Email: Mark.Fraser@ottawa.ca

**Please consider your environmental responsibility before printing this e-mail*

From: Matthew Linton [<mailto:m.linton@novatech-eng.com>]
Sent: August 04, 2016 11:44 AM
To: Fraser, Mark
Cc: Greg MacDonald
Subject: RE: Fire Flow Request - Civic Address_333 Preston Street - Closest X-Street_Aberdeen Street

Good afternoon Mark,

I am just wondering if there is any update as to when we will receive the boundary conditions.

Thanks,

Matthew Linton, CAD Drafting

NOVATECH Engineers, Planners & Landscape Architects

240 Michael Cowpland Drive, Suite 200, Ottawa, ON, K2M 1P6 | Tel: 613.254.9643 | Fax: 613.254.5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

From: Adam Lambros
Sent: July-28-16 3:00 PM
To: Fraser, Mark <Mark.Fraser@ottawa.ca>
Cc: Greg MacDonald <g.Macdonald@novatech-eng.com>; Matthew Linton <m.linton@novatech-eng.com>
Subject: RE: Fire Flow Request - Civic Address_333 Preston Street - Closest X-Street_Aberdeen Street

Hello Mark,

Thanks for the update. My last day at Novatech is tomorrow, please include Greg and Matt (CCed) on your email.

Regards,

Adam Lambros

From: Fraser, Mark [<mailto:Mark.Fraser@ottawa.ca>]

Sent: July-28-16 2:58 PM

To: Adam Lambros <a.lambros@novatech-eng.com>

Subject: RE: Fire Flow Request - Civic Address_333 Preston Street - Closest X-Street_Aberdeen Street

Hi Adam,

I should have the boundary conditions by tomorrow for you.

Regards,

Mark Fraser

Junior Infrastructure Engineer, Suburban Services



City of Ottawa | Ville d'Ottawa

Planning and Growth Management Department

110 Laurier Avenue West, 4th Floor, Ottawa ON, K1P 1J1

[Tel: 613.580.2424](tel:613.580.2424) ext. 27791

Fax: 613-580-2576

Mail: Code 01-14

Email: Mark.Fraser@ottawa.ca

*Please consider your environmental responsibility before printing this e-mail

From: Fraser, Mark

Sent: July 18, 2016 8:46 AM

To: 'Adam Lambros'

Subject: RE: Fire Flow Request - Civic Address_333 Preston Street - Closest X-Street_Aberdeen Street

Hi Adam,

Please accept this email as confirmation that boundary conditions for hydraulic analysis have been requested based on the anticipated water demands for the subject site. Please note that It takes approximately 5 business days to receive boundary conditions.

If you require any additional information I will direct you to a Project Manager in the Development Review Urban Services Unit.

Regards,

Mark Fraser



City of Ottawa | Ville d'Ottawa
Planning and Growth Management Department
110 Laurier Avenue West, 4th Floor, Ottawa ON, K1P 1J1
[Tel: 613.580.2424](tel:613.580.2424) ext. 27791
Fax: 613-580-2576
Mail: Code 01-14
Email: Mark.Fraser@ottawa.ca

*Please consider your environmental responsibility before printing this e-mail

From: Adam Lambros [<mailto:a.lambros@novatech-eng.com>]

Sent: July 15, 2016 3:14 PM

To: Fraser, Mark

Cc: Matthew Linton

Subject: RE: Fire Flow Request - Civic Address_333 Preston Street - Closest X-Street_Aberdeen Street

Hi Mark,

The service connection will be made to Aberdeen street while the fire flows will come off of the hydrant along 200mm WM on-site. So, can the model please be run accordingly, providing boundary conditions at points "1" and "2" as shown on the attached plan and highlighted in yellow?

Requested info is as follows;

Residential Condominium Tower, 184 units.

Site Address: 17 Aberdeen St. (Extension of existing building)

A plan clearly showing the proposed water service connection location(s): See attached, highlighted in yellow.

Anticipated Water Demands:

Population Calculation = 184 units x 1.4 persons per unit
 = 258 people

Proposed Average Residential Flows = 258 people x 350 L/cap/day
 = 90,160 L/day
 = 1.04 L/sec

Average Day Demand = 90,160 L/day
 = 1.04 L/s

Max Daily Demand = 90,160 L/day x 2.5
 = 225,400 L/day
 = 2.61 L/s

Max Hourly Demand = 225,400 L/day x 2.2
 = 495,880 L/day
 = 5.74 L/s

Fire Flow = 10,000 L/min (See attached FUS calc)

Please call I you would like to discuss,

Adam Lambros, P.Eng

NOVATECH Engineers, Planners & Landscape Architects

The information contained in this email message is confidential and is for exclusive use of the addressee.

From: Fraser, Mark [<mailto:Mark.Fraser@ottawa.ca>]

Sent: July-12-16 3:22 PM

To: Adam Lambros <a.lambros@novatech-eng.com>

Subject: RE: Fire Flow Request - Civic Address_333 Preston Street - Closest X-Street_Aberdeen Street

Hi Adam,

To request City of Ottawa water distribution network boundary conditions please provide the City with following information:

- Type of Development
- Site Address
- A plan clearly showing the proposed water service connection location(s)
- Anticipated Water Demands
 - Average Daily Demand (L/s)
 - Maximum Daily Demand (L/s)
 - Peak Hour Demand (L/s)
 - Fire Flow (L/s)

Please provide a PDF copy of the FUS and water demand calculations to support the anticipated demands provided.

- Fire flow demand requirements shall be based on Fire Underwriters Survey (FUS) Water Supply for Public Fire Protection 1999 as per the *Ottawa Design Guidelines – Water Distribution*, First Edition, Document WDG001, July 2010, City of Ottawa Clause 4.2.11.
- The full 50% reduction for sprinklering is only available for monitored systems.
- Reductions, where applied to the fire requirement demand calculation(s), need to be justified.

Once the required information has been provided it will take **approximately five (5) business days** to receive boundary condition results for hydraulic analysis.

If you have any questions please let me know.

Regards,

Mark Fraser

Junior Infrastructure Engineer, Suburban Services



City of Ottawa | Ville d'Ottawa
Planning and Growth Management Department
110 Laurier Avenue West, 4th Floor, Ottawa ON, K1P 1J1
[Tel: 613.580.2424](tel:613.580.2424) ext. 27791
Fax: 613-580-2576
Mail: Code 01-14
Email: Mark.Fraser@ottawa.ca

*Please consider your environmental responsibility before printing this e-mail

From: Adam Lambros [<mailto:a.lambros@novatech-eng.com>]
Sent: July 12, 2016 1:19 PM
To: Fraser, Mark
Subject: RE: Fire Flow Request - Civic Address_333 Preston Street - Closest X-Street_Aberdeen Street

Hello Mark,

Can we obtain boundary conditions instead? If so, I'll send over our demands?

Left you a message earlier, please call if you would like to discuss.

Regards,

Adam Lambros

From: Fraser, Mark [<mailto:Mark.Fraser@ottawa.ca>]
Sent: July-08-16 3:31 PM
To: Adam Lambros <a.lambros@novatech-eng.com>
Cc: Greg MacDonald <g.Macdonald@novatech-eng.com>; Matthew Linton <m.linton@novatech-eng.com>
Subject: RE: Fire Flow Request - Civic Address_333 Preston Street - Closest X-Street_Aberdeen Street

Hi Adam,

Please note that I have been advised by the Environmental Services Department that the City of Ottawa is no longer in a position to provide fire flow/pressure data. Should you wish to schedule a flow test, please visit the website [Water Bylaw](#) section 62, and contact Sarah.Ramsey@Ottawa.ca or call the Business Services Branch at 613-580-2424 x22268.

Regards,

Mark Fraser

Junior Infrastructure Engineer, Suburban Services



City of Ottawa | Ville d'Ottawa
Planning and Growth Management Department
110 Laurier Avenue West, 4th Floor, Ottawa ON, K1P 1J1
[Tel: 613.580.2424](tel:613.580.2424) ext. 27791
Fax: 613-580-2576
Mail: Code 01-14
Email: Mark.Fraser@ottawa.ca

**Please consider your environmental responsibility before printing this e-mail*

From: Fraser, Mark
Sent: July 05, 2016 2:29 PM
To: 'hydrantfireflow@ottawa.ca'
Cc: 'Adam Lambros'; 'Greg MacDonald'; Matthew Linton
Subject: Fire Flow Request - Civic Address_333 Preston Street - Closest X-Street_Aberdeen Street

Hydrant Fire Flow,

Please accept this email as a request to obtain City of Ottawa available **Fire Hydrant Flow Data**:

- A civic address and the closest x-street:
333 Preston Street – Closest x-Street: Aberdeen Street [Adelaide Tower]
- Fire hydrant identification no.(s):
Public Fire Hydrant(s): [H312] [H053] [H054] [H212] [H213]
Private Fire Hydrant(s): [HP296] [HP295] if data is available for private fire hydrants
- The nature of the request, **development** or **non-development** (development requests are those in which other City permits will be required regardless of the requestor's scope of work):
Development Request_Proposed Site Servicing Study
- General details as to the work being performed (i.e. purpose for request):
Fire hydrant flow data has been requested prior to submission of a Site Plan Control development application for a proposed tower, an extension of the existing Adelaide tower residence, 24 story residential building.
Please note that the consultant will be advised to also request boundary conditions to further validate any fire hydrant flow data issued as it is noted that testing remains a point-in-time test, and as such may not reflect the current system conditions and/or hydraulics.
- Required Fire Flow (as per Fire Underwriter's Survey Guidelines):
Fire Flow Calculations Attached. The floor area in the attached calculations is that of the existing building + the area of the new extension + 25% of floor above + 25% of floor below.



If obsolete or insufficient fire hydrant flow data is only available at this time please notify.

Through this email the consultant has been notified to allow for **10 business days** to receive a reply to this Fire Hydrant Flow Data Request.

To schedule a new test, please contact the Business Services Branch at 613-580-2424 x22268 and visit the website [Water Bylaw](#) section **62** for more information.

Regards,

Mark Fraser

Junior Infrastructure Engineer, Suburban Services



City of Ottawa | Ville d'Ottawa
Planning and Growth Management Department
110 Laurier Avenue West, 4th Floor, Ottawa ON, K1P 1J1

Tel:613.580.2424 ext. 27791
Fax: 613-580-2576
Mail: Code 01-14
Email: Mark.Fraser@ottawa.ca

*Please consider your environmental responsibility before printing this e-mail

This e-mail, including any document or other material contained within the e-mail, is the property of the City of Ottawa. It is to be used only for the purposes intended by the sender. It may contain confidential information. If you have received this e-mail in error, please notify the sender immediately by e-mail. Do not copy, distribute or take any action in reliance on the information contained in this e-mail. If you are not the intended recipient, please do not print, copy, retransmit, disseminate, or otherwise use the information contained in this e-mail. If you are not the intended recipient, please do not print, copy, retransmit, disseminate, or otherwise use the information contained in this e-mail.

From: Adam Lambros [<mailto:a.lambros@novatech-eng.com>]
Sent: July 04, 2016 2:06 PM
To: Fraser, Mark
Cc: Greg MacDonald; Matthew Linton
Subject: RE: Adelaide Tower

Sorry Mark,

Can we please have HP296 & HP295 as well?

Regards,

Adam Lambros

From: Adam Lambros
Sent: July-04-16 2:03 PM
To: 'Fraser, Mark' <Mark.Fraser@ottawa.ca>
Cc: Greg MacDonald <g.Macdonald@novatech-eng.com>; Matthew Linton <m.linton@novatech-eng.com>
Subject: Adelaide Tower

Hello Mark,

Can you please provide hydrant data for the following hydrants on or near Aberdeen St.

H312
H053
H054
H212
H213

Regards,

Adam Lambros, P.Eng

NOVATECH Engineers, Planners & Landscape Architects

240 Michael Cowpland Drive, Suite 200, Ottawa, ON, K2M 1P6 | Tel: 613.254.9643 x278 | Tel(Direct): 613.254.9839 x278 | Fax: 613.254.5867

The information contained in this email message is confidential and is for exclusive use of the addressee.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

ISSUED FOR
No. DATE DESCRIPTION

1. JUL 1998 ISSUED WITH EPA

REVISIONS

ALL DIMENSIONS TO BE VERIFIED ON SITE. ANY DISCREPANCIES TO BE REPORTED TO THE ARCHITECT PRIOR TO PROCEEDING WITH THE WORK. DIMENSIONS ARE NOT TO BE SCALES.

CONSTRUCTION OF THIS TOWER WILL BE GROUP ARCHITECTS. ALL RIGHTS RESERVED. NO PART OF THIS DRAWING IS TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT PERMISSION IN WRITING FROM GROUP ARCHITECTS.

ADLAIDE APARTMENTS
TOWER EXTENSION
BMD CORPORATION

17 ABERDEEN STREET
DUNEDIN, DUNEDIN 915 333

GENERAL PLAN OF SERVICES

MTL CLM 1250

39040 C.100

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION


PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION


PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION

PROPOSED
ADLAIDE
APARTMENTS
TOWER
EXTENSION



DRAWINGS



- GRADING NOTES:**
1. ALL TOPSOIL, ORGANIC OR DELETERIOUS MATERIAL MUST BE ENTIRELY REMOVED FROM BENEATH THE PROPOSED PAVED AREAS AS DIRECTED BY THE SITE ENGINEER OR GEOTECHNICAL ENGINEER.
 2. EXPOSED SUBGRADES IN PROPOSED PAVED AREAS SHOULD BE PROOF ROLLED WITH A LARGE STEEL DRUM ROLLER AND INSPECTED BY THE GEOTECHNICAL ENGINEER PRIOR TO THE PLACEMENT OF GRANULARS.
 3. ANY SOFT AREAS EVIDENT FROM THE PROOF ROLLING SHOULD BE SUB-EXCAVATED AND REPLACED WITH SUITABLE MATERIAL THAT IS FROST COMPATIBLE WITH THE EXISTING SOILS AS RECOMMENDED BY THE GEOTECHNICAL ENGINEER.
 4. THE GRANULAR BASE SHOULD BE COMPACTED TO AT LEAST 100% OF THE STANDARD PROCTOR MAXIMUM DRY DENSITY VALUE. ANY ADDITIONAL GRANULAR FILL USED BELOW THE PROPOSED PAVEMENT SHOULD BE COMPACTED TO AT LEAST 90% OF THE STANDARD PROCTOR MAXIMUM DRY DENSITY VALUE.
 5. MINIMUM OF 2% GRADE FOR ALL GRASS AREAS UNLESS OTHERWISE NOTED.
 6. ALL GRADES BY CURBS ARE EDGE OF PAVEMENT GRADES UNLESS OTHERWISE INDICATED.
 7. ALL CURBS SHALL BE BARRIER CURBS (150mm) UNLESS OTHERWISE NOTED AND CONSTRUCTED AS PER CITY OF OTTAWA STANDARDS (SCL1).
 8. REFER TO LANDSCAPE PLAN FOR PLANTING AND OTHER LANDSCAPE FEATURE DETAILS.
 13. CONTRACTOR TO PROVIDE THE CONSULTANT WITH A GRADING PLAN INDICATING AS-BUILT ELEVATIONS OF ALL DESIGN GRADES SHOWN ON THIS PLAN.
- GENERAL NOTES:**
1. COORDINATE AND SCHEDULE ALL WORK WITH OTHER TRADES AND CONTRACTORS.
 2. DETERMINE THE EXACT LOCATION, SIZE, MATERIAL AND ELEVATION OF ALL EXISTING UTILITIES PRIOR TO COMMENCING CONSTRUCTION. PROTECT AND ASSUME RESPONSIBILITY FOR ALL EXISTING UTILITIES WHETHER OR NOT SHOWN ON THIS DRAWING.
 3. OBTAIN ALL NECESSARY PERMITS AND APPROVALS FROM THE CITY OF OTTAWA BEFORE COMMENCING CONSTRUCTION.
 4. BEFORE COMMENCING CONSTRUCTION OBTAIN AND PROVIDE PROOF OF COMPREHENSIVE, ALL RISK AND OPERATIONAL LIABILITY INSURANCE FOR \$5,000,000.00, INSURANCE POLICY TO NAME OWNERS, ENGINEERS AND ARCHITECTS AS CO-INSURED.
 5. RESTORE ALL DISTURBED AREAS ON-SITE AND OFF-SITE, INCLUDING TRENCHES AND SURFACES ON PUBLIC ROAD ALLOWANCES TO EXISTING CONDITIONS OR BETTER TO THE SATISFACTION OF THE CITY OF OTTAWA AND ENGINEER.
 6. REMOVS FROM SITE ALL EXCESS EXCAVATED MATERIAL, ORGANIC MATERIAL AND DEBRIS UNLESS OTHERWISE INSTRUCTED BY ENGINEER, EXCAVATE AND REMOVE FROM SITE ANY CONTAMINATED MATERIAL. ALL CONTAMINATED MATERIAL SHALL BE DISPOSED OF AT A LICENSED LANDFILL FACILITY.
 7. ALL ELEVATIONS ARE GEODETIC.
 8. THE GEOTECHNICAL CONSULTANT IS TO REVIEW ON-SITE CONDITIONS AFTER EXCAVATION PRIOR TO PLACEMENT OF THE GRANULAR MATERIAL.
 9. REFER TO ARCHITECTS AND LANDSCAPE ARCHITECTS DRAWINGS FOR BUILDING AND HARDSURFACE AREAS AND DIMENSIONS.
 10. REFER TO STORMWATER MANAGEMENT REPORT(R-2016-076) PREPARED BY NOVATECH ENGINEERING CONSULTANTS LTD.
 11. SAW CUT AND KEY GRID ASPHALT AT ALL ROAD CUTS AND ASPHALT TIE IN POINTS AS PER CITY OF OTTAWA STANDARDS (R10).
 12. PROVIDE LINE/PARKING PAINTING.

CLIENT

SAKTO CORPORATION

910-333 PRESTON STREET
OTTAWA, ON, K1S 5N4

COPYRIGHT

ISSUES

No.	DESCRIPTION	DATE
1.	ISSUED FOR SPA	2016/09/20
2.	REVISED PER CITY COMMENTS	2016/12/14
3.	REVISED PARKING ALONG ENTRANCE	2017/04/07
4.	PATH ADDED FROM ROCHESTER	2017/05/24
5.	SIAMSESE CONNECTION, DEPRESSED CURBS AND FIRE TRUCK ROUTE ADDED	2017/07/12
6.	REVISED SITE PLAN APPLICATION	2019/01/11

KEYPLAN

CONSULTANTS

NOVATECH

Engineers, Planners & Landscape Architects
Suite 200, 240 Michael Cowpland Drive
Ottawa, Ontario, Canada K1M 1R6
Telephone: (613) 254-9643
Facsimile: (613) 254-5887
Website: www.novatech-eng.com

NORTH ARROW:

SEAL

PRIME CONSULTANT

IBI GROUP

Suite 500, 611 Main Street West
Ottawa, Ontario, Canada K1P 1H1
Tel: 613 237 1900 Fax: 613 270 5610
ibi-group.com

PROJECT

ADELAIDE TOWER EXPANSION
17 Aberdeen Street
Ottawa, Ontario, Canada
K1S 3J3

PROJECT NO:

116070

DRAWN BY:

MMW/GB

CHECKED BY:

LGB

PROJECT MGR:

GJM

APPROVED BY:

GJM

SCALE:

1:250

DATE:

2019-01-04

SHEET TITLE

GRADING PLAN

SHEET NUMBER

C.101

ISSUE

6

