


UPDATED ROADWAY TRAFFIC NOISE ASSESSMENT

400 Albert Street
Ottawa, Ontario

REPORT: GWE19-154 – Traffic Noise



August 27, 2019

PREPARED FOR

main + main

109 Atlantic Avenue, Suite 302B
Toronto, ON
M6K 1X4

PREPARED BY

Michael Lafortune, C.E.T., Environmental Scientist
Joshua Foster, P.Eng., Principal

EXECUTIVE SUMMARY

This report describes an updated traffic noise assessment undertaken for a mixed-use development to be located at 400 Albert Street in Ottawa, Ontario. The original analysis completed as part of 'Traffic Noise Impact Study', dated April 20, 2017, contained similar massing and layout. The development comprises Tower A (18 storeys) and Tower B (33 storeys), which are respectively located north and southeast on the site and connected by a three-storey podium, and Tower C (38 storeys), located southwest on the site. Outdoor amenity space is provided atop the 3-storey podium. The major source of noise is roadway traffic along Albert Street, Lyon Street, and Slater Street. The site is surrounded with a mix of residential and commercial, low to high-rise buildings. Figure 1 illustrates a complete site plan with surrounding context.

The assessment is based on (i) theoretical noise prediction methods that conform to the Ministry of the Environment, Conservation and Parks (MOECP) and City of Ottawa requirements; (ii) noise level criteria as specified by the City of Ottawa's Environmental Noise Control Guidelines (ENCG); (iii) future vehicular traffic volumes based on the City of Ottawa's Official Plan roadway classifications; and (iv) architectural drawings provided by IBI Group in August 2019.

The results of the current analysis indicate that noise levels will range between 51 and 70 dBA during the daytime period (07:00-23:00) and between 44 and 63 dBA during the nighttime period (23:00-07:00). The highest noise level (70 dBA) occurs at façades fronting onto arterial roadways. Building components with a higher Sound Transmission Class (STC) rating will be required where exterior noise levels exceed 65 dBA, as indicated in Figure 3.

Results of the calculations also indicate that the development will require central air conditioning, which will allow occupants to keep windows closed and maintain a comfortable living environment. A Warning Clause will also be required on all Lease, Purchase and Sale Agreements, as summarized in Section 6.

With regards to stationary noise impacts, a stationary noise study will be performed once mechanical plans for the proposed building become available. This study would assess impacts of stationary noise from rooftop mechanical units serving the proposed building on surrounding noise-sensitive areas. This study will include recommendations for any noise control measures that may be necessary to ensure noise levels fall below MECP and ENCG criteria.

TABLE OF CONTENTS

1. INTRODUCTION	1
2. TERMS OF REFERENCE	1
3. OBJECTIVES	2
4. METHODOLOGY.....	2
4.1 Background.....	2
4.2 Roadway Traffic Noise.....	2
4.2.1 Criteria for Roadway Traffic Noise	2
4.2.2 Theoretical Roadway Noise Predictions	4
4.2.3 Roadway Traffic Volumes	4
4.3 Indoor Noise Calculations	5
5. RESULTS AND DISCUSSION.....	6
5.1 Roadway Traffic Noise Levels.....	6
5.2 Noise Control Measures	8
6. CONCLUSIONS AND RECOMMENDATIONS	9

FIGURES

APPENDICES

Appendix A – STAMSON 5.04 Input and Output Data and Supporting Information



1. INTRODUCTION

Gradient Wind Engineering Inc. (Gradient Wind) was retained by main + main to undertake a roadway traffic noise assessment for a mixed-use development to be located at 400 Albert Street in Ottawa, Ontario. This report summarizes the methodology, results, and recommendations related to the assessment of exterior and interior noise levels generated by local roadway traffic.

Our work is based on theoretical noise calculation methods conforming to the City of Ottawa¹ and Ministry of the Environment, Conservation and Parks (MOECP)² guidelines. Noise calculations were based on architectural drawings provided by IBI Group in August 2019, with future traffic volumes corresponding to the City of Ottawa's Official Plan (OP) roadway classifications.

2. TERMS OF REFERENCE

The focus of this updated roadway traffic noise assessment is a proposed mixed-use development at 400 Albert Street in Ottawa, Ontario. The study site is located on a parcel of land bounded by Bay Street to the west, Albert Street to the north, Lyon Street North to the east, and Slater Street to the south. The original analysis completed as part of 'Traffic Noise Impact Study', dated April 20, 2017, contained similar massing and layout.

The proposed development comprises Tower A (18 storeys) and Tower B (33 storeys), which are respectively located north and southeast on the site and connected by a three-storey podium, and Tower C (38 storeys), located southwest on the site. Two existing three-storey buildings occupy the northwest corner of the site, while an urban park occupies the northeast corner of the site. Towers A and B are separated from Tower C by a multi-functional mid-block connection from Albert Street to Slater Street. The ground floor of the podium comprises residential lobbies at the northwest and southeast corners, an office lobby north of the residential lobby at the southeast corner, and a grocery store in the remaining space. An enclosed loading bay is located at the northwest corner. Ground floor of Tower C comprises a residential lobby at the southwest corner, retail space at the southeast corner, and a ramp to underground

¹ City of Ottawa Environmental Noise Control Guidelines, January 2016

² Ontario Ministry of the Environment and Climate Change – Environmental Noise Guidelines, Publication NPC-300, Queens Printer for Ontario, Toronto, 2013



parking along the north side of the building accessed from Bay Street. Outdoor amenity space is provided atop the 3-storey podium.

The major source of noise is roadway traffic along Albert Street, Lyon Street, and Slater Street. The site is surrounded with a mix of residential and commercial, low to high-rise buildings. Figure 1 illustrates a complete site plan with surrounding context.

3. OBJECTIVES

The principal objectives of this study are to (i) calculate the future noise levels on the study buildings produced by local roadway traffic, and (ii) ensure that interior and exterior noise levels do not exceed the allowable limits specified by the City of Ottawa's Environmental Noise Control Guidelines as outlined in Section 4.2 of this report.

4. METHODOLOGY

4.1 Background

Noise can be defined as any obtrusive sound. It is created at a source, transmitted through a medium, such as air, and intercepted by a receiver. Noise may be characterized in terms of the power of the source or the sound pressure at a specific distance. While the power of a source is characteristic of that particular source, the sound pressure depends on the location of the receiver and the path that the noise takes to reach the receiver. Measurement of noise is based on the decibel unit, dBA, which is a logarithmic ratio referenced to a standard noise level (2×10^{-5} Pascals). The 'A' suffix refers to a weighting scale, which better represents how the noise is perceived by the human ear. With this scale, a doubling of power results in a 3 dBA increase in measured noise levels and is just perceptible to most people. An increase of 10 dBA is often perceived to be twice as loud.

4.2 Roadway Traffic Noise

4.2.1 Criteria for Roadway Traffic Noise

For surface roadway traffic noise, the equivalent sound energy level, L_{eq} , provides a measure of the time varying noise levels, which is well correlated with the annoyance of sound. It is defined as the continuous sound level, which has the same energy as a time varying noise level over a period of time. For roadways,



the L_{eq} is commonly calculated on the basis of a 16-hour (L_{eq16}) daytime (07:00-23:00) / 8-hour (L_{eq8}) nighttime (23:00-07:00) split to assess its impact on residential buildings. The City of Ottawa's Environmental Noise Control Guidelines (ENCG) specifies that the recommended indoor noise limit range (that is relevant to this study) is 45 and 40 dBA for living rooms and sleeping quarters respectively for roadway as listed in Table 1.

TABLE 1: INDOOR SOUND LEVEL CRITERIA (ROAD)³

Type of Space	Time Period	L_{eq} (dBA)
General offices, reception areas, retail stores, etc.	07:00 – 23:00	50
Living/dining/den areas of residences , hospitals, schools, nursing/retirement homes, day-care centres, theatres, places of worship, libraries, individual or semi-private offices, conference rooms, etc.	07:00 – 23:00	45
Sleeping quarters of hotels/motels	23:00 – 07:00	45
Sleeping quarters of residences , hospitals, nursing/retirement homes, etc.	23:00 – 07:00	40

Predicted noise levels at the plane of window (POW) dictate the action required to achieve the recommended sound levels. An open window is considered to provide a 10 dBA reduction in noise, while a standard closed window is capable of providing a minimum 20 dBA noise reduction⁴. A closed window due to a ventilation requirement will bring noise levels down to achieve an acceptable indoor environment⁵. Therefore, where noise levels exceed 55 dBA daytime and 50 dBA nighttime, the ventilation for the building should consider the need for having windows and doors closed, which triggers the need for forced air heating with provision for central air conditioning. Where noise levels exceed 65 dBA daytime and 60 dBA nighttime, air conditioning will be required and building components will require higher levels of sound attenuation⁶.

³ Adapted from ENCG 2016 – Tables 2.2b and 2.2c

⁴ Burberry, P.B. (2014). *Mitchell's Environment and Services*. Routledge, Page 125

⁵ MOECP, Environmental Noise Guidelines, NPC 300 – Part C, Section 7.8

⁶ MOECP, Environmental Noise Guidelines, NPC 300 – Part C, Section 7.1.3



The sound level criterion for outdoor living areas is 55 dBA, which applies during the daytime (07:00 to 23:00). When noise levels exceed 55 dBA, mitigation must be provided to reduce noise levels where technically and administratively feasible to acceptable levels at or below the criterion.

4.2.2 Theoretical Roadway Noise Predictions

Noise predictions were performed with the aid of the MOECP computerized noise assessment program, STAMSON 5.04, for road analysis. Appendix A includes the STAMSON 5.04 input and output data.

Roadway traffic noise calculations were performed by treating each roadway segment as separate line sources of noise. In addition to the traffic volumes summarized in Table 2, theoretical noise predictions were based on the following parameters:

- Truck traffic on all roadways was taken to comprise 5% heavy trucks and 7% medium trucks, as per ENCG requirements for noise level predictions.
- The day/night split for all streets was taken to be 92%/8%, respectively.
- Ground surfaces were taken to be reflective due to the presence of hard (paved) ground.
- Topography was assumed to be a flat/gentle slope surrounding the study building.
- For select sources, where appropriate, the proposed building was considered as a barrier. Tower A, B, C and podium at 62.3 m, 107.9 m, 123.6 m and 16 m, respectively.
- Noise receptors were strategically placed at 28 locations around the study area (see Figure 2).
- Sample receptor distances and exposure angles are illustrated in Figures 4-8.

4.2.3 Roadway Traffic Volumes

The ENCG dictates that noise calculations should consider future sound levels based on a roadway's classification at the mature state of development. Therefore, traffic volumes are based on the roadway classifications outlined in the City of Ottawa's Official Plan (OP) and Transportation Master Plan⁷ which provide additional details on future roadway expansions. Average Annual Daily Traffic (AADT) volumes are then based on data in Table B1 of the ENCG for each roadway classification. Table 2 (below) summarizes the AADT values used for each roadway included in this assessment.

⁷ City of Ottawa Transportation Master Plan, November 2013



TABLE 2: ROADWAY TRAFFIC DATA

Segment	Roadway Traffic Data	Speed Limit (km/h)	Traffic Volumes
Albert Street	2- Lane Urban Arterial (2-UAU)	50	15,000
Slater Street	2- Lane Urban Arterial (2-UAU)	50	15,000
Lyon Street	2- Lane Urban Arterial (2-UAU)	50	15,000

4.3 Indoor Noise Calculations

The difference between outdoor and indoor noise levels is the noise attenuation provided by the building envelope. According to common industry practice, complete walls and individual wall elements are rated according to the Sound Transmission Class (STC). The STC ratings of common residential walls built in conformance with the Ontario Building Code (2012) typically exceed STC 35, depending on exterior cladding, thickness and interior finish details. For example, brick veneer walls can achieve STC 50 or more. Standard commercially sided exterior metal stud walls have around STC 45. Standard good quality double-glazed non-operable windows can have STC ratings ranging from 25 to 40, depending on the window manufacturer, pane thickness and inter-pane spacing. As previously mentioned, the windows are the known weak point in a partition.

As per Section 4.2, when daytime noise levels (from road and rail sources) at the plane of the window exceed 65 dBA, calculations must be performed to evaluate the sound transmission quality of the building components to ensure acceptable indoor noise levels. The calculation procedure⁸ considers:

- Window type and total area as a percentage of total room floor area
- Exterior wall type and total area as a percentage of the total room floor area
- Acoustic absorption characteristics of the room
- Outdoor noise source type and approach geometry
- Indoor sound level criteria, which varies according to the intended use of a space

⁸ Building Practice Note: Controlling Sound Transmission into Buildings by J.D. Quirt, National Research Council of Canada, September 1985

Based on published research⁹, exterior walls possess specific sound attenuation characteristics that are used as a basis for calculating the required STC ratings of windows in the same partition. Due to the limited information available at the time of the study, which was prepared for site plan approval, detailed floor layouts and building elevations have not been finalized; therefore, detailed STC calculations could not be performed at this time. As a guideline, the anticipated STC requirements for windows have been estimated based on the overall noise reduction required for each intended use of space (STC = outdoor noise level – targeted indoor noise levels).

5. RESULTS AND DISCUSSION

5.1 Roadway Traffic Noise Levels

The results of the roadway traffic noise calculations are summarized in Table 3 below. A complete set of input and output data from all STAMSON 5.04 calculations are available in Appendix A.

⁹ CMHC, Road & Rail Noise: Effects on Housing



TABLE 3: EXTERIOR NOISE LEVELS DUE TO ROAD TRAFFIC

Receptor Number	Receptor Height Above Roof/Grade (m)	Receptor Location	STAMSON 5.04 Noise Level (dBA)	
			Day	Night
1	1.5	POW – Ground Level – Tower A North Façade	68	61
2	1.5	POW – Ground Level – Tower B East Façade	70	62
3	7.1	POW – 3rd Floor – Tower B East Façade	69	62
4	7.1	POW – 3rd Floor – Tower B South Façade	70	63
5	7.1	POW – 3rd Floor – Tower B West Façade	65	58
6	7.1	POW – 3rd Floor – Tower C South Façade	68	61
7	7.1	POW – 3rd Floor – Tower C West Façade	65	58
8	7.1	POW – 3rd Floor – Tower C East Façade	66	58
9	16.6	POW – 6 th Floor – Tower A North Façade	69	61
10	60.8	POW – 18 th Floor – Tower A East Façade	67	59
11	16.6	POW – 6 th Floor – Tower A West Façade	65	58
12	24.9	POW – 9 th Floor – Tower A South Façade	58	51
13	24.9	POW – 9 th Floor – Tower A West Façade	65	58
14	49.8	POW – 18th Floor – Tower B East Façade	69	62
15	49.8	POW – 18th Floor – Tower B South Façade	70	62
16	49.8	POW – 18th Floor – Tower B West Façade	65	57
17	49.8	POW – 18th Floor – Tower C East Façade	66	58
18	49.8	POW – 18th Floor – Tower C South Façade	68	61
19	49.8	POW – 18th Floor – Tower C West Façade	65	57
20	49.8	POW – 18th Floor – Tower C North Façade	63	55
21	72.2	POW – 26th Floor – Tower B East Façade	69	62
22	72.2	POW – 26th Floor – Tower B South Façade	70	62
23	72.2	POW – 26th Floor – Tower B West Façade	65	57
24	72.2	POW – 26th Floor – Tower C East Façade	66	58
25	72.2	POW – 26th Floor – Tower C South Façade	68	61
26	72.2	POW – 26th Floor – Tower C West Façade	65	57
27	72.2	POW – 26th Floor – Tower B North Façade	65	58
28	1.5	OLA – Podium Terrace	51	44

The results of the current analysis indicate that noise levels will range between 51 and 70 dBA during the daytime period (07:00-23:00) and between 44 and 63 dBA during the nighttime period (23:00-07:00). The highest noise level (70 dBA) occurs at façades fronting onto arterial roadways.

5.2 Noise Control Measures

The noise levels predicted due to roadway traffic exceed the criteria listed in Section 4.2 for building components. As discussed in Section 4.3, the anticipated STC requirements for windows have been estimated based on the overall noise reduction required for each intended use of space (STC = outdoor noise level – targeted indoor noise levels). As per city of Ottawa requirements, detailed STC calculations will be required to be completed prior to building permit application for each unit type. The STC requirements for the windows are summarized below for various units within the development (see Figure 3):

TABLE 4: WINDOW STC REQUIREMENTS

Location	Façade	Window STC Requirements		
		Bedroom	Living Room	Retail
Podium	North	33	28	25
	East	33	28	25
	South	33	28	25
	West	OBC 2012		
Tower A	North	33	28	25
	East	30	25	25
	South	OBC 2012		
	West	OBC 2012		
Tower B	North	30	25	25
	East	33	28	25
	South	33	28	25
	West	OBC 2012		
Tower C	North	OBC 2012		
	East	30	25	25
	South	33	28	25
	West	OBC 2012		

Exterior wall components on these façades will require a minimum STC of 45, which will be achieved with brick cladding or an acoustical equivalent according to NRC test data¹⁰. The STC requirements apply to windows, doors, spandrel panels and curtainwall elements. Exterior wall components on these façades are recommended to have a minimum STC of 45, where a window/wall system is used. A review of window supplier literature indicates that the specified STC ratings can be achieved by a variety of window systems having a combination of glass thickness and inter-pane spacing. We have specified an example window configuration, however several manufacturers and various combinations of window components, such as those proposed, will offer the necessary sound attenuation rating. It is the responsibility of the manufacturer to ensure that the specified window achieves the required STC. This can only be assured by using window configurations that have been certified by laboratory testing. The requirements for STC ratings assume that the remaining components of the building are constructed and installed according to the minimum standards of the Ontario Building Code. The specified STC requirements also apply to swinging and/or sliding patio doors.

Results of the calculations also indicate that the development will require central air conditioning, which will allow occupants to keep windows closed and maintain a comfortable living environment. In addition to ventilation requirements, Warning Clauses will also be required in all Lease, Purchase and Sale Agreements, as summarized in Section 6.

6. CONCLUSIONS AND RECOMMENDATIONS

The results of the current analysis indicate that noise levels will range between 51 and 70 dBA during the daytime period (07:00-23:00) and between 44 and 63 dBA during the nighttime period (23:00-07:00). The highest noise level (70 dBA) occurs at façades fronting onto arterial roadways. Building components with a higher Sound Transmission Class (STC) rating will be required where exterior noise levels exceed 65 dBA, as indicated in Figure 3.

Results of the calculations also indicate that the development will require central air conditioning, which will allow occupants to keep windows closed and maintain a comfortable living environment. The

¹⁰ J.S. Bradley and J.A. Birta. Laboratory Measurements of the Sound Insulation of Building Façade Elements, National Research Council October 2000.

following Warning Clause¹¹ will also be required on all Lease, Purchase and Sale Agreements, as summarized below:

"Purchasers/tenants are advised that despite the inclusion of noise control features in the development and within the building units, sound levels due to increasing roadway traffic may, on occasion, interfere with some activities of the dwelling occupants, as the sound levels exceed the sound level limits of the City and the Ministry of the Environment and Climate Change. To help address the need for sound attenuation, this development includes:

- *STC rated multi-pane glazing elements and spandrel panels*
- *STC rated exterior walls*

This dwelling unit has also been designed with air conditioning. Air conditioning will allow windows and exterior doors to remain closed, thereby ensuring that the indoor sound levels are within the sound level limits of the City and the Ministry of the Environment and Climate Change.

To ensure that provincial sound level limits are not exceeded, it is important to maintain these sound attenuation features."

With regards to stationary noise impacts, a stationary noise study will be performed once mechanical plans for the proposed building become available. This study would assess impacts of stationary noise from rooftop mechanical units serving the proposed building on surrounding noise-sensitive areas. This study will include recommendations for any noise control measures that may be necessary to ensure noise levels fall below MECP and ENCG criteria.

¹¹ City of Ottawa Environmental Noise Control Guidelines, January 2016

GRADIENTWIND

ENGINEERS & SCIENTISTS


This concludes our traffic noise assessment and report. If you have any questions or wish to discuss our findings, please advise us. In the interim, we thank you for the opportunity to be of service.

Sincerely,

Gradient Wind Engineering Inc.




Michael Lafortune, C.E.T.
Environmental Scientist




Joshua Foster, P.Eng.
Principal


Gradient Wind File #19-154 – Traffic Noise


























GRADIENTWIND
ENGINEERS & SCIENTISTS



APPENDIX A

STAMSON 5.04 – INPUT AND OUTPUT DATA

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 09:11:51
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r1.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Albert (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Albert (day/night)

Angle1 Angle2 : -90.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 15.00 / 15.00 m
Receiver height : 1.50 / 1.50 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : 67.00 deg Angle2 : 90.00 deg
Barrier height : 7.00 m
Barrier receiver distance : 9.00 / 9.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00



GRADIENTWIND

ENGINEERS & SCIENTISTS

```
Road data, segment # 2: Lyon (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Lyon (day/night)

```
Angle1 Angle2 : -90.00 deg -23.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 59.00 / 59.00 m
Receiver height : 1.50 / 1.50 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : -58.00 deg
Barrier height : 7.00 m
Barrier receiver distance : 33.00 / 33.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```



GRADIENTWIND

ENGINEERS & SCIENTISTS

```
Road data, segment # 3: Lyon2 (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 3: Lyon2 (day/night)

```
Angle1 Angle2 : -23.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 59.00 / 59.00 m
Receiver height : 1.50 / 1.50 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -23.00 deg Angle2 : 0.00 deg
Barrier height : 7.00 m
Barrier receiver distance : 9.00 / 9.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```



GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	1.50	1.50	1.50

ROAD $(67.89 + 45.93 + 0.00) = 67.91$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	67	0.00	68.48	0.00	0.00	-0.59	0.00	0.00	0.00	67.89
67	90	0.00	68.48	0.00	0.00	-8.94	0.00	0.00	-13.62	45.93

Segment Leq : 67.91 dBA

Results segment # 2: Lyon (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	1.50	1.50	1.50

ROAD $(0.00 + 44.27 + 55.42) = 55.74$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-58	0.00	68.48	0.00	-5.95	-7.50	0.00	0.00	-10.76	44.27
-58	-23	0.00	68.48	0.00	-5.95	-7.11	0.00	0.00	0.00	55.42

Segment Leq : 55.74 dBA

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 3: Lyon2 (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	1.50	1.50	1.50

ROAD (0.00 + 33.60 + 0.00) = 33.60 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-23	0	0.00	68.48	0.00	-5.95	-8.94	0.00	0.00	-20.00	33.60

Segment Leq : 33.60 dBA

Total Leq All Segments: 68.17 dBA

Results segment # 1: Albert (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	1.50	1.50	1.50

ROAD (60.29 + 38.33 + 0.00) = 60.32 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	67	0.00	60.88	0.00	0.00	-0.59	0.00	0.00	0.00	60.29
67	90	0.00	60.88	0.00	0.00	-8.94	0.00	0.00	-13.62	38.33

Segment Leq : 60.32 dBA

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 2: Lyon (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	1.50	1.50	1.50

ROAD (0.00 + 36.67 + 47.82) = 48.14 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-58	0.00	60.88	0.00	-5.95	-7.50	0.00	0.00	-10.76	36.67
-58	-23	0.00	60.88	0.00	-5.95	-7.11	0.00	0.00	0.00	47.82

Segment Leq : 48.14 dBA

Results segment # 3: Lyon2 (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	1.50	1.50	1.50

ROAD (0.00 + 26.00 + 0.00) = 26.00 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-23	0	0.00	60.88	0.00	-5.95	-8.94	0.00	0.00	-20.00	26.00

Segment Leq : 26.00 dBA

Total Leq All Segments: 60.58 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 68.17
 (NIGHT): 60.58



GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 09:11:59
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r2.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Albert (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Albert (day/night)

Angle1 Angle2 : 0.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 62.00 / 62.00 m
Receiver height : 1.50 / 1.50 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : 33.00 deg Angle2 : 90.00 deg
Barrier height : 72.00 m
Barrier receiver distance : 48.00 / 48.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00



GRADIENTWIND

ENGINEERS & SCIENTISTS

Road data, segment # 2: Lyon (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *

Medium truck volume : 966/84 veh/TimePeriod *

Heavy truck volume : 690/60 veh/TimePeriod *

Posted speed limit : 50 km/h

Road gradient : 0 %

Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 2: Lyon (day/night)

Angle1 Angle2 : -90.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 16.00 / 16.00 m
Receiver height : 1.50 / 1.50 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00



GRADIENTWIND

ENGINEERS & SCIENTISTS

Road data, segment # 3: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 3: Slater (day/night)

Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 17.00 / 17.00 m
Receiver height : 1.50 / 1.50 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00



GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	1.50	1.50	1.50

ROAD $(54.95 + 37.54 + 0.00) = 55.03$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	33	0.00	68.48	0.00	-6.16	-7.37	0.00	0.00	0.00	54.95
33	90	0.00	68.48	0.00	-6.16	-4.99	0.00	0.00	-19.78	37.54

Segment Leq : 55.03 dBA

Results segment # 2: Lyon (day)

Source height = 1.50 m

ROAD $(0.00 + 68.20 + 0.00) = 68.20$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	68.48	0.00	-0.28	0.00	0.00	0.00	0.00	68.20

Segment Leq : 68.20 dBA

Results segment # 3: Slater (day)

Source height = 1.50 m

ROAD $(0.00 + 64.93 + 0.00) = 64.93$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	68.48	0.00	-0.54	-3.01	0.00	0.00	0.00	64.93

Segment Leq : 64.93 dBA

Total Leq All Segments: 70.02 dBA

Results segment # 1: Albert (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	1.50	1.50	1.50

ROAD $(47.35 + 29.95 + 0.00) = 47.43$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	33	0.00	60.88	0.00	-6.16	-7.37	0.00	0.00	0.00	47.35
33	90	0.00	60.88	0.00	-6.16	-4.99	0.00	0.00	-19.78	29.95

Segment Leq : 47.43 dBA

Results segment # 2: Lyon (night)

Source height = 1.50 m

ROAD $(0.00 + 60.60 + 0.00) = 60.60$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	60.88	0.00	-0.28	0.00	0.00	0.00	0.00	60.60

Segment Leq : 60.60 dBA

Results segment # 3: Slater (night)

Source height = 1.50 m

ROAD $(0.00 + 57.33 + 0.00) = 57.33$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	60.88	0.00	-0.54	-3.01	0.00	0.00	0.00	57.33

Segment Leq : 57.33 dBA

Total Leq All Segments: 62.42 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 70.02
(NIGHT): 62.42

STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 09:12:11
 MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r3.te Time Period: Day/Night 16/8 hours
 Description:

Road data, segment # 1: Albert (day/night)

```
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 1: Albert (day/night)

```
-----
Angle1 Angle2 : 0.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 44.00 / 44.00 m
Receiver height : 7.10 / 7.10 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : 44.00 deg Angle2 : 90.00 deg
Barrier height : 72.00 m
Barrier receiver distance : 30.00 / 30.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```



```
Road data, segment # 2: Lyon (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Lyon (day/night)

```
Angle1 Angle2 : -90.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 15.00 / 15.00 m
Receiver height : 7.10 / 7.10 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00
```



```
Road data, segment # 3: Slater (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 3: Slater (day/night)

```
Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 34.00 / 34.00 m
Receiver height : 7.10 / 7.10 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : -54.00 deg
Barrier height : 72.00 m
Barrier receiver distance : 21.00 / 21.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	7.10	3.28	3.28

ROAD $(57.69 + 38.14 + 0.00) = 57.74$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	44	0.00	68.48	0.00	-4.67	-6.12	0.00	0.00	0.00	57.69
44	90	0.00	68.48	0.00	-4.67	-5.93	0.00	0.00	-19.74	38.14

Segment Leq : 57.74 dBA

Results segment # 2: Lyon (day)

Source height = 1.50 m

ROAD $(0.00 + 68.48 + 0.00) = 68.48$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	68.48	0.00	0.00	0.00	0.00	0.00	0.00	68.48

Segment Leq : 68.48 dBA

Results segment # 3: Slater (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	7.10	3.64	3.64

ROAD $(0.00 + 38.25 + 59.70) = 59.73$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-54	0.00	68.48	0.00	-3.55	-6.99	0.00	0.00	-19.69	38.25
-54	0	0.00	68.48	0.00	-3.55	-5.23	0.00	0.00	0.00	59.70

Segment Leq : 59.73 dBA

Total Leq All Segments: 69.34 dBA

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	7.10	3.28	3.28

ROAD $(50.09 + 30.55 + 0.00) = 50.14$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	44	0.00	60.88	0.00	-4.67	-6.12	0.00	0.00	0.00	50.09
44	90	0.00	60.88	0.00	-4.67	-5.93	0.00	0.00	-19.74	30.55

Segment Leq : 50.14 dBA

Results segment # 2: Lyon (night)

Source height = 1.50 m

ROAD $(0.00 + 60.88 + 0.00) = 60.88$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	60.88	0.00	0.00	0.00	0.00	0.00	0.00	60.88

Segment Leq : 60.88 dBA

Results segment # 3: Slater (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	7.10	3.64	3.64

ROAD $(0.00 + 30.65 + 52.10) = 52.13$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-54	0.00	60.88	0.00	-3.55	-6.99	0.00	0.00	-19.69	30.65
-54	0	0.00	60.88	0.00	-3.55	-5.23	0.00	0.00	0.00	52.10

Segment Leq : 52.13 dBA

Total Leq All Segments: 61.74 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 69.34
 (NIGHT): 61.74

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 09:12:20
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r4.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : -90.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 15.00 / 15.00 m
Receiver height : 7.10 / 7.10 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

GRADIENTWIND

ENGINEERS & SCIENTISTS

Road data, segment # 2: Lyon (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *

Medium truck volume : 966/84 veh/TimePeriod *

Heavy truck volume : 690/60 veh/TimePeriod *

Posted speed limit : 50 km/h

Road gradient : 0 %

Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 2: Lyon (day/night)

Angle1 Angle2 : 0.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 16.00 / 16.00 m
Receiver height : 7.10 / 7.10 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

ROAD	(0.00 + 68.48 + 0.00) = 68.48 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	68.48	0.00	0.00	0.00	0.00	0.00	0.00	68.48

Segment Leq : 68.48 dBA

Results segment # 2: Lyon (day)

Source height = 1.50 m

ROAD	(0.00 + 65.19 + 0.00) = 65.19 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	90	0.00	68.48	0.00	-0.28	-3.01	0.00	0.00	0.00	65.19

Segment Leq : 65.19 dBA

Total Leq All Segments: 70.15 dBA

Results segment # 1: Slater (night)

Source height = 1.50 m

ROAD	(0.00 + 60.88 + 0.00) = 60.88 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	60.88	0.00	0.00	0.00	0.00	0.00	0.00	60.88

Segment Leq : 60.88 dBA

Results segment # 2: Lyon (night)

Source height = 1.50 m

ROAD	(0.00 + 57.59 + 0.00) = 57.59 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	90	0.00	60.88	0.00	-0.28	-3.01	0.00	0.00	0.00	57.59

Segment Leq : 57.59 dBA

Total Leq All Segments: 62.55 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 70.15
 (NIGHT): 62.55

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 09:12:30
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r5.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : 0.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 15.00 / 15.00 m
Receiver height : 7.10 / 7.10 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

ROAD	(0.00 + 65.47 + 0.00) = 65.47 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----
0	90	0.00	68.48	0.00	0.00	-3.01	0.00	0.00	0.00	65.47
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Segment Leq : 65.47 dBA

Total Leq All Segments: 65.47 dBA

Results segment # 1: Slater (night)

Source height = 1.50 m

ROAD	(0.00 + 57.87 + 0.00) = 57.87 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----
0	90	0.00	60.88	0.00	0.00	-3.01	0.00	0.00	0.00	57.87
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Segment Leq : 57.87 dBA

Total Leq All Segments: 57.87 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 65.47
(NIGHT): 57.87

STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 09:12:36
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r6.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : -90.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 15.00 / 15.00 m
Receiver height : 7.10 / 7.10 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

ROAD	(0.00 + 68.48 + 0.00) = 68.48 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	68.48	0.00	0.00	0.00	0.00	0.00	0.00	68.48

Segment Leq : 68.48 dBA

Total Leq All Segments: 68.48 dBA

Results segment # 1: Slater (night)

Source height = 1.50 m

ROAD	(0.00 + 60.88 + 0.00) = 60.88 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	60.88	0.00	0.00	0.00	0.00	0.00	0.00	60.88

Segment Leq : 60.88 dBA

Total Leq All Segments: 60.88 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 68.48
(NIGHT): 60.88

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 09:12:44
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r7.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : 0.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 16.00 / 16.00 m
Receiver height : 7.10 / 7.10 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

```
Road data, segment # 2: Albert (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Albert (day/night)

```
Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 62.00 / 62.00 m
Receiver height : 7.10 / 7.10 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : -23.00 deg
Barrier height : 14.00 m
Barrier receiver distance : 47.00 / 47.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

ROAD	(0.00 + 65.19 + 0.00) = 65.19 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	90	0.00	68.48	0.00	-0.28	-3.01	0.00	0.00	0.00	65.19

Segment Leq : 65.19 dBA

Results segment # 2: Albert (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	! Receiver Height (m)	! Barrier Height (m)	! Elevation of Barrier Top (m)
1.50 !	7.10 !	2.85 !	2.85

ROAD	(0.00 + 40.79 + 53.38) = 53.61 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-23	0.00	68.48	0.00	-6.16	-4.29	0.00	0.00	-17.24	40.79
-23	0	0.00	68.48	0.00	-6.16	-8.94	0.00	0.00	0.00	53.38

Segment Leq : 53.61 dBA

Total Leq All Segments: 65.48 dBA

Results segment # 1: Slater (night)

Source height = 1.50 m

ROAD	(0.00 + 57.59 + 0.00) = 57.59 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	90	0.00	60.88	0.00	-0.28	-3.01	0.00	0.00	0.00	57.59

Segment Leq : 57.59 dBA



GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 2: Albert (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	! Receiver Height (m)	! Barrier Height (m)	! Elevation of Barrier Top (m)
1.50	7.10	2.85	2.85

ROAD (0.00 + 33.19 + 45.78) = 46.02 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-23	0.00	60.88	0.00	-6.16	-4.29	0.00	0.00	-17.24	33.19
-23	0	0.00	60.88	0.00	-6.16	-8.94	0.00	0.00	0.00	45.78

Segment Leq : 46.02 dBA

Total Leq All Segments: 57.88 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 65.48
(NIGHT): 57.88

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 22-08-2019 33:12:45
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r8.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 16.00 / 16.00 m
Receiver height : 7.10 / 7.10 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

```
Road data, segment # 2: Lyon (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Lyon (day/night)

```
Angle1 Angle2 : -90.00 deg -10.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 81.00 / 81.00 m
Receiver height : 7.10 / 7.10 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : -10.00 deg
Barrier height : 107.90 m
Barrier receiver distance : 14.00 / 14.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

```
Road data, segment # 3: Lyon 2 (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 3: Lyon 2 (day/night)

```
Angle1 Angle2 : -10.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 81.00 / 81.00 m
Receiver height : 7.10 / 7.10 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : 23.00 deg Angle2 : 90.00 deg
Barrier height : 8.00 m
Barrier receiver distance : 51.00 / 51.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

ROAD	(0.00 + 65.19 + 0.00) = 65.19 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	68.48	0.00	-0.28	-3.01	0.00	0.00	0.00	65.19

Segment Leq : 65.19 dBA

Results segment # 2: Lyon (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	7.10 !	6.13 !	6.13

ROAD	(0.00 + 37.74 + 0.00) = 37.74 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-10	0.00	68.48	0.00	-7.32	-3.52	0.00	0.00	-19.90	37.74

Segment Leq : 37.74 dBA

Results segment # 3: Lyon 2 (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	7.10 !	3.57 !	3.57

ROAD	(53.79 + 46.13 + 0.00) = 54.48 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-10	23	0.00	68.48	0.00	-7.32	-7.37	0.00	0.00	0.00	53.79
23	90	0.00	68.48	0.00	-7.32	-4.29	0.00	0.00	-10.74	46.13

Segment Leq : 54.48 dBA

Total Leq All Segments: 65.55 dBA

Results segment # 1: Slater (night)

Source height = 1.50 m

ROAD	(0.00 + 57.59 + 0.00) = 57.59 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	60.88	0.00	-0.28	-3.01	0.00	0.00	0.00	57.59

Segment Leq : 57.59 dBA

Results segment # 2: Lyon (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	7.10 !	6.13 !	6.13

ROAD	(0.00 + 30.14 + 0.00) = 30.14 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-10	0.00	60.88	0.00	-7.32	-3.52	0.00	0.00	-19.90	30.14

Segment Leq : 30.14 dBA

Results segment # 3: Lyon 2 (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	7.10 !	3.57 !	3.57

ROAD	(46.19 + 38.53 + 0.00) = 46.88 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-10	23	0.00	60.88	0.00	-7.32	-7.37	0.00	0.00	0.00	46.19
23	90	0.00	60.88	0.00	-7.32	-4.29	0.00	0.00	-10.74	38.53

Segment Leq : 46.88 dBA

Total Leq All Segments: 57.95 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 65.55
(NIGHT): 57.95

STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 09:12:58
 MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r9.te Time Period: Day/Night 16/8 hours
 Description:

Road data, segment # 1: Albert (day/night)

 Car traffic volume : 12144/1056 veh/TimePeriod *
 Medium truck volume : 966/84 veh/TimePeriod *
 Heavy truck volume : 690/60 veh/TimePeriod *
 Posted speed limit : 50 km/h
 Road gradient : 0 %
 Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
 Percentage of Annual Growth : 0.00
 Number of Years of Growth : 0.00
 Medium Truck % of Total Volume : 7.00
 Heavy Truck % of Total Volume : 5.00
 Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Albert (day/night)

 Angle1 Angle2 : -90.00 deg 90.00 deg
 Wood depth : 0 (No woods.)
 No of house rows : 0 / 0
 Surface : 2 (Reflective ground surface)
 Receiver source distance : 15.00 / 15.00 m
 Receiver height : 16.62 / 16.62 m
 Topography : 1 (Flat/gentle slope; no barrier)
 Reference angle : 0.00

```
Road data, segment # 2: Lyon (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Lyon (day/night)

```
Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 59.00 / 59.00 m
Receiver height : 16.62 / 16.62 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : -58.00 deg
Barrier height : 7.00 m
Barrier receiver distance : 32.00 / 32.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```



GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (day)

Source height = 1.50 m

ROAD	(0.00 + 68.48 + 0.00) = 68.48 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	68.48	0.00	0.00	0.00	0.00	0.00	0.00	68.48

Segment Leq : 68.48 dBA

Results segment # 2: Lyon (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	! Receiver Height (m)	! Barrier Height (m)	! Elevation of Barrier Top (m)
1.50 !	16.62 !	8.42 !	8.42

ROAD (0.00 + 55.03 + 57.61) = 59.52 dBA

ROAD	(0.00 + 55.03 + 57.61) = 59.52 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-58	0.00	68.48	0.00	-5.95	-7.50	0.00	0.00	-3.96	51.07*
-90	-58	0.00	68.48	0.00	-5.95	-7.50	0.00	0.00	0.00	55.03
-58	0	0.00	68.48	0.00	-5.95	-4.92	0.00	0.00	0.00	57.61

* Bright Zone !

Segment Leq : 59.52 dBA

Total Leq All Segments: 69.00 dBA

Results segment # 1: Albert (night)

Source height = 1.50 m

ROAD	(0.00 + 60.88 + 0.00) = 60.88 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	60.88	0.00	0.00	0.00	0.00	0.00	0.00	60.88

Segment Leq : 60.88 dBA

Results segment # 2: Lyon (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	! Receiver Height (m)	! Barrier Height (m)	! Elevation of Barrier Top (m)
1.50 !	16.62 !	8.42 !	8.42

ROAD (0.00 + 47.43 + 50.02) = 51.93 dBA

ROAD	(0.00 + 47.43 + 50.02) = 51.93 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-58	0.00	60.88	0.00	-5.95	-7.50	0.00	0.00	-3.96	43.47*
-90	-58	0.00	60.88	0.00	-5.95	-7.50	0.00	0.00	0.00	47.43
-58	0	0.00	60.88	0.00	-5.95	-4.92	0.00	0.00	0.00	50.02

* Bright Zone !

Segment Leq : 51.93 dBA

Total Leq All Segments: 61.40 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 69.00
(NIGHT): 61.40



STAMSON 5.0 NORMAL REPORT Date: 22-08-2019 33:12:55
 MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r10.te Time Period: Day/Night 16/8 hours
 Description:

Road data, segment # 1: Albert (day/night)

 Car traffic volume : 12144/1056 veh/TimePeriod *
 Medium truck volume : 966/84 veh/TimePeriod *
 Heavy truck volume : 690/60 veh/TimePeriod *
 Posted speed limit : 50 km/h
 Road gradient : 0 %
 Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
 Percentage of Annual Growth : 0.00
 Number of Years of Growth : 0.00
 Medium Truck % of Total Volume : 7.00
 Heavy Truck % of Total Volume : 5.00
 Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Albert (day/night)

 Angle1 Angle2 : 0.00 deg 90.00 deg
 Wood depth : 0 (No woods.)
 No of house rows : 0 / 0
 Surface : 2 (Reflective ground surface)
 Receiver source distance : 15.00 / 15.00 m
 Receiver height : 60.80 / 60.80 m
 Topography : 1 (Flat/gentle slope; no barrier)
 Reference angle : 0.00

GRADIENTWIND

ENGINEERS & SCIENTISTS

```
Road data, segment # 2: Lyon (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Lyon (day/night)

```
Angle1 Angle2 : -90.00 deg 36.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 51.00 / 51.00 m
Receiver height : 60.80 / 60.80 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : -66.00 deg
Barrier height : 8.00 m
Barrier receiver distance : 24.00 / 24.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

```
Road data, segment # 3: Lyon 2 (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 3: Lyon 2 (day/night)

```
Angle1 Angle2 : 36.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 51.00 / 51.00 m
Receiver height : 60.80 / 60.80 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : 36.00 deg Angle2 : 90.00 deg
Barrier height : 107.90 m
Barrier receiver distance : 37.00 / 37.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (day)

Source height = 1.50 m

ROAD	(0.00 + 65.47 + 0.00) = 65.47 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	90	0.00	68.48	0.00	0.00	-3.01	0.00	0.00	0.00	65.47

Segment Leq : 65.47 dBA

Results segment # 2: Lyon (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	60.80 !	32.89 !	32.89

ROAD	(0.00 + 54.41 + 60.70) = 61.62 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-66	0.00	68.48	0.00	-5.31	-8.75	0.00	0.00	-0.04	54.37*
-90	-66	0.00	68.48	0.00	-5.31	-8.75	0.00	0.00	0.00	54.41
-66	36	0.00	68.48	0.00	-5.31	-2.47	0.00	0.00	0.00	60.70

* Bright Zone !

Segment Leq : 61.62 dBA

Results segment # 3: Lyon 2 (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	60.80 !	17.78 !	17.78

ROAD	(0.00 + 38.19 + 0.00) = 38.19 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
36	90	0.00	68.48	0.00	-5.31	-5.23	0.00	0.00	-19.75	38.19

Segment Leq : 38.19 dBA

Total Leq All Segments: 66.97 dBA

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (night)

Source height = 1.50 m

ROAD	(0.00 + 57.87 + 0.00) = 57.87 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	90	0.00	60.88	0.00	0.00	-3.01	0.00	0.00	0.00	57.87

Segment Leq : 57.87 dBA

Results segment # 2: Lyon (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	60.80 !	32.89 !	32.89

ROAD	(0.00 + 46.82 + 53.10) = 54.02 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-66	0.00	60.88	0.00	-5.31	-8.75	0.00	0.00	-0.04	46.78*
-90	-66	0.00	60.88	0.00	-5.31	-8.75	0.00	0.00	0.00	46.82
-66	36	0.00	60.88	0.00	-5.31	-2.47	0.00	0.00	0.00	53.10

* Bright Zone !

Segment Leq : 54.02 dBA

Results segment # 3: Lyon 2 (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	60.80 !	17.78 !	17.78

ROAD	(0.00 + 30.59 + 0.00) = 30.59 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
36	90	0.00	60.88	0.00	-5.31	-5.23	0.00	0.00	-19.75	30.59

Segment Leq : 30.59 dBA

Total Leq All Segments: 59.37 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 66.97
 (NIGHT): 59.37

STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 09:13:17
 MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r11.te Time Period: Day/Night 16/8 hours
 Description:

Road data, segment # 1: Albert (day/night)

```
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 1: Albert (day/night)

```
-----
Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 15.00 / 15.00 m
Receiver height : 16.62 / 16.62 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : -31.00 deg
Barrier height : 9.00 m
Barrier receiver distance : 5.00 / 5.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	! Receiver Height (m)	! Barrier Height (m)	! Elevation of Barrier Top (m)
1.50	16.62	11.58	11.58

ROAD (0.00 + 63.64 + 60.84) = 65.47 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-31	0.00	68.48	0.00	0.00	-4.84	0.00	0.00	-0.41	63.22*
-90	-31	0.00	68.48	0.00	0.00	-4.84	0.00	0.00	0.00	63.64
-31	0	0.00	68.48	0.00	0.00	-7.64	0.00	0.00	0.00	60.84

* Bright Zone !

Segment Leq : 65.47 dBA

Total Leq All Segments: 65.47 dBA

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	16.62	11.58	11.58

ROAD (0.00 + 56.04 + 53.24) = 57.87 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-31	0.00	60.88	0.00	0.00	-4.84	0.00	0.00	-0.41	55.63*
-90	-31	0.00	60.88	0.00	0.00	-4.84	0.00	0.00	0.00	56.04
-31	0	0.00	60.88	0.00	0.00	-7.64	0.00	0.00	0.00	53.24

* Bright Zone !

Segment Leq : 57.87 dBA

Total Leq All Segments: 57.87 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 65.47
 (NIGHT): 57.87

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 22-08-2019 33:13:03
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r12.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : -90.00 deg 12.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 45.00 / 45.00 m
Receiver height : 24.85 / 24.85 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : -37.00 deg
Barrier height : 107.90 m
Barrier receiver distance : 34.00 / 34.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00

```
Road data, segment # 2: Slater 2 (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Slater 2 (day/night)

```
Angle1 Angle2 : 12.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 45.00 / 45.00 m
Receiver height : 24.85 / 24.85 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : 12.00 deg Angle2 : 90.00 deg
Barrier height : 123.60 m
Barrier receiver distance : 31.00 / 31.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```



GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	24.85	7.20	7.20

ROAD (0.00 + 38.56 + 58.06) = 58.11 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-37	0.00	68.48	0.00	-4.77	-5.31	0.00	0.00	-19.84	38.56
-37	12	0.00	68.48	0.00	-4.77	-5.65	0.00	0.00	0.00	58.06

Segment Leq : 58.11 dBA

Results segment # 2: Slater 2 (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	24.85	8.76	8.76

ROAD (0.00 + 40.17 + 0.00) = 40.17 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
12	90	0.00	68.48	0.00	-4.77	-3.63	0.00	0.00	-19.91	40.17

Segment Leq : 40.17 dBA

Total Leq All Segments: 58.18 dBA

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	24.85	7.20	7.20

ROAD (0.00 + 30.96 + 50.46) = 50.51 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-37	0.00	60.88	0.00	-4.77	-5.31	0.00	0.00	-19.84	30.96
-37	12	0.00	60.88	0.00	-4.77	-5.65	0.00	0.00	0.00	50.46

Segment Leq : 50.51 dBA

Results segment # 2: Slater 2 (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	24.85	8.76	8.76

ROAD (0.00 + 32.57 + 0.00) = 32.57 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
12	90	0.00	60.88	0.00	-4.77	-3.63	0.00	0.00	-19.91	32.57

Segment Leq : 32.57 dBA

Total Leq All Segments: 50.58 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 58.18
 (NIGHT): 50.58

STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 09:14:27
 MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r13.te Time Period: Day/Night 16/8 hours
 Description:

Road data, segment # 1: Albert (day/night)

```
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 1: Albert (day/night)

```
-----
Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 15.00 / 15.00 m
Receiver height : 24.85 / 24.85 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : -31.00 deg
Barrier height : 9.00 m
Barrier receiver distance : 5.00 / 5.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	24.85	17.07	17.07

ROAD (0.00 + 63.64 + 60.84) = 65.47 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-31	0.00	68.48	0.00	0.00	-4.84	0.00	0.00	-0.09	63.54*
-90	-31	0.00	68.48	0.00	0.00	-4.84	0.00	0.00	0.00	63.64
-31	0	0.00	68.48	0.00	0.00	-7.64	0.00	0.00	0.00	60.84

* Bright Zone !

Segment Leq : 65.47 dBA

Total Leq All Segments: 65.47 dBA

Results segment # 1: Albert (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	24.85	17.07	17.07

ROAD (0.00 + 56.04 + 53.24) = 57.87 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-31	0.00	60.88	0.00	0.00	-4.84	0.00	0.00	-0.09	55.95*
-90	-31	0.00	60.88	0.00	0.00	-4.84	0.00	0.00	0.00	56.04
-31	0	0.00	60.88	0.00	0.00	-7.64	0.00	0.00	0.00	53.24

* Bright Zone !

Segment Leq : 57.87 dBA

Total Leq All Segments: 57.87 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 65.47
 (NIGHT): 57.87

STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 09:14:35
 MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r14.te Time Period: Day/Night 16/8 hours
 Description:

Road data, segment # 1: Albert (day/night)

```
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 1: Albert (day/night)

```
-----
Angle1 Angle2 : 0.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 61.00 / 61.00 m
Receiver height : 49.83 / 49.83 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : 38.00 deg Angle2 : 90.00 deg
Barrier height : 70.00 m
Barrier receiver distance : 46.00 / 46.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```



```
Road data, segment # 2: Lyon (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Lyon (day/night)

```
Angle1 Angle2 : -90.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 20.00 / 20.00 m
Receiver height : 49.83 / 49.83 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00
```



```
Road data, segment # 3: Slater (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 3: Slater (day/night)

```
Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 18.00 / 18.00 m
Receiver height : 49.83 / 49.83 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00
```

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	49.83	13.38	13.38

ROAD $(55.63 + 37.52 + 0.00) = 55.70$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	38	0.00	68.48	0.00	-6.09	-6.75	0.00	0.00	0.00	55.63
38	90	0.00	68.48	0.00	-6.09	-5.39	0.00	0.00	-19.48	37.52

Segment Leq : 55.70 dBA

Results segment # 2: Lyon (day)

Source height = 1.50 m

ROAD $(0.00 + 67.23 + 0.00) = 67.23$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	68.48	0.00	-1.25	0.00	0.00	0.00	0.00	67.23

Segment Leq : 67.23 dBA

Results segment # 3: Slater (day)

Source height = 1.50 m

ROAD $(0.00 + 64.68 + 0.00) = 64.68$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	68.48	0.00	-0.79	-3.01	0.00	0.00	0.00	64.68

Segment Leq : 64.68 dBA

Total Leq All Segments: 69.34 dBA

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	49.83	13.38	13.38

ROAD $(48.04 + 29.92 + 0.00) = 48.10$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	38	0.00	60.88	0.00	-6.09	-6.75	0.00	0.00	0.00	48.04
38	90	0.00	60.88	0.00	-6.09	-5.39	0.00	0.00	-19.48	29.92

Segment Leq : 48.10 dBA

Results segment # 2: Lyon (night)

Source height = 1.50 m

ROAD $(0.00 + 59.63 + 0.00) = 59.63$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	60.88	0.00	-1.25	0.00	0.00	0.00	0.00	59.63

Segment Leq : 59.63 dBA

Results segment # 3: Slater (night)

Source height = 1.50 m

ROAD $(0.00 + 57.08 + 0.00) = 57.08$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	60.88	0.00	-0.79	-3.01	0.00	0.00	0.00	57.08

Segment Leq : 57.08 dBA

Total Leq All Segments: 61.74 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 69.34
(NIGHT): 61.74

STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 09:14:54
 MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r15.te Time Period: Day/Night 16/8 hours
 Description:

Road data, segment # 1: Lyon (day/night)

 Car traffic volume : 12144/1056 veh/TimePeriod *
 Medium truck volume : 966/84 veh/TimePeriod *
 Heavy truck volume : 690/60 veh/TimePeriod *
 Posted speed limit : 50 km/h
 Road gradient : 0 %
 Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
 Percentage of Annual Growth : 0.00
 Number of Years of Growth : 0.00
 Medium Truck % of Total Volume : 7.00
 Heavy Truck % of Total Volume : 5.00
 Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Lyon (day/night)

 Angle1 Angle2 : 0.00 deg 90.00 deg
 Wood depth : 0 (No woods.)
 No of house rows : 0 / 0
 Surface : 2 (Reflective ground surface)
 Receiver source distance : 23.00 / 23.00 m
 Receiver height : 49.83 / 49.83 m
 Topography : 1 (Flat/gentle slope; no barrier)
 Reference angle : 0.00

```
Road data, segment # 2: Slater (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Slater (day/night)

```
Angle1 Angle2 : -90.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 15.00 / 15.00 m
Receiver height : 49.83 / 49.83 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00
```



Results segment # 1: Lyon (day)

Source height = 1.50 m

ROAD	(0.00 + 63.61 + 0.00) = 63.61 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	90	0.00	68.48	0.00	-1.86	-3.01	0.00	0.00	0.00	63.61

Segment Leq : 63.61 dBA

Results segment # 2: Slater (day)

Source height = 1.50 m

ROAD	(0.00 + 68.48 + 0.00) = 68.48 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	68.48	0.00	0.00	0.00	0.00	0.00	0.00	68.48

Segment Leq : 68.48 dBA

Total Leq All Segments: 69.70 dBA

Results segment # 1: Lyon (night)

Source height = 1.50 m

ROAD	(0.00 + 56.02 + 0.00) = 56.02 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	90	0.00	60.88	0.00	-1.86	-3.01	0.00	0.00	0.00	56.02

Segment Leq : 56.02 dBA

Results segment # 2: Slater (night)

Source height = 1.50 m

ROAD	(0.00 + 60.88 + 0.00) = 60.88 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	60.88	0.00	0.00	0.00	0.00	0.00	0.00	60.88

Segment Leq : 60.88 dBA

Total Leq All Segments: 62.11 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 69.70
(NIGHT): 62.11

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 09:15:01
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r16.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : 0.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 17.00 / 17.00 m
Receiver height : 49.83 / 49.83 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

ROAD (0.00 + 64.93 + 0.00) = 64.93 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

0 90 0.00 68.48 0.00 -0.54 -3.01 0.00 0.00 0.00 64.93

Segment Leq : 64.93 dBA

Total Leq All Segments: 64.93 dBA

Results segment # 1: Slater (night)

Source height = 1.50 m

ROAD (0.00 + 57.33 + 0.00) = 57.33 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

0 90 0.00 60.88 0.00 -0.54 -3.01 0.00 0.00 0.00 57.33

Segment Leq : 57.33 dBA

Total Leq All Segments: 57.33 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 64.93
(NIGHT): 57.33



GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 22-08-2019 33:13:09
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r17.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 17.00 / 17.00 m
Receiver height : 49.83 / 49.83 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

```
Road data, segment # 2: Lyon (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Lyon (day/night)

```
Angle1 Angle2 : -90.00 deg 22.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 84.00 / 84.00 m
Receiver height : 49.83 / 49.83 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : 7.00 deg
Barrier height : 107.90 m
Barrier receiver distance : 70.00 / 70.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

```
Road data, segment # 3: Lyon2 (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 3: Lyon2 (day/night)

```
Angle1 Angle2 : 22.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 84.00 / 84.00 m
Receiver height : 49.83 / 49.83 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : 22.00 deg Angle2 : 90.00 deg
Barrier height : 7.00 m
Barrier receiver distance : 54.00 / 54.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

ROAD	(0.00 + 64.93 + 0.00) = 64.93 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	68.48	0.00	-0.54	-3.01	0.00	0.00	0.00	64.93

Segment Leq : 64.93 dBA

Results segment # 2: Lyon (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	49.83 !	9.55 !	9.55

ROAD	(0.00 + 38.44 + 50.21) = 50.49 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	7	0.00	68.48	0.00	-7.48	-2.69	0.00	0.00	-19.88	38.44
7	22	0.00	68.48	0.00	-7.48	-10.79	0.00	0.00	0.00	50.21

Segment Leq : 50.49 dBA

Results segment # 3: Lyon2 (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	49.83 !	18.76 !	18.76

ROAD	(0.00 + 56.77 + 0.00) = 56.77 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
22	90	0.00	68.48	0.00	-7.48	-4.23	0.00	0.00	-0.04	56.73*
22	90	0.00	68.48	0.00	-7.48	-4.23	0.00	0.00	0.00	56.77

* Bright Zone !

Segment Leq : 56.77 dBA

Total Leq All Segments: 65.68 dBA

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (night)

Source height = 1.50 m

ROAD	(0.00 + 57.33 + 0.00) = 57.33 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	60.88	0.00	-0.54	-3.01	0.00	0.00	0.00	57.33

Segment Leq : 57.33 dBA

Results segment # 2: Lyon (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	49.83 !	9.55 !	9.55

ROAD	(0.00 + 30.84 + 42.61) = 42.89 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	7	0.00	60.88	0.00	-7.48	-2.69	0.00	0.00	-19.88	30.84
7	22	0.00	60.88	0.00	-7.48	-10.79	0.00	0.00	0.00	42.61

Segment Leq : 42.89 dBA

Results segment # 3: Lyon2 (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	49.83 !	18.76 !	18.76

ROAD	(0.00 + 49.17 + 0.00) = 49.17 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
22	90	0.00	60.88	0.00	-7.48	-4.23	0.00	0.00	-0.04	49.13*
22	90	0.00	60.88	0.00	-7.48	-4.23	0.00	0.00	0.00	49.17

* Bright Zone !

Segment Leq : 49.17 dBA

Total Leq All Segments: 58.08 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 65.68
 (NIGHT): 58.08

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 14-02-2017 16:14:11
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r18.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : -90.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 15.00 / 15.00 m
Receiver height : 49.83 / 49.83 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

ROAD	(0.00 + 68.48 + 0.00) = 68.48 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	68.48	0.00	0.00	0.00	0.00	0.00	0.00	68.48

Segment Leq : 68.48 dBA

Total Leq All Segments: 68.48 dBA

Results segment # 1: Slater (night)

Source height = 1.50 m

ROAD	(0.00 + 60.88 + 0.00) = 60.88 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	60.88	0.00	0.00	0.00	0.00	0.00	0.00	60.88

Segment Leq : 60.88 dBA

Total Leq All Segments: 60.88 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 68.48
(NIGHT): 60.88

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 14-02-2017 16:14:28
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r19.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : 0.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 17.00 / 17.00 m
Receiver height : 49.83 / 49.83 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

ROAD (0.00 + 64.93 + 0.00) = 64.93 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

0 90 0.00 68.48 0.00 -0.54 -3.01 0.00 0.00 0.00 64.93

Segment Leq : 64.93 dBA

Total Leq All Segments: 64.93 dBA

Results segment # 1: Slater (night)

Source height = 1.50 m

ROAD (0.00 + 57.33 + 0.00) = 57.33 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

0 90 0.00 60.88 0.00 -0.54 -3.01 0.00 0.00 0.00 57.33

Segment Leq : 57.33 dBA

Total Leq All Segments: 57.33 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 64.93
(NIGHT): 57.33

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 14-02-2017 16:15:04
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r20.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Albert (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Albert (day/night)

Angle1 Angle2 : -90.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 42.00 / 42.00 m
Receiver height : 49.83 / 49.83 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : 48.00 deg Angle2 : 90.00 deg
Barrier height : 26.21 m
Barrier receiver distance : 29.00 / 29.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00



GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	49.83	16.46	16.46

ROAD (62.85 + 45.50 + 0.00) = 62.93 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	48	0.00	68.48	0.00	-4.47	-1.15	0.00	0.00	0.00	62.85
48	90	0.00	68.48	0.00	-4.47	-6.32	0.00	0.00	-12.19	45.50

Segment Leq : 62.93 dBA

Total Leq All Segments: 62.93 dBA

Results segment # 1: Albert (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	49.83	16.46	16.46

ROAD (55.26 + 37.90 + 0.00) = 55.34 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	48	0.00	60.88	0.00	-4.47	-1.15	0.00	0.00	0.00	55.26
48	90	0.00	60.88	0.00	-4.47	-6.32	0.00	0.00	-12.19	37.90

Segment Leq : 55.34 dBA

Total Leq All Segments: 55.34 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 62.93
 (NIGHT): 55.34

STAMSON 5.0 NORMAL REPORT Date: 14-02-2017 16:15:13
 MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r21.te Time Period: Day/Night 16/8 hours
 Description:

Road data, segment # 1: Albert (day/night)

```
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 1: Albert (day/night)

```
-----
Angle1 Angle2 : 0.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 61.00 / 61.00 m
Receiver height : 72.20 / 72.20 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : 38.00 deg Angle2 : 90.00 deg
Barrier height : 70.00 m
Barrier receiver distance : 46.00 / 46.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```



```
Road data, segment # 2: Lyon (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Lyon (day/night)

```
Angle1 Angle2 : -90.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 20.00 / 20.00 m
Receiver height : 72.20 / 72.20 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00
```



```
Road data, segment # 3: Slater (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 3: Slater (day/night)

```
Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 18.00 / 18.00 m
Receiver height : 72.20 / 72.20 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00
```



GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	72.20	18.88	18.88

ROAD (55.63 + 37.93 + 0.00) = 55.71 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	38	0.00	68.48	0.00	-6.09	-6.75	0.00	0.00	0.00	55.63
38	90	0.00	68.48	0.00	-6.09	-5.39	0.00	0.00	-19.07	37.93

Segment Leq : 55.71 dBA

Results segment # 2: Lyon (day)

Source height = 1.50 m

ROAD (0.00 + 67.23 + 0.00) = 67.23 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	68.48	0.00	-1.25	0.00	0.00	0.00	0.00	67.23

Segment Leq : 67.23 dBA

Results segment # 3: Slater (day)

Source height = 1.50 m

ROAD (0.00 + 64.68 + 0.00) = 64.68 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	68.48	0.00	-0.79	-3.01	0.00	0.00	0.00	64.68

Segment Leq : 64.68 dBA

Total Leq All Segments: 69.34 dBA

Results segment # 1: Albert (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	72.20	18.88	18.88

ROAD $(48.04 + 30.33 + 0.00) = 48.11$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	38	0.00	60.88	0.00	-6.09	-6.75	0.00	0.00	0.00	48.04
38	90	0.00	60.88	0.00	-6.09	-5.39	0.00	0.00	-19.07	30.33

Segment Leq : 48.11 dBA

Results segment # 2: Lyon (night)

Source height = 1.50 m

ROAD $(0.00 + 59.63 + 0.00) = 59.63$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	60.88	0.00	-1.25	0.00	0.00	0.00	0.00	59.63

Segment Leq : 59.63 dBA

Results segment # 3: Slater (night)

Source height = 1.50 m

ROAD $(0.00 + 57.08 + 0.00) = 57.08$ dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	60.88	0.00	-0.79	-3.01	0.00	0.00	0.00	57.08

Segment Leq : 57.08 dBA

Total Leq All Segments: 61.74 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 69.34
(NIGHT): 61.74



GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 14-02-2017 16:15:19
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r22.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Lyon (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Lyon (day/night)

Angle1 Angle2 : 0.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 23.00 / 23.00 m
Receiver height : 72.20 / 72.20 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

```
Road data, segment # 2: Slater (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Slater (day/night)

```
Angle1 Angle2 : -90.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 15.00 / 15.00 m
Receiver height : 72.20 / 72.20 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00
```



Results segment # 1: Lyon (day)

Source height = 1.50 m

ROAD	(0.00 + 63.61 + 0.00) = 63.61 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	90	0.00	68.48	0.00	-1.86	-3.01	0.00	0.00	0.00	63.61

Segment Leq : 63.61 dBA

Results segment # 2: Slater (day)

Source height = 1.50 m

ROAD	(0.00 + 68.48 + 0.00) = 68.48 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	68.48	0.00	0.00	0.00	0.00	0.00	0.00	68.48

Segment Leq : 68.48 dBA

Total Leq All Segments: 69.70 dBA

Results segment # 1: Lyon (night)

Source height = 1.50 m

ROAD	(0.00 + 56.02 + 0.00) = 56.02 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
0	90	0.00	60.88	0.00	-1.86	-3.01	0.00	0.00	0.00	56.02

Segment Leq : 56.02 dBA

Results segment # 2: Slater (night)

Source height = 1.50 m

ROAD	(0.00 + 60.88 + 0.00) = 60.88 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	60.88	0.00	0.00	0.00	0.00	0.00	0.00	60.88

Segment Leq : 60.88 dBA

Total Leq All Segments: 62.11 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 69.70
(NIGHT): 62.11

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 14-02-2017 16:15:28
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r23.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : 0.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 17.00 / 17.00 m
Receiver height : 72.20 / 72.20 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00



GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

ROAD (0.00 + 64.93 + 0.00) = 64.93 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

0 90 0.00 68.48 0.00 -0.54 -3.01 0.00 0.00 0.00 64.93

Segment Leq : 64.93 dBA

Total Leq All Segments: 64.93 dBA

Results segment # 1: Slater (night)

Source height = 1.50 m

ROAD (0.00 + 57.33 + 0.00) = 57.33 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

0 90 0.00 60.88 0.00 -0.54 -3.01 0.00 0.00 0.00 57.33

Segment Leq : 57.33 dBA

Total Leq All Segments: 57.33 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 64.93
(NIGHT): 57.33

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 22-08-2019 33:13:17
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r24.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 17.00 / 17.00 m
Receiver height : 72.20 / 72.20 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

```
Road data, segment # 2: Lyon (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Lyon (day/night)

```
Angle1 Angle2 : -90.00 deg 22.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 84.00 / 84.00 m
Receiver height : 72.20 / 72.20 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : 7.00 deg
Barrier height : 107.90 m
Barrier receiver distance : 70.00 / 70.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

```
Road data, segment # 3: Lyon2 (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 3: Lyon2 (day/night)

```
Angle1 Angle2 : 22.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 84.00 / 84.00 m
Receiver height : 72.20 / 72.20 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : 22.00 deg Angle2 : 90.00 deg
Barrier height : 7.00 m
Barrier receiver distance : 54.00 / 54.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	68.48	0.00	-0.54	-3.01	0.00	0.00	0.00	64.93

Segment Leq : 64.93 dBA

Results segment # 2: Lyon (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	72.20 !	13.28 !	13.28

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	7	0.00	68.48	0.00	-7.48	-2.69	0.00	0.00	-19.84	38.48
7	22	0.00	68.48	0.00	-7.48	-10.79	0.00	0.00	0.00	50.21

Segment Leq : 50.49 dBA

Results segment # 3: Lyon2 (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	72.20 !	26.75 !	26.75

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
22	90	0.00	68.48	0.00	-7.48	-4.23	0.00	0.00	-0.02	56.75*
22	90	0.00	68.48	0.00	-7.48	-4.23	0.00	0.00	0.00	56.77

* Bright Zone !

Segment Leq : 56.77 dBA

Total Leq All Segments: 65.68 dBA

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (night)

Source height = 1.50 m

ROAD	(0.00 + 57.33 + 0.00) = 57.33 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	60.88	0.00	-0.54	-3.01	0.00	0.00	0.00	57.33

Segment Leq : 57.33 dBA

Results segment # 2: Lyon (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	72.20 !	13.28 !	13.28

ROAD	(0.00 + 30.88 + 42.61) = 42.89 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	7	0.00	60.88	0.00	-7.48	-2.69	0.00	0.00	-19.84	30.88
7	22	0.00	60.88	0.00	-7.48	-10.79	0.00	0.00	0.00	42.61

Segment Leq : 42.89 dBA

Results segment # 3: Lyon2 (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	! Elevation of
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)
1.50 !	72.20 !	26.75 !	26.75

ROAD	(0.00 + 49.17 + 0.00) = 49.17 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
22	90	0.00	60.88	0.00	-7.48	-4.23	0.00	0.00	-0.02	49.15*
22	90	0.00	60.88	0.00	-7.48	-4.23	0.00	0.00	0.00	49.17

* Bright Zone !

Segment Leq : 49.17 dBA

Total Leq All Segments: 58.08 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 65.68
 (NIGHT): 58.08

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 14-02-2017 16:15:45
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r25.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : -90.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 15.00 / 15.00 m
Receiver height : 72.20 / 72.20 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

ROAD	(0.00 + 68.48 + 0.00) = 68.48 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	68.48	0.00	0.00	0.00	0.00	0.00	0.00	68.48

Segment Leq : 68.48 dBA

Total Leq All Segments: 68.48 dBA

Results segment # 1: Slater (night)

Source height = 1.50 m

ROAD	(0.00 + 60.88 + 0.00) = 60.88 dBA									
Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	90	0.00	60.88	0.00	0.00	0.00	0.00	0.00	0.00	60.88

Segment Leq : 60.88 dBA

Total Leq All Segments: 60.88 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 68.48
(NIGHT): 60.88

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 14-02-2017 16:15:52
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r26.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Slater (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Slater (day/night)

Angle1 Angle2 : 0.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 17.00 / 17.00 m
Receiver height : 72.20 / 72.20 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

ROAD (0.00 + 64.93 + 0.00) = 64.93 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

0 90 0.00 68.48 0.00 -0.54 -3.01 0.00 0.00 0.00 64.93

Segment Leq : 64.93 dBA

Total Leq All Segments: 64.93 dBA

Results segment # 1: Slater (night)

Source height = 1.50 m

ROAD (0.00 + 57.33 + 0.00) = 57.33 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj B.Adj SubLeq

0 90 0.00 60.88 0.00 -0.54 -3.01 0.00 0.00 0.00 57.33

Segment Leq : 57.33 dBA

Total Leq All Segments: 57.33 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 64.93
(NIGHT): 57.33



STAMSON 5.0 NORMAL REPORT Date: 15-02-2017 11:07:41
 MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r27.te Time Period: Day/Night 16/8 hours
 Description:

Road data, segment # 1: Slater (day/night)

```
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 1: Slater (day/night)

```
-----
Angle1 Angle2 : -90.00 deg 35.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 42.00 / 42.00 m
Receiver height : 49.83 / 49.83 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : -43.00 deg
Barrier height : 26.20 m
Barrier receiver distance : 29.00 / 29.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

```
Road data, segment # 2: Slater 2 (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Slater 2 (day/night)

```
Angle1 Angle2 : 35.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 42.00 / 42.00 m
Receiver height : 49.83 / 49.83 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : 35.00 deg Angle2 : 90.00 deg
Barrier height : 70.00 m
Barrier receiver distance : 28.00 / 28.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

GRADIENTWIND

ENGINEERS & SCIENTISTS

Road data, segment # 3: Lyon (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *

Medium truck volume : 966/84 veh/TimePeriod *

Heavy truck volume : 690/60 veh/TimePeriod *

Posted speed limit : 50 km/h

Road gradient : 0 %

Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 3: Lyon (day/night)

Angle1 Angle2 : -90.00 deg 0.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 24.00 / 24.00 m
Receiver height : 49.83 / 49.83 m
Topography : 1 (Flat/gentle slope; no barrier)
Reference angle : 0.00

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	Elevation of		
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)		
1.50 !	49.83 !	16.46 !	16.46		

ROAD (0.00 + 45.66 + 60.38) = 60.52 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-43	0.00	68.48	0.00	-4.47	-5.83	0.00	0.00	-12.51	45.66
-43	35	0.00	68.48	0.00	-4.47	-3.63	0.00	0.00	0.00	60.38

Segment Leq : 60.52 dBA

Results segment # 2: Slater 2 (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source	! Receiver	! Barrier	Elevation of		
Height (m)	! Height (m)	! Height (m)	! Barrier Top (m)		
1.50 !	49.83 !	17.61 !	17.61		

ROAD (0.00 + 39.38 + 0.00) = 39.38 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
35	90	0.00	68.48	0.00	-4.47	-5.15	0.00	0.00	-19.48	39.38

Segment Leq : 39.38 dBA

Results segment # 3: Lyon (day)

Source height = 1.50 m

ROAD (0.00 + 63.43 + 0.00) = 63.43 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	68.48	0.00	-2.04	-3.01	0.00	0.00	0.00	63.43

Segment Leq : 63.43 dBA

Total Leq All Segments: 65.24 dBA

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Slater (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	49.83	16.46	16.46

ROAD (0.00 + 38.07 + 52.78) = 52.92 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-43	0.00	60.88	0.00	-4.47	-5.83	0.00	0.00	-12.51	38.07
-43	35	0.00	60.88	0.00	-4.47	-3.63	0.00	0.00	0.00	52.78

Segment Leq : 52.92 dBA

Results segment # 2: Slater 2 (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	49.83	17.61	17.61

ROAD (0.00 + 31.78 + 0.00) = 31.78 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
35	90	0.00	60.88	0.00	-4.47	-5.15	0.00	0.00	-19.48	31.78

Segment Leq : 31.78 dBA

Results segment # 3: Lyon (night)

Source height = 1.50 m

ROAD (0.00 + 55.83 + 0.00) = 55.83 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	0	0.00	60.88	0.00	-2.04	-3.01	0.00	0.00	0.00	55.83

Segment Leq : 55.83 dBA

Total Leq All Segments: 57.64 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 65.24
(NIGHT): 57.64

GRADIENTWIND

ENGINEERS & SCIENTISTS

STAMSON 5.0 NORMAL REPORT Date: 22-08-2019 33:13:33
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r29.te Time Period: Day/Night 16/8 hours
Description:

Road data, segment # 1: Albert1 (day/night)

Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)

* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00

Data for Segment # 1: Albert1 (day/night)

Angle1 Angle2 : -90.00 deg -40.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 24.00 / 24.00 m
Receiver height : 17.50 / 17.50 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : -40.00 deg
Barrier height : 62.30 m
Barrier receiver distance : 14.00 / 14.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00

```
Road data, segment # 2: Albert2 (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 2: Albert2 (day/night)

```
Angle1 Angle2 : -40.00 deg 79.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 24.00 / 24.00 m
Receiver height : 17.50 / 17.50 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -40.00 deg Angle2 : 79.00 deg
Barrier height : 16.00 m
Barrier receiver distance : 14.00 / 14.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

```
Road data, segment # 3: Lyon1 (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 3: Lyon1 (day/night)

```
Angle1 Angle2 : -90.00 deg 39.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 32.00 / 32.00 m
Receiver height : 17.50 / 17.50 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : -90.00 deg Angle2 : 39.00 deg
Barrier height : 16.00 m
Barrier receiver distance : 12.00 / 12.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

```
Road data, segment # 4: Lyon2 (day/night)
-----
Car traffic volume : 12144/1056 veh/TimePeriod *
Medium truck volume : 966/84 veh/TimePeriod *
Heavy truck volume : 690/60 veh/TimePeriod *
Posted speed limit : 50 km/h
Road gradient : 0 %
Road pavement : 1 (Typical asphalt or concrete)
```

* Refers to calculated road volumes based on the following input:

```
24 hr Traffic Volume (AADT or SADT): 15000
Percentage of Annual Growth : 0.00
Number of Years of Growth : 0.00
Medium Truck % of Total Volume : 7.00
Heavy Truck % of Total Volume : 5.00
Day (16 hrs) % of Total Volume : 92.00
```

Data for Segment # 4: Lyon2 (day/night)

```
Angle1 Angle2 : 39.00 deg 90.00 deg
Wood depth : 0 (No woods.)
No of house rows : 0 / 0
Surface : 2 (Reflective ground surface)
Receiver source distance : 32.00 / 32.00 m
Receiver height : 17.50 / 17.50 m
Topography : 2 (Flat/gentle slope; with barrier)
Barrier angle1 : 39.00 deg Angle2 : 90.00 deg
Barrier height : 107.90 m
Barrier receiver distance : 12.00 / 12.00 m
Source elevation : 0.00 m
Receiver elevation : 0.00 m
Barrier elevation : 0.00 m
Reference angle : 0.00
```

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 1: Albert1 (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	17.50	8.16	8.16

ROAD (0.00 + 41.17 + 0.00) = 41.17 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-40	0.00	68.48	0.00	-2.04	-5.56	0.00	0.00	-19.70	41.17

Segment Leq : 41.17 dBA

Results segment # 2: Albert2 (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	17.50	8.16	8.16

ROAD (0.00 + 45.23 + 0.00) = 45.23 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-40	79	0.00	68.48	0.00	-2.04	-1.80	0.00	0.00	-19.42	45.23

Segment Leq : 45.23 dBA

Results segment # 3: Lyon1 (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	17.50	11.50	11.50

ROAD (0.00 + 49.28 + 0.00) = 49.28 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	39	0.00	68.48	0.00	-3.29	-1.45	0.00	0.00	-14.46	49.28

Segment Leq : 49.28 dBA



GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 4: Lyon2 (day)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	17.50	11.50	11.50

ROAD (0.00 + 39.86 + 0.00) = 39.86 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
39	90	0.00	68.48	0.00	-3.29	-5.48	0.00	0.00	-19.85	39.86

Segment Leq : 39.86 dBA

Total Leq All Segments: 51.49 dBA

Results segment # 1: Albert1 (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	17.50	8.16	8.16

ROAD (0.00 + 33.58 + 0.00) = 33.58 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	-40	0.00	60.88	0.00	-2.04	-5.56	0.00	0.00	-19.70	33.58

Segment Leq : 33.58 dBA

GRADIENTWIND

ENGINEERS & SCIENTISTS

Results segment # 2: Albert2 (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	17.50	8.16	8.16

ROAD (0.00 + 37.63 + 0.00) = 37.63 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-40	79	0.00	60.88	0.00	-2.04	-1.80	0.00	0.00	-19.42	37.63

Segment Leq : 37.63 dBA

Results segment # 3: Lyon1 (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	17.50	11.50	11.50

ROAD (0.00 + 41.69 + 0.00) = 41.69 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
-90	39	0.00	60.88	0.00	-3.29	-1.45	0.00	0.00	-14.46	41.69

Segment Leq : 41.69 dBA

Results segment # 4: Lyon2 (night)

Source height = 1.50 m

Barrier height for grazing incidence

Source Height (m)	Receiver Height (m)	Barrier Height (m)	Elevation of Barrier Top (m)
1.50	17.50	11.50	11.50

ROAD (0.00 + 32.26 + 0.00) = 32.26 dBA

Angle1	Angle2	Alpha	RefLeq	P.Adj	D.Adj	F.Adj	W.Adj	H.Adj	B.Adj	SubLeq
39	90	0.00	60.88	0.00	-3.29	-5.48	0.00	0.00	-19.85	32.26

Segment Leq : 32.26 dBA

Total Leq All Segments: 43.89 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 51.49
 (NIGHT): 43.89