



November 8, 2019

Mr. Stream Shen, MCIP RPP
Planner II
Development West
City of Ottawa, ON

Stream.shen@ottawa.ca

Re: OTT-00250806-A-C

Review of Grading Plan
Proposed Residential Development. Hazeldean Crossing
5924 and 5938 Hazeldean Road, City of Ottawa, ON

We have reviewed the grading plans prepared by EXP for this project and specifically Drawing C200-Rev 3, dated November 5, 2019 under Project OTT-00250806-B0.

The review indicates a proposed grade raise of up to 3 m which is considered acceptable from a geotechnical point of view as the site is underlain by shallow bedrock.

Should you have any questions, please do not hesitate to contact this office.

Yours truly,

A handwritten signature in blue ink, appearing to read "Ismail Taki".

Ismail Taki, P. Eng.
Manager, Senior Geotechnical Engineer
Earth & Environment

