



## Smith + Andersen

1600 Carling Ave Suite 530 Ottawa Ontario K1Z 1G3  
613 230 1186 f 613 230 2598 [smithandandersen.com](http://smithandandersen.com)

2022-08-29

### City of Ottawa

Infrastructure Services and Community Sustainability  
110 Laurier Avenue West  
Ottawa, ON  
K1P 1J1

**Attention: City Building Official**

**RE: ZIBI BLOCK 204, 315 PRIVÉ MIWÀTE PRIVATE  
S+A PROJECT # 22087.000.M.001  
SPRINKLER SYSTEM DESIGN**

Dear City Building Official:

This letter is to confirm that the sprinkler system will be designed as a fully supervised system that will be continuously monitored with fire alarm. System shall be designed to NFPA 13 and conform to all applicable NFPA standards.

Yours truly,

SMITH + ANDERSEN

Elaine Guenette B.A.Sc., P.Eng., LEED AP  
Principal

22087.000.m.001.I001

C.C. Justin Alarie – Smith + Andersen

