

July 7, 2026  
File: 160402328

**Attention: Andrew McCreight**  
City of Ottawa  
Development Review – Central Branch  
110 Laurier Avenue West  
Ottawa, ON K1P 1J1

Good day Mr. McCreight,

**Reference: Functional Site Servicing Review – 35 Laurel Street (Previously 75 Breezehill Avenue North): Building Height Increase Memorandum**

Stantec Consulting Ltd. (Stantec) is commissioned by 2729685 Ontario Inc. to prepare this Functional Site Servicing Review Memorandum for the proposed infill re-development at 35 Laurel Street in the City of Ottawa. The site includes a proposed mixed-use development with ground-level commercial occupancy, shared underground parking, and two residential high-rise towers.

Stantec previously provided Civil Engineering Services for this project in support of the Official Plan Amendment (OPA) and Zoning By-law Amendment (ZBLA). The *Functional Site Servicing and Stormwater Management Report – 35 Laurel Street (Previously 75 Breezehill Avenue) Revision 1*, and drawings GP-1 and SSP-1 (Rev.3, 24.12.04) were prepared and submitted to the City for review by Stantec in December 2024. In Revision 1 of the report, Buildings A and B were to include a total of 27 and 29 above-ground storeys, respectively. In the revised Site Plan provided by RLA Architecture, dated February 16, 2026 (see **Appendix A**), four (4) additional floors are added to the height of each building, including a further sixty-four (64) residential units. The revised building attributes and statistics are listed in **Table 1**.

**Table 0: Revised Attributes of Proposed Buildings**

| Use/Attribute                      | Revision 1 (Dec 2024) |            |            | Revision 2 (July 2026) |            |            |
|------------------------------------|-----------------------|------------|------------|------------------------|------------|------------|
|                                    | Total                 | Building A | Building B | Total                  | Building A | Building B |
| Number of Above Ground Storeys     |                       |            |            |                        |            |            |
| Podium                             | -                     | 6          | 6          | -                      | 6          | 6          |
| High-Rise Tower                    | -                     | 21         | 23         | -                      | 25         | 27         |
| <b>Total</b>                       | -                     | <b>27</b>  | <b>29</b>  | -                      | <b>31</b>  | <b>33</b>  |
| Underground Parking Levels         | 2                     | -          | -          | 2                      | -          | -          |
| Commercial (m <sup>2</sup> )       | 429                   | 0          | 429        | 425                    | 0          | 425        |
| Residential Apartment Rental Units | 479                   | 232        | 247        | 543                    | 264        | 279        |
| Residential Apartment Unit Types   |                       |            |            |                        |            |            |
| Studio                             | <b>48</b>             | 25         | 23         | <b>56</b>              | 29         | 27         |
| One-bedroom                        | <b>131</b>            | 51         | 80         | <b>151</b>             | 59         | 92         |
| One-bedroom with Study             | <b>77</b>             | 29         | 48         | <b>85</b>              | 33         | 52         |
| Two-bedroom                        | <b>193</b>            | 117        | 76         | <b>221</b>             | 133        | 88         |
| Three-bedroom                      | <b>30</b>             | 10         | 20         | <b>30</b>              | 10         | 20         |

Reference: Functional Site Servicing Review – 35 Laurel Street (Previously 75 Breezehill Avenue North): Building Height Increase Memorandum

The purpose of this memorandum is to demonstrate that the functional servicing scheme proposed in Revision 1 and adjacent municipal infrastructure is adequate to support the building height increase and additional units. The domestic water demand, hydraulic analysis, wastewater peak flows, and sanitary sewer design have been revised to reflect the increased number of units and projected population. The findings are summarized in the following sections.

PROJECTED POPULATION

Based on the densities outlined in Table 4.1 of the *City of Ottawa Water Distribution Design Guidelines (WDG002) 2<sup>nd</sup> Edition*, December 8, 2025, the projected population for the development increased from 911 persons to 1,025 persons.

POTABLE WATER DEMANDS

Water demand for the development was estimated using the same demand rates and peaking factors as Revision 1, the residential demand rate of 280 L/cap/day and the commercial demand rate of 28,000 L/ha/day for the proposed commercial floor areas. The increase in residential population resulted in additional average day demand (AVDY) of 0.3 L/s, maximum day demand (MXDY) of 0.9 L/s, and peak hour demand (PKHR) of 2.0 L/s. See **Appendix B.1** for detailed calculations as summarized in **Table 2**.

Table 2: Estimated Water Demands

|             | Revision 1 (Dec 2024) |            |            |            | Revision 2 (July 2026) |            |            |            |
|-------------|-----------------------|------------|------------|------------|------------------------|------------|------------|------------|
| Demand Type | Area (ha)             | AVDY (L/s) | MXDY (L/s) | PKHR (L/s) | Area (ha)              | AVDY (L/s) | MXDY (L/s) | PKHR (L/s) |
| Commercial  | 0.04                  | 0.01       | 0.02       | 0.04       | 0.04                   | 0.01       | 0.02       | 0.04       |
| Residential | -                     | 3.0        | 7.4        | 16.2       | -                      | 3.32       | 8.31       | 18.28      |
| Total Site  | 0.04                  | 3.0        | 7.4        | 16.3       | 0.04                   | 3.3        | 8.3        | 18.3       |
| Increase    | -                     | -          | -          | -          | -                      | 0.3        | 0.9        | 2.0        |

FIRE FLOW DEMANDS

The revised Site Plan (Feb 2026) did not significantly change the gross floor areas of the podium, nor the tower compared to Revision 1 (Dec 2024). Based on the non-combustible construction type, full sprinkler coverage, and no detectable change to the exposures to the adjacent buildings, it was verified that the worst-case required fire flow for the site remains unchanged at 4,000 L/min (67 L/s). See **Appendix B.2** for the FUS calculations.

HYDRAULIC ASSESSMENT

The available water flow and pressures from the existing watermain in Laurel Street were previously obtained from the City of Ottawa, as Boundary Conditions included in **Appendix B.3** and summarized in **Table 3**. The available boundary conditions included the previous 30- and 35-storey scenario (Revision 0). The City confirmed there were no significant changes to the boundary conditions for the 27- and 29-storey scenario (Revision 1). Since the new scenario (Revision 2) with building heights of 31- and 33-storeys falls between

**Reference:** Functional Site Servicing Review – 35 Laurel Street (Previously 75 Breezehill Avenue North): Building Height Increase Memorandum

the two previous scenarios, we have assumed the Boundary Conditions for Revision 0 can still be applied. It is assumed that the ground floor elevation remains unchanged from Revision 1 at 64.44m, Consequently, the hydraulic analysis of residual pressures at ground level also remains unchanged. The anticipated pressures are within the acceptable range under both normal and emergency fire flow demand scenarios. The proposed functional Water Servicing, as presented in Revision 1 (Dec, 2024) is found to be adequate to support the additional stories and projected population of the development.

**Table 3: Functional Hydraulic Analysis and Boundary Conditions**

| Condition              | Laurel Street<br>14-Nov-2023<br>(HGL, m) | Revision 0<br>30- and 35-<br>Storeys<br>Demand (L/s) | Revision 2<br>31- and 33-<br>Storeys<br>Demand (L/s) | Residual<br>Ground Floor<br>Pressure<br>(kPa) | Residual<br>Ground Floor<br>Pressure<br>(psi) |
|------------------------|------------------------------------------|------------------------------------------------------|------------------------------------------------------|-----------------------------------------------|-----------------------------------------------|
| PKHR Min. HGL          | 107.4                                    | 18.4                                                 | 18.3                                                 | 421.2                                         | 61.1                                          |
| AVDY Max. HGL          | 115.1                                    | 3.4                                                  | 3.3                                                  | 496.7                                         | 72.0                                          |
| Max. Day + FF (67 L/s) | 104.3                                    | 75.1                                                 | 75.0                                                 | 390.8                                         | 56.7                                          |

## WASTEWATER

Peak wastewater flows for the proposed development were estimated using the same generation rates as Revision 1, the residential demand rate of 280 L/cap/day, the commercial demand rate of 28,000 L/ha/day for the proposed commercial floor areas, and the infiltration inflow rate of 0.33L/s/ha as per the *City of Ottawa Sewer Design Guidelines (SDG 004) 4th Edition* (December 2025). The sanitary sewer design sheet was revised to accommodate the additional 64 residential apartment units, as shown in the **Appendix C.1**. The estimated peak wastewater flow is summarized in **Table 4**. The total estimated wastewater peak flow for Revision 2 is **11.0 L/s**, which is an increase of 1.2 L/s compared to Revision 1.

**Table 4: Estimated Peak Wastewater Flow**

|                        | Peak Residential Wastewater Flow |                |                    | Commercial<br>Wastewater<br>Flow (L/s) | Infiltration<br>Flow<br>(L/s) | Total Peak<br>Flow<br>(L/s) |
|------------------------|----------------------------------|----------------|--------------------|----------------------------------------|-------------------------------|-----------------------------|
|                        | Population                       | Peak<br>Factor | Peak Flow<br>(L/s) |                                        |                               |                             |
| Revision 2 (July 2027) | 1025                             | 3.234          | 10.7               | 0.02                                   | 0.2                           | 11.0                        |
| Revision 1 (Dec 2024)  | 911                              | 3.261          | 9.6                | 0.02                                   | 0.2                           | 9.8                         |
| <b>Difference</b>      | <b>114</b>                       | <b>-0.027</b>  | <b>1.1</b>         | <b>0</b>                               | <b>0</b>                      | <b>1.2</b>                  |

## PROPOSED SANITARY SERVICING

The servicing strategy remains the same as presented in the Revision 1 (Dec 2024) functional servicing report, which proposes to discharge wastewater from both buildings into the 1050mm diameter sanitary trunk sewer in Laurel Street via the proposed 200mm diameter sanitary service lateral. The sanitary sewer design sheet demonstrates that the sanitary lateral is adequately sized. The City of Ottawa staff have previously confirmed that the receiving 1050mm diameter sanitary sewer on Laurel Street has a downstream capacity which is sufficient to receive the wastewater flow generated from this site.

Reference: Functional Site Servicing Review – 35 Laurel Street (Previously 75 Breezehill Avenue North): Building Height Increase Memorandum

## STORMWATER


The Revision 2 proposed building height increase does not affect the stormwater management requirements, nor does it affect the proposed building storm servicing for this site compared to Revision 1.

## CONCLUSIONS

This memorandum has demonstrated the proposed building height increase for 35 Laurel Street can be adequately serviced based on the Servicing Scheme proposed by Stantec in the December 2024 *Functional Site Servicing and Stormwater Management Report – 35 Laurel Street (Previously 75 Breezehill Avenue) Revision 1*, and drawings GP-1 and SSP-1 (Rev.3, 24.12.04). We trust this addresses the City of Ottawa's concerns to your satisfaction. Should you have any further questions, please do not hesitate to contact the undersigned.

Regards,

**Stantec Consulting Ltd.**



---

**Ziyi Wang**  
Engineering Graduate  
Phone: 613 784 2305  
Ziyi.Wang@stantec.com



---

**Alyssa Gladish P.Eng.**  
Project Engineer  
Phone: 587 7211241  
Alyssa.Gladish@stantec.com

Attachments: Appendix A: Site Plan – 35 Laurel Street  
Appendix B: Functional Water Servicing  
B.1 Domestic Demand Calculations  
B.2 FUS Calculations  
B.3 Boundary Conditions  
Appendix C: Functional Sanitary Servicing  
C.1 Sanitary Sewer Design Sheet  
C.2 Correspondence for Downstream Sewer Capacity

**Reference:** Functional Site Servicing Review – 35 Laurel Street (Previously 75 Breezehill Avenue North): Building Height Increase Memorandum

## **Appendix A**      **Site Plan (February 2026)**



|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>5\$;1* 127(6</p> <p>3523(57&lt; 2.1(5</p> <p>5( 816.257+<br/>2WWDZD 21<br/>( 0DLO, IJBXQVZRUKW#URJHUV</p> <p>1/(\$/ 6&amp;5,37,21</p> <p>6859(&lt;25 6 5(\$/ 3523(57&lt; 5(3257<br/>/27 %/2&amp;. %<br/>35576 RI /276<br/>50\$// 2) /276 ( \$1' "</p> <p>50&amp;25(77\$ \$9(<br/>5',67(5' 3/\$1<br/>&amp;7&lt; 2) 277\$:\$<br/>6XUYHIG EI 6WDQWHF *HRPDWLF</p> <p>6859(&lt;25<br/>6WDQWHF *HRPDWLFV /W<br/>2QWDULR /DQG 6XUYHURV<br/>&amp;OIGH SYHQXH 6XLWH<br/>2WWDZD 2QWDULR . &amp; *<br/>7HO.<br/>( 0DLO, EULDQ ZHEVWUHVW</p> <p>85%\$1 3/\$11(5<br/>)RWHQQ &amp;RQVXOWDQWV<br/>OF/HRG 6WUHHW<br/>2WWDZD 21 &amp;DQDGD . 3 =<br/>7HO.<br/>( 0DLEHGH#IRWHQQ FRP</p> <p>&amp;9, / (1*,1(5<br/>6WDQWHF &amp;LYLO /WG<br/>&amp;LYLO (QJLQHULQJ<br/>&amp;OIGH SYHQXH 6XLWH<br/>2WWDZD 2QWDULR . &amp; *<br/>7HO.<br/>( 0DLO, \$OIVVD *ODGLVK#VW</p> | <p>352-( &amp;7 ,1)250\$7,21</p> <p>3523(57&lt; 2.1(5</p> <p>5( 816.257+<br/>2WWDZD 21<br/>( 0DLO, IJBXQVZRUKW#URJHUV</p> <p>1/(\$/ 6&amp;5,37,21</p> <p>6859(&lt;25 6 5(\$/ 3523(57&lt; 5(3257<br/>/27 %/2&amp;. %<br/>35576 RI /276<br/>50\$// 2) /276 ( \$1' "</p> <p>50&amp;25(77\$ \$9(<br/>5',67(5' 3/\$1<br/>&amp;7&lt; 2) 277\$:\$<br/>6XUYHIG EI 6WDQWHF *HRPDWLF</p> <p>6859(&lt;25<br/>6WDQWHF *HRPDWLFV /W<br/>2QWDULR /DQG 6XUYHURV<br/>&amp;OIGH SYHQXH 6XLWH<br/>2WWDZD 2QWDULR . &amp; *<br/>7HO.<br/>( 0DLO, EULDQ ZHEVWUHVW</p> <p>85%\$1 3/\$11(5<br/>)RWHQQ &amp;RQVXOWDQWV<br/>OF/HRG 6WUHHW<br/>2WWDZD 21 &amp;DQDGD . 3 =<br/>7HO.<br/>( 0DLEHGH#IRWHQQ FRP</p> <p>&amp;9, / (1*,1(5<br/>6WDQWHF &amp;LYLO /WG<br/>&amp;LYLO (QJLQHULQJ<br/>&amp;OIGH SYHQXH 6XLWH<br/>2WWDZD 2QWDULR . &amp; *<br/>7HO.<br/>( 0DLO, \$OIVVD *ODGLVK#VW</p> |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Reference:** Functional Site Servicing Review – 35 Laurel Street (Previously 75 Breezehill Avenue North): Building Height Increase Memorandum

## **Appendix B**      **Functional Water Servicing**

### **B.1 Domestic Demand Calculations**

**35 Laurel Street (75 Breezehill Avenue North), Ottawa, ON - Domestic Water Demand Estimates**

Site Plan provided by RLA Architecture (2026-02-16)

Stantec Project No. 160401738 / 160402328

Created By: P. Mott

Date Created: 6/13/2023

Checked By: A. Gladish

Revision No. 3

Revision Date: 6/17/2026

Revision By: Z. Wang

| Densities as per City Guidelines: |     |     |
|-----------------------------------|-----|-----|
| Apartment Units                   |     |     |
| Studio                            | 1.4 | ppu |
| 1 Bedroom                         | 1.4 | ppu |
| 1 Bedroom + Study                 | 2.1 | ppu |
| 2 Bedroom                         | 2.1 | ppu |
| 3 Bedroom                         | 3.1 | ppu |



| Building ID             | Commerical Area (m²) | No. of Units | Population¹ | Daily Rate of Demand ² ³<br>(L/cap/day or L/ha/day) | Avg Day Demand |       | Max Day Demand ⁴ ⁵ |       | Peak Hour Demand ⁴ ⁵ |       |
|-------------------------|----------------------|--------------|-------------|-----------------------------------------------------|----------------|-------|--------------------|-------|----------------------|-------|
|                         |                      |              |             |                                                     | (L/min)        | (L/s) | (L/min)            | (L/s) | (L/min)              | (L/s) |
| Building A & Building B |                      |              |             |                                                     |                |       |                    |       |                      |       |
| Apartment Units         |                      |              |             |                                                     |                |       |                    |       |                      |       |
| Studio                  |                      | 56           | 78          | 280                                                 | 15.2           | 0.25  | 38.1               | 0.64  | 83.8                 | 1.40  |
| 1 Bedroom               |                      | 151          | 211         | 280                                                 | 41.1           | 0.69  | 102.8              | 1.71  | 226.1                | 3.77  |
| 1 Bedroom + Study       |                      | 85           | 179         | 280                                                 | 34.7           | 0.58  | 86.8               | 1.45  | 190.9                | 3.18  |
| 2 Bedroom               |                      | 221          | 464         | 280                                                 | 90.2           | 1.50  | 225.6              | 3.76  | 496.3                | 8.27  |
| 3 Bedroom               |                      | 30           | 93          | 280                                                 | 18.1           | 0.30  | 45.2               | 0.75  | 99.5                 | 1.66  |
| Total Building A & B    |                      | 543          | 1025        | 1400                                                | 199.4          | 3.32  | 498.5              | 8.31  | 1096.6               | 18.28 |
|                         |                      |              |             |                                                     |                |       |                    |       |                      |       |
| Total Commercial Area   | 425                  |              |             | 28000                                               | 0.8            | 0.014 | 1.2                | 0.021 | 2.2                  | 0.037 |
|                         |                      |              |             |                                                     |                |       |                    |       |                      |       |
| Total Site :            |                      | 543          | 1025        |                                                     | 200.2          | 3.3   | 499.7              | 8.3   | 1098.8               | 18.3  |

1 Population density for all residential units based on an population densities provided in Table 4.1 - Per Unit Populations of the City of Ottawa Water Distribution Design Guidelines (Dec 2025).

2 Average day water demand for residential areas: 280 L/cap/d

2 Average day water demand for commercial areas: 28,000 L/ha/d - Per Table 4.2 Consumption Rates for subdivisions of 501 to 3,000 persons (City of Ottawa Water Distribution Design Guidelines, Dec 2025)

3 The City of Ottawa water demand criteria used to estimate peak demand rates for residential areas are as follows:

maximum day demand rate = 2.5 x average day demand rate for residential

peak hour demand rate = 2.2 x maximum day demand rate for residential


4 Water demand criteria used to estimate peak demand rates for amenity/common areas are as follows:

maximum daily demand rate = 1.5 x average day demand rate

peak hour demand rate = 1.8 x maximum day demand rate

**Reference:** Functional Site Servicing Review – 35 Laurel Street (Previously 75 Breezehill Avenue North): Building Height Increase Memorandum

## **B.2 FUS Calculations**



|        |                                                                                                                                                                                                                                                                                 |                  |                |            |
|--------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|----------------|------------|
| Notes: | Stantec Project #:                                                                                                                                                                                                                                                              | 160401738        | Created By:    | P. Mott    |
|        | Project Name:                                                                                                                                                                                                                                                                   | 35 Laurel Street | Revision No.:  | 3          |
|        | Date Created:                                                                                                                                                                                                                                                                   | 9/27/2023        | Revised By:    | Z. Wang    |
|        | Fire Flow Calculation #:                                                                                                                                                                                                                                                        | 1                | Revision Date: | 7/7/2026   |
|        | Description:                                                                                                                                                                                                                                                                    | Building A       | Checked By:    | A. Gladish |
|        | Building A: 31-storey residential high-rise with indoor amenities. Largest floor area Levels 3-6. Information taken from Site Plan by RLA architecture dated February 16, 2026. Sprinklered with floor assemblies / load bearing walls as 1hr rated assemblies per OBC 3.2.2.52 |                  |                |            |

| Step | Task                                        | Notes                                                                        |                       |                    |                          |                                    |                                  |       |                          |       |       | Value Used | Req'd Fire Flow (L/min) |
|------|---------------------------------------------|------------------------------------------------------------------------------|-----------------------|--------------------|--------------------------|------------------------------------|----------------------------------|-------|--------------------------|-------|-------|------------|-------------------------|
| 1    | Determine Type of Construction              | Type II - Noncombustible Construction / Type IV-A - Mass Timber Construction |                       |                    |                          |                                    |                                  |       |                          |       |       | 0.8        | -                       |
| 2    | Determine Effective Floor Area              | Sum of Largest Floor + 25% of Two Additional Floors                          |                       |                    |                          |                                    | Vertical Openings Protected?     |       |                          |       |       | YES        | -                       |
|      |                                             | 1083.5                                                                       | 1083.5                | 1083.5             | 1083.5                   | 1024                               | 554.9                            | 554.9 | 554.9                    | 554.9 | 554.9 | 1625.25    | -                       |
| 3    | Determine Required Fire Flow                | (F = 220 x C x A <sup>1/2</sup> ). Round to nearest 1000 L/min               |                       |                    |                          |                                    |                                  |       |                          |       |       | -          | 7000                    |
| 4    | Determine Occupancy Charge                  | Limited Combustible                                                          |                       |                    |                          |                                    |                                  |       |                          |       |       | -15%       | 5950                    |
| 5    | Determine Sprinkler Reduction               | Conforms to NFPA 13                                                          |                       |                    |                          |                                    |                                  |       |                          |       |       | -30%       | -2975                   |
|      |                                             | Standard Water Supply                                                        |                       |                    |                          |                                    |                                  |       |                          |       |       | -10%       |                         |
|      |                                             | Fully Supervised                                                             |                       |                    |                          |                                    |                                  |       |                          |       |       | -10%       |                         |
|      |                                             | % Coverage of Sprinkler System                                               |                       |                    |                          |                                    |                                  |       |                          |       |       | 100%       |                         |
| 6    | Determine Increase for Exposures (Max. 75%) | Direction                                                                    | Exposure Distance (m) | Exposed Length (m) | Exposed Height (Stories) | Length-Height Factor (m x stories) | Construction of Adjacent Wall    |       | Firewall / Sprinklered ? |       | -     | 119        |                         |
|      |                                             | North                                                                        | 10.1 to 20            | 26                 | 2                        | 41-60                              | Type I-II - Unprotected Openings |       | YES                      |       | 0%    |            |                         |
|      |                                             | East                                                                         | > 30                  | 0                  | 0                        | 0-20                               | Type V                           |       | NO                       |       | 0%    |            |                         |
|      |                                             | South                                                                        | 10.1 to 20            | 26                 | 27                       | > 100                              | Type I-II - Protected Openings   |       | YES                      |       | 0%    |            |                         |
|      |                                             | West                                                                         | 20.1 to 30            | 17                 | 2                        | 21-49                              | Type V                           |       | NO                       |       | 2%    |            |                         |
| 7    | Determine Final Required Fire Flow          | Total Required Fire Flow in L/min, Rounded to Nearest 1000L/min              |                       |                    |                          |                                    |                                  |       |                          |       |       | 3000       |                         |
|      |                                             | Total Required Fire Flow in L/s                                              |                       |                    |                          |                                    |                                  |       |                          |       |       | 50.0       |                         |
|      |                                             | Required Duration of Fire Flow (hrs)                                         |                       |                    |                          |                                    |                                  |       |                          |       |       | 1.25       |                         |
|      |                                             | Required Volume of Fire Flow (m³)                                            |                       |                    |                          |                                    |                                  |       |                          |       |       | 225        |                         |

## FUS Fire Flow Calculation Sheet - 2020 FUS Guidelines

|        |                                                                                                                                                                                                                                                                                 |                         |
|--------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------|
| Notes: | Stantec Project #: 160401738                                                                                                                                                                                                                                                    | Created By: P. Mott     |
|        | Project Name: 35 Laurel Street                                                                                                                                                                                                                                                  | Revision No.: 3         |
|        | Date Created: 9/27/2023                                                                                                                                                                                                                                                         | Revised By: Z. Wang     |
|        | Fire Flow Calculation #: 2                                                                                                                                                                                                                                                      | Revision Date: 7/7/2026 |
|        | Description: Building B                                                                                                                                                                                                                                                         | Checked By: A. Gladish  |
|        | Building A: 31-storey residential high-rise with indoor amenities. Largest floor area Levels 3-6. Information taken from Site Plan by RLA architecture dated February 16, 2026. Sprinklered with floor assemblies / load bearing walls as 1hr rated assemblies per OBC 3.2.2.52 |                         |

| Step | Task                                        | Notes                                                                        |                       |                    |                          |                                    |                                |                          |     |     |     | Value Used | Req'd Fire Flow (L/min) |
|------|---------------------------------------------|------------------------------------------------------------------------------|-----------------------|--------------------|--------------------------|------------------------------------|--------------------------------|--------------------------|-----|-----|-----|------------|-------------------------|
| 1    | Determine Type of Construction              | Type II - Noncombustible Construction / Type IV-A - Mass Timber Construction |                       |                    |                          |                                    |                                |                          |     |     |     | 0.8        | -                       |
| 2    | Determine Effective Floor Area              | Sum of Largest Floor + 25% of Two Additional Floors                          |                       |                    |                          |                                    | Vertical Openings Protected?   |                          |     |     |     | YES        | -                       |
|      |                                             | 1060                                                                         | 1060                  | 1060               | 1060                     | 1060                               | 536                            | 536                      | 536 | 536 | 536 | 1590.5     | -                       |
| 3    | Determine Required Fire Flow                | (F = 220 x C x A <sup>1/2</sup> ). Round to nearest 1000 L/min               |                       |                    |                          |                                    |                                |                          |     |     |     | -          | 7000                    |
| 4    | Determine Occupancy Charge                  | Limited Combustible                                                          |                       |                    |                          |                                    |                                |                          |     |     |     | -15%       | 5950                    |
| 5    | Determine Sprinkler Reduction               | Conforms to NFPA 13                                                          |                       |                    |                          |                                    |                                |                          |     |     |     | -30%       | -2975                   |
|      |                                             | Standard Water Supply                                                        |                       |                    |                          |                                    |                                |                          |     |     |     | -10%       |                         |
|      |                                             | Fully Supervised                                                             |                       |                    |                          |                                    |                                |                          |     |     |     | -10%       |                         |
|      |                                             | % Coverage of Sprinkler System                                               |                       |                    |                          |                                    |                                |                          |     |     |     | 100%       |                         |
| 6    | Determine Increase for Exposures (Max. 75%) | Direction                                                                    | Exposure Distance (m) | Exposed Length (m) | Exposed Height (Stories) | Length-Height Factor (m x stories) | Construction of Adjacent Wall  | Firewall / Sprinklered ? | -   | -   |     |            |                         |
|      |                                             | North                                                                        | 10.1 to 20            | 26                 | 27                       | > 100                              | Type I-II - Protected Openings | YES                      | 0%  | 952 |     |            |                         |
|      |                                             | East                                                                         | > 30                  | 0                  | 0                        | 0-20                               | Type V                         | NO                       | 0%  |     |     |            |                         |
|      |                                             | South                                                                        | > 30                  | 0                  | 0                        | 0-20                               | Type V                         | NO                       | 0%  |     |     |            |                         |
|      |                                             | West                                                                         | 3.1 to 10             | 18                 | 2                        | 21-49                              | Type V                         | NO                       | 16% |     |     |            |                         |
| 7    | Determine Final Required Fire Flow          | Total Required Fire Flow in L/min, Rounded to Nearest 1000L/min              |                       |                    |                          |                                    |                                |                          |     |     |     | 4000       |                         |
|      |                                             | Total Required Fire Flow in L/s                                              |                       |                    |                          |                                    |                                |                          |     |     |     | 66.7       |                         |
|      |                                             | Required Duration of Fire Flow (hrs)                                         |                       |                    |                          |                                    |                                |                          |     |     |     | 1.50       |                         |
|      |                                             | Required Volume of Fire Flow (m³)                                            |                       |                    |                          |                                    |                                |                          |     |     |     | 360        |                         |

**Reference:** Functional Site Servicing Review – 35 Laurel Street (Previously 75 Breezehill Avenue North): Building Height Increase Memorandum

## **B.3 Boundary Conditions**

## Gladish, Alyssa

---

**From:** Mottalib, Abdul <Abdul.Mottalib@ottawa.ca>  
**Sent:** Tuesday, November 14, 2023 4:41 PM  
**To:** Gladish, Alyssa  
**Cc:** Mottalib, Abdul; McCreight, Andrew  
**Subject:** FW: Sanitary Sewer Capacity & Updated Boundary Conditions  
**Attachments:** 75 Breezehill Ave North November 2023.pdf

You don't often get email from [abdul.mottalib@ottawa.ca](mailto:abdul.mottalib@ottawa.ca). [Learn why this is important](#)

Please see the email below.

--

Thanks,

Abdul  
Mohammad Abdul Mottalib, P. Eng.  
Extension: 27798

---

**From:** ...  
**Sent:** November 14, 2023 10:41 AM  
**To:** Mottalib, Abdul <Abdul.Mottalib@ottawa.ca>  
**Cc:** .....  
**Subject:** RE: Sanitary Sewer Capacity & Updated Boundary Conditions

Good morning Abdul,

The following are boundary conditions, HGL, for hydraulic analysis at 75 Breezehill Avenue North, (zone 1W) assumed to be a dual connection to the 203 mm watermain on Laurel Street (see attached PDF for location).

Minimum HGL: 107.4 m

Maximum HGL: 115.1 m

Maximum Day + Fire Flow (67 L/s): 104.3 m

These are for current conditions and are based on computer model simulation.

*Disclaimer: The boundary condition information is based on current operation of the city water distribution system. The computer model simulation is based on the best information available at the time. The operation of the water distribution system can change on a regular basis, resulting in a variation in boundary conditions. The physical properties of watermains deteriorate over time, as such must be assumed in the absence of actual field test data. The variation in physical watermain properties can therefore alter the results of the computer model simulation.*

---

**From:** Mott, Peter  
**Sent:** Wednesday, October 11, 2023 5:07 PM  
**To:** Mottalib, Abdul <[Abdul.Mottalib@ottawa.ca](mailto:Abdul.Mottalib@ottawa.ca)>  
**Cc:** Gladish, Alyssa <[Alyssa.Gladish@stantec.com](mailto:Alyssa.Gladish@stantec.com)>  
**Subject:** Sanitary Sewer Capacity & Updated Boundary Conditions

Good afternoon Abdul,

### **Sanitary Servicing**

As part of the functional servicing for the proposed development on 75 Breezehill Avenue North, we would like to confirm if there is sufficient capacity within the receiving 300 mm diameter sanitary sewer within Breezehill Avenue North to receive an additional peak flow of **13.0 L/s** from the proposed development, based on site plan updates. I don't imagine that this marginal increase should have any impact on your capacity analysis, but wanted your confirmation as outlined in the pre-consultation. Please find our sanitary design sheet and location map attached for your information.

### **Water Servicing**

Additionally, we would like to request updated boundary conditions based on the changes to the unit count for the development. Please find attached the key map showing the location of the proposed development with the identified connection locations, domestic water demand calculations, fire flow calculations, a conceptual site plan, and the fire hydrant coverage map with associated tables to demonstrate adequate emergency flow for the proposed development.

A summary of the proposed site is provided below:

We anticipate two (2) connection to service the development: two connections to the existing 203 mm diameter watermain within Laurel Street. The following connection is expected for servicing:

➤ Connections (2) to the existing 203 mm watermain on Laurel Street (Existing).

**For the purpose of the boundary conditions request, may you please provide us with the boundary conditions for the following servicing options:**

- i. Watermain connections to the above listed connections; assuming a fire flow requirement of **4,000 L/min (67 L/s)** for the site in addition to the domestic water demands provided below.
  - The intended land use is a combination of residential and commercial/mixed use per the summary provided in the Domestic Demands spreadsheet.
  - Estimated fire flow demand per the FUS methodology: 4,000 L/min (67 L/s) for the worst-case scenario (Building A)
  - Domestic water demands for the entire development:
    - **Average day: 201.0 L/min (3.35 L/s)**
    - **Maximum day: 501.5 L/min (8.36 L/s)**
    - **Peak hour: 1102.6 L/min (18.38 L/s)**

Thank you for your time and please contact me at your earliest convenience if any additional information or clarification is required.

Best regards,

**Peter Mott** EIT

Engineering Intern, Community Development

Mobile: +1 (613) 897-0445

Teams: +1 (613) 724-4370

Peter.Mott@stantec.com

Stantec

300 - 1331 Clyde Avenue

Ottawa ON K2C 3G4



This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

**Caution:** This email originated from outside of Stantec. Please take extra precaution.

**Attention:** Ce courriel provient de l'extérieur de Stantec. Veuillez prendre des précautions supplémentaires.

**Atención:** Este correo electrónico proviene de fuera de Stantec. Por favor, tome precauciones adicionales.

## Gladish, Alyssa

---

**From:** Wu, John <John.Wu@ottawa.ca>  
**Sent:** Monday, November 4, 2024 11:22 AM  
**To:** Gladish, Alyssa  
**Cc:** Wessel, Shawn  
**Subject:** 35 Laurel Street (previously 75 Breezehill Avenue North) - File No. PC2024-0132

No changes for the BC.

**John Wu**, P.Eng.

Senior Engineer, Infrastructure Approval

Development Review (Urban Services)

Ingenieur Principal, Approbation de L'infrastructure

Examen des projects d'aménagement (Services urbains)

Planning, Infrastructure and Economic Development Department

Services de planification, d'infrastructure et de développement économique

City of Ottawa | Ville d'Ottawa

110 Laurier Avenue West. Ottawa, ON | 110, avenue. Laurier Ouest. Ottawa (Ontario) K1P 1J1

613.580.2424 ext./poste 27734, fax/téléc:613-560-6006, john.wu@ottawa.ca

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

**Caution:** This email originated from outside of Stantec. Please take extra precaution.

**Attention:** Ce courriel provient de l'extérieur de Stantec. Veuillez prendre des précautions supplémentaires.

**Atención:** Este correo electrónico proviene de fuera de Stantec. Por favor, tome precauciones adicionales.

## Gladish, Alyssa

---

**From:** Wessel, Shawn <shawn.wessel@ottawa.ca>  
**Sent:** Friday, November 1, 2024 5:07 PM  
**To:** Gladish, Alyssa  
**Subject:** RE: 35 Laurel Street (previously 75 Breezehill Avenue North) - File No. PC2024-0132

Thanks Alyssa

I have forwarded to our Water Dept. for comment.

As I am away, please contact John Wu at [John.Wu@ottawa.ca](mailto:John.Wu@ottawa.ca) as I have asked them to send to him in the interim.

Have a nice weekend.

**Please be advised that I will be away Nov 4-12 inclusive. Please contact the City File Lead or Sr. Engineer in my absence.**

*Regards,*

**Shawn Wessel, A.Sc.T.,rcji**

Pronouns: he/him | Pronom: il

**Project Manager - Infrastructure Approvals**

**Gestionnaire de projet – Approbation des demandes d'infrastructures**

Development Review Central Branch | Direction de l'examen des projets d'aménagement, Centrale  
Planning, Development & Building Services Department (PDBS) | Direction générale des services de la planification, de l'aménagement et du bâtiment (DGSPAB)

City of Ottawa | Ville d'Ottawa

110 Laurier Ave. W. | 110, avenue Laurier Ouest, Ottawa ON K1P 1J1

(613) 580 2424 Ext. | Poste 33017

Int. Mail Code | Code de Courrier Interne 01-14

[shawn.wessel@ottawa.ca](mailto:shawn.wessel@ottawa.ca)

 Please consider the environment before printing this email

**\*\*\*Please also note that, while my work hours may be affected by the current situation and am working from home, I still have access to email, video conferencing and telephone. Feel free to schedule video conferences and/or telephone calls, as necessary.\*\*\***

---

**From:** Gladish, Alyssa <Alyssa.Gladish@stantec.com>  
**Sent:** Friday, November 1, 2024 4:10 PM

To: Wessel, Shawn <shawn.wessel@ottawa.ca>

Subject: RE: 35 Laurel Street (previously 75 Breezehill Avenue North) - File No. PC2024-0132

**CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.**

**ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.**

Hello Shawn,

Thank you. I appreciate the prompt response regarding the sanitary servicing.

Regarding the water servicing:

1. Domestic **water demands** have decreased from the previous submission and required fire flow remains unchanged at 4,000 L/min (67 L/s).

|                   | Demand Type       | Population  | Area (ha)   | AVDY (L/s)   | MXDY (L/s)   | PKHR (L/s)   |
|-------------------|-------------------|-------------|-------------|--------------|--------------|--------------|
| 1st Submission    | Commercial        |             | 0.04        | 0.01         | 0.02         | 0.04         |
|                   | Residential       | 1028        | -           | 3.34         | 8.33         | 17.9         |
|                   | <b>Total Site</b> | <b>1028</b> | <b>0.04</b> | <b>3.35</b>  | <b>8.35</b>  | <b>18.4</b>  |
| 2nd Submission    | Commercial        |             | 0.04        | 0.01         | 0.02         | 0.04         |
|                   | Residential       | 911         | -           | 2.95         | 7.38         | 16.23        |
|                   | <b>Total Site</b> | <b>911</b>  | <b>0.04</b> | <b>2.96</b>  | <b>7.4</b>   | <b>16.27</b> |
| <b>Difference</b> | <b>Total Site</b> | <b>-117</b> | <b>0</b>    | <b>-0.39</b> | <b>-0.95</b> | <b>-2.13</b> |

Since the domestic water demands have decreased, and fire flow remains unchanged, please confirm that the boundary conditions received Nov 14, 2023, (attached) are sufficient for the current submission.

Thank you very much and wishing you also have an excellent weekend.

Sincerely,  
Alyssa

**Alyssa Gladish** E.I.T.  
Project Manager, Community Development

Direct: 780 917-8567  
Mobile: 587 721-1241  
Alyssa.Gladish@stantec.com

Stantec  
300-1331 Clyde Avenue  
Ottawa ON K2C 3G4



The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.

From: Wessel, Shawn <shawn.wessel@ottawa.ca>

Sent: Friday, November 1, 2024 3:37 PM

**Reference:** Functional Site Servicing Review – 35 Laurel Street (Previously 75 Breezehill Avenue North): Building Height Increase Memorandum

## **Appendix C** Functional Sanitary Servicing

### **C.1 Sanitary Sewer Calculation Sheet**

|                                                                                             |                                                                      |                                                |                                                                                                                 |       |     |                               |    |                     |       |                      |                                  |      |                |                              |                                      |       |               |       |                           |       |       |       |              |       |       |       |       |       |      |       |     |       |        |         |      |       |        |      |      |  |          |  |       |  |        |  |           |  |        |  |        |  |      |  |
|---------------------------------------------------------------------------------------------|----------------------------------------------------------------------|------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|-------|-----|-------------------------------|----|---------------------|-------|----------------------|----------------------------------|------|----------------|------------------------------|--------------------------------------|-------|---------------|-------|---------------------------|-------|-------|-------|--------------|-------|-------|-------|-------|-------|------|-------|-----|-------|--------|---------|------|-------|--------|------|------|--|----------|--|-------|--|--------|--|-----------|--|--------|--|--------|--|------|--|
| <div></div> | SUBDIVISION:<br><b>35 LAUREL STREET<br/>BUILDING HEIGHT INCREASE</b> |                                                | <div><b>SANITARY SEWER<br/>DESIGN SHEET</b><br/>(City of Ottawa)</div> <div><b>FILE NUMBER:</b> 160402328</div> |       |     |                               |    |                     |       |                      | DESIGN PARAMETERS                |      |                |                              |                                      |       |               |       |                           |       |       |       |              |       |       |       |       |       |      |       |     |       |        |         |      |       |        |      |      |  |          |  |       |  |        |  |           |  |        |  |        |  |      |  |
|                                                                                             | REVISION DATE: 7/7/2026                                              |                                                |                                                                                                                 |       |     |                               |    |                     |       |                      | MAX PEAK FACTOR (RES.)= 4.0      |      |                |                              | AVG. DAILY FLOW / PERSON 280 l/p/day |       |               |       | MINIMUM VELOCITY 0.60 m/s |       |       |       |              |       |       |       |       |       |      |       |     |       |        |         |      |       |        |      |      |  |          |  |       |  |        |  |           |  |        |  |        |  |      |  |
|                                                                                             | REVISION NO.: 3                                                      |                                                |                                                                                                                 |       |     |                               |    |                     |       |                      | MIN PEAK FACTOR (RES.)= 2.0      |      |                |                              | COMMERCIAL 28,000 l/ha/day           |       |               |       | MAXIMUM VELOCITY 3.00 m/s |       |       |       |              |       |       |       |       |       |      |       |     |       |        |         |      |       |        |      |      |  |          |  |       |  |        |  |           |  |        |  |        |  |      |  |
|                                                                                             | DESIGNED BY: PM                                                      |                                                |                                                                                                                 |       |     |                               |    |                     |       |                      | PEAKING FACTOR (INDUSTRIAL): 2.4 |      |                |                              | INDUSTRIAL (HEAVY) 55,000 l/ha/day   |       |               |       | MANNINGS n 0.013          |       |       |       |              |       |       |       |       |       |      |       |     |       |        |         |      |       |        |      |      |  |          |  |       |  |        |  |           |  |        |  |        |  |      |  |
|                                                                                             | REVISED BY: ZW                                                       |                                                |                                                                                                                 |       |     |                               |    |                     |       |                      | PEAKING FACTOR (ICI >20%): 1.5   |      |                |                              | INDUSTRIAL (LIGHT) 35,000 l/ha/day   |       |               |       | BEDDING CLASS B           |       |       |       |              |       |       |       |       |       |      |       |     |       |        |         |      |       |        |      |      |  |          |  |       |  |        |  |           |  |        |  |        |  |      |  |
| CHECKED BY: AG                                                                              |                                                                      | PERSONS / 1 BEDROOM & STUDIO 1.4               |                                                                                                                 |       |     | INSTITUTIONAL 28,000 l/ha/day |    |                     |       | MINIMUM COVER 2.50 m |                                  |      |                | HARMON CORRECTION FACTOR 0.8 |                                      |       |               |       |                           |       |       |       |              |       |       |       |       |       |      |       |     |       |        |         |      |       |        |      |      |  |          |  |       |  |        |  |           |  |        |  |        |  |      |  |
|                                                                                             |                                                                      | PERSONS / 2 BEDROOM & 1 BEDROOM WITH STUDY 2.1 |                                                                                                                 |       |     | INFILTRATION 0.33 l/s/ha      |    |                     |       |                      |                                  |      |                |                              |                                      |       |               |       |                           |       |       |       |              |       |       |       |       |       |      |       |     |       |        |         |      |       |        |      |      |  |          |  |       |  |        |  |           |  |        |  |        |  |      |  |
|                                                                                             |                                                                      | PERSONS / 3 BEDROOM 3.1                        |                                                                                                                 |       |     |                               |    |                     |       |                      |                                  |      |                |                              |                                      |       |               |       |                           |       |       |       |              |       |       |       |       |       |      |       |     |       |        |         |      |       |        |      |      |  |          |  |       |  |        |  |           |  |        |  |        |  |      |  |
| LOCATION                                                                                    |                                                                      |                                                | RESIDENTIAL AREA AND POPULATION                                                                                 |       |     |                               |    |                     |       |                      | COMMERCIAL                       |      | INDUSTRIAL (L) |                              | INDUSTRIAL (H)                       |       | INSTITUTIONAL |       | GREEN / UNUSED            |       | C+H   |       | INFILTRATION |       |       | TOTAL | PIPE  |       |      |       |     |       |        |         |      |       |        |      |      |  |          |  |       |  |        |  |           |  |        |  |        |  |      |  |
| AREA ID                                                                                     |                                                                      | FROM                                           | TO                                                                                                              | AREA  |     | UNITS                         |    | POP.                |       | CUMULATIVE           |                                  | PEAK |                | PEAK                         |                                      | AREA  |               | ACCU. |                           | AREA  |       | ACCU. |              | AREA  |       | ACCU. |       | PEAK  |      | TOTAL |     | ACCU. |        | INFILT. |      | FLOW  | LENGTH |      | DIA  |  | MATERIAL |  | CLASS |  | SLOPE  |  | CAP.      |  | CAP. V |  | VEL.   |  | VEL. |  |
| NUMBER                                                                                      |                                                                      | M.H.                                           |                                                                                                                 | M.H.  |     | 1 BED & STUDIO                |    | 2 BED & 1BED +STUDY |       | 3 BED                |                                  | AREA |                | POP.                         |                                      | FACT. |               | FLOW  |                           | AREA  |       | AREA  |              | AREA  |       | AREA  |       | AREA  |      | AREA  |     | AREA  |        | AREA    |      | FLOW  |        |      |      |  |          |  |       |  | (FULL) |  | PEAK FLOW |  | (FULL) |  | (ACT.) |  |      |  |
|                                                                                             |                                                                      |                                                |                                                                                                                 |       |     | (ha)                          |    |                     |       |                      |                                  | (ha) |                |                              |                                      | (l/s) |               |       |                           | (ha)  |       | (ha)  |              | (ha)  |       | (ha)  |       | (ha)  |      | (ha)  |     | (ha)  |        | (l/s)   |      | (l/s) | (m)    |      | (mm) |  |          |  | (%)   |  | (l/s)  |  | (%)       |  | (m/s)  |  | (m/s)  |  |      |  |
| BLDG A, BLDG B                                                                              |                                                                      | BLDG B                                         | SAN 1                                                                                                           | 0.255 | 207 | 306                           | 30 | 1025                | 0.255 | 1025                 | 3.234                            | 10.7 | 0.043          | 0.043                        | 0.000                                | 0.000 | 0.000         | 0.000 | 0.000                     | 0.000 | 0.000 | 0.000 | 0.000        | 0.000 | 0.000 | 0.021 | 0.255 | 0.255 | 0.1  | 10.9  | 2.6 | 200   | PVC    | SDR 35  | 1.24 | 37.2  | 29.1%  | 1.17 | 0.86 |  |          |  |       |  |        |  |           |  |        |  |        |  |      |  |
| G1A                                                                                         |                                                                      | SAN1                                           | EXISTING                                                                                                        | 0.362 | 0   | 0                             | 0  | 0                   | 0.617 | 1025                 | 3.234                            | 10.7 | 0.000          | 0.043                        | 0.000                                | 0.000 | 0.000         | 0.000 | 0.000                     | 0.000 | 0.000 | 0.000 | 0.000        | 0.000 | 0.021 | 0.362 | 0.617 | 0.2   | 11.0 | 1.5   | 200 | PVC   | SDR 35 | 1.04    | 34.1 | 32.2% | 1.07   | 0.80 |      |  |          |  |       |  |        |  |           |  |        |  |        |  |      |  |

Notes:

1. Unit counts taken from RLA Architecture Site Plan provided on February 16, 2026

2. Studio apartments assumed to have ppu of 1.4; One bedroom assumed to have ppu of 1.4; One bedroom with study assumed to have ppu of 2.1

3. See Figure FIG-2 for functional sanitary drainage plan

**Reference:** Functional Site Servicing Review – 35 Laurel Street (Previously 75 Breezehill Avenue North): Building Height Increase Memorandum

## **C.2 Correspondence for Downstream Sewer Capacity**

## Gladish, Alyssa

---

**From:** Wessel, Shawn <shawn.wessel@ottawa.ca>  
**Sent:** Friday, November 1, 2024 3:37 PM  
**To:** Gladish, Alyssa  
**Subject:** RE: 35 Laurel Street (previously 75 Breezehill Avenue North) - File No. PC2024-0132

My apologies Alyssa

As there are no other options and Laurel is the preferred option, a connection to that Trunk Sewer on Laurel is acceptable.

For some reason I thought that one was a local sewer there also.

Sorry about the confusion.

Have a nice weekend!

**Please be advised that I will be away Nov 4-12 inclusive. Please contact the City File Lead or Sr. Engineer in my absence.**

*Regards,*

**Shawn Wessel, A.Sc.T.,rcji**

Pronouns: he/him | Pronom: il

**Project Manager - Infrastructure Approvals**

**Gestionnaire de projet – Approbation des demandes d'infrastructures**

Development Review Central Branch | Direction de l'examen des projets d'aménagement, Centrale  
Planning, Development & Building Services Department (PDBS) | Direction générale des services de la planification, de l'aménagement et du bâtiment (DGSPAB)

City of Ottawa | Ville d'Ottawa

110 Laurier Ave. W. | 110, avenue Laurier Ouest, Ottawa ON K1P 1J1

(613) 580 2424 Ext. | Poste 33017

Int. Mail Code | Code de Courrier Interne 01-14

[shawn.wessel@ottawa.ca](mailto:shawn.wessel@ottawa.ca)



Please consider the environment before printing this email

**\*\*\*Please also note that, while my work hours may be affected by the current situation and am working from home, I still have access to email, video conferencing and telephone. Feel free to schedule video conferences and/or telephone calls, as necessary.\*\*\***

---

**From:** Gladish, Alyssa <Alyssa.Gladish@stantec.com>  
**Sent:** Friday, November 1, 2024 2:19 PM  
**To:** Wessel, Shawn <shawn.wessel@ottawa.ca>  
**Subject:** RE: 35 Laurel Street (previously 75 Breezehill Avenue North) - File No. PC2024-0132

**CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.**

**ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.**

Hello Shawn,


Thank you for your email.

1. Can you please also provide a response for question #1 below?
2. Sanitary:

Thank you for re-confirming the downstream sanitary sewer capacity.

Thank you for confirming that a sanitary connection to Laurel is the preferred option to avoid encumbering the parkland area, which fronts Breezehill Avenue. This was my understanding from our meeting September 23, 2024.

During the September 23, 2024 meeting you indicated that Asset Management was allowing for the connection to the trunk sewer for this site, because we have to make the sanitary connection to Laurel Street to avoid encumbering the parkland, the trunk sewer has the capacity to receive the projected flows and because there are no local sanitary sewers in Laurel Street (it is the only pipe available). Please confirm this is correct, and that we may proceed with the sanitary servicing design.



Thank you kindly for your time,  
Alyssa

**Alyssa Gladish** E.I.T.  
Project Manager, Community Development

Direct: 780 917-8567  
Mobile: 587 721-1241  
Alyssa.Gladish@stantec.com

Stantec  
300-1331 Clyde Avenue  
Ottawa ON K2C 3G4



The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.

---

**From:** Wessel, Shawn <[shawn.wessel@ottawa.ca](mailto:shawn.wessel@ottawa.ca)>  
**Sent:** Friday, November 1, 2024 1:57 PM  
**To:** Gladish, Alyssa <[Alyssa.Gladish@stantec.com](mailto:Alyssa.Gladish@stantec.com)>  
**Subject:** RE: 35 Laurel Street (previously 75 Breezhill Avenue North) - File No. PC2024-0132

Hi Alyssa

Laurel is the preferred option, due to Park location and local sewer available, in case I didn't make that clear.

Have a nice weekend!

Thank you

**Please be advised that I will be away Nov 4-12 inclusive. Please contact the City File Lead or Sr. Engineer in my absence.**

*Regards,*

**Shawn Wessel, A.Sc.T.,rcji**

Pronouns: he/him | Pronom: il

**Project Manager - Infrastructure Approvals**

**Gestionnaire de projet – Approbation des demandes d'infrastructures**

Development Review Central Branch | Direction de l'examen des projets d'aménagement, Centrale  
Planning, Development & Building Services Department (PDBS) | Direction générale des services de la planification, de l'aménagement et du bâtiment (DGSPAB)  
City of Ottawa | Ville d'Ottawa  
110 Laurier Ave. W. | 110, avenue Laurier Ouest, Ottawa ON K1P 1J1  
(613) 580 2424 Ext. | Poste 33017  
Int. Mail Code | Code de Courrier Interne 01-14  
[shawn.wessel@ottawa.ca](mailto:shawn.wessel@ottawa.ca)

Please consider the environment before printing this email

**\*\*\*Please also note that, while my work hours may be affected by the current situation and am working from home, I still have access to email, video conferencing and telephone. Feel free to schedule video conferences and/or telephone calls, as necessary.\*\*\***

---

**From:** Wessel, Shawn  
**Sent:** Friday, November 1, 2024 1:50 PM  
**To:** Gladish, Alyssa <[Alyssa.Gladish@stantec.com](mailto:Alyssa.Gladish@stantec.com)>  
**Subject:** RE: 35 Laurel Street (previously 75 Breezehill Avenue North) - File No. PC2024-0132

Hello Alyssa

From discussions with Nishant, who is now with the modeling group with Eric Tousignant, I have been asked to relay the following:

Either of the two local sewers (300 mm) are to be used and the trunk sewer is to be avoided. There is ample capacity in both. Trunk sewer is deep, a critical asset and Asset Management will only allow connection under certain circumstances, one being the only sewer available and is on a case-by-case basis, always. No sanitary capacity concerns on Laurel or Breezehill for the proposed 9.8L/s

A park is proposed for N/W corner of property and next to ROW. Parks do not permit servicing infrastructure within their park lands and generally do not want any SWM works within said lands.

If you require additional information or clarification, please do not hesitate to contact me anytime.

Thank you

**Please be advised that I will be away Nov 4-12 inclusive. Please contact the City File Lead or Sr. Engineer in my absence.**

*Regards,*

**Shawn Wessel, A.Sc.T.,rcji**

Pronouns: he/him | Pronom: il

**Project Manager - Infrastructure Approvals**

**Gestionnaire de projet – Approbation des demandes d’infrastructures**

Development Review Central Branch | Direction de l’examen des projets d’aménagement, Centrale  
Planning, Development & Building Services Department (PDBS) | Direction générale des services de la planification, de l’aménagement et du bâtiment (DGSPAB)

City of Ottawa | Ville d'Ottawa

110 Laurier Ave. W. | 110, avenue Laurier Ouest, Ottawa ON K1P 1J1

(613) 580 2424 Ext. | Poste 33017

Int. Mail Code | Code de Courrier Interne 01-14

[shawn.wessel@ottawa.ca](mailto:shawn.wessel@ottawa.ca)

 Please consider the environment before printing this email

**\*\*\*Please also note that, while my work hours may be affected by the current situation and am working from home, I still have access to email, video conferencing and telephone. Feel free to schedule video conferences and/or telephone calls, as necessary.\*\*\***

**From:** Gladish, Alyssa <[Alyssa.Gladish@stantec.com](mailto:Alyssa.Gladish@stantec.com)>

**Sent:** Monday, October 28, 2024 2:37 PM

**To:** Wessel, Shawn <[shawn.wessel@ottawa.ca](mailto:shawn.wessel@ottawa.ca)>

**Subject:** 35 Laurel Street (previously 75 Breezehill Avenue North) - File No. PC2024-0132

**Importance:** High

**CAUTION: This email originated from an External Sender. Please do not click links or open attachments unless you recognize the source.**

**ATTENTION : Ce courriel provient d'un expéditeur externe. Ne cliquez sur aucun lien et n'ouvrez pas de pièce jointe, excepté si vous connaissez l'expéditeur.**

Hello Shawn,

I wanted to follow-up with you regarding the 35 Laurel Street development (previously 75 Breezehill Avenue North) – City of Ottawa File No. PC2024-0132.

1. Domestic **water demands** have decreased from the previous submission and required fire flow remains unchanged at 4,000 L/min (67 L/s).

|                   | Demand Type       | Population  | Area (ha)   | AVDY (L/s)   | MXDY (L/s)   | PKHR (L/s)   |
|-------------------|-------------------|-------------|-------------|--------------|--------------|--------------|
| 1st Submission    | Commercial        |             | 0.04        | 0.01         | 0.02         | 0.04         |
|                   | Residential       | 1028        | -           | 3.34         | 8.33         | 17.9         |
|                   | <b>Total Site</b> | <b>1028</b> | <b>0.04</b> | <b>3.35</b>  | <b>8.35</b>  | <b>18.4</b>  |
| 2nd Submission    | Commercial        |             | 0.04        | 0.01         | 0.02         | 0.04         |
|                   | Residential       | 911         | -           | 2.95         | 7.38         | 16.23        |
|                   | <b>Total Site</b> | <b>911</b>  | <b>0.04</b> | <b>2.96</b>  | <b>7.4</b>   | <b>16.27</b> |
| <b>Difference</b> | <b>Total Site</b> | <b>-117</b> | <b>0</b>    | <b>-0.39</b> | <b>-0.95</b> | <b>-2.13</b> |

- a) Since the domestic water demands have decreased, and fire flow remains unchanged, please confirm that the boundary conditions received for the first submission (Nov 14, 2023, attached) are sufficient for the current submission.
2. **Sanitary** peak flows have decreased from 11.1 L/s to 9.8L/s from the first to the current submission, respectively.
    - a. Please confirm that the 1050mm diameter concrete collector sewer on Laurel Street and the downstream infrastructure has the capacity to receive the proposed 9.8 L/s peak sanitary flows for the proposed development.
    - b. Please confirm in writing that the servicing connection to the 1050mm diameter concrete collector sewer on Laurel Street is the preferred sanitary servicing connection option.
    - c. The construction drawings indicate that a sanitary sewer lateral was connected to the 1050 mm sewer during the upgrade work completed in 2023-2024 (highlighted yellow in the second PDF attached). Do you have any information regarding the size, material, and invert of this lateral?

Thank you,  
Alyssa

**Alyssa Gladish** E.I.T.  
Project Manager, Community Development

Direct: 780 917-8567  
Mobile: 587 721-1241  
Alyssa.Gladish@stantec.com

Stantec  
300-1331 Clyde Avenue  
Ottawa ON K2C 3G4



The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

**Caution:** This email originated from outside of Stantec. Please take extra precaution.

**Attention:** Ce courriel provient de l'extérieur de Stantec. Veuillez prendre des précautions supplémentaires.

**Atención:** Este correo electrónico proviene de fuera de Stantec. Por favor, tome precauciones adicionales.

This e-mail originates from the City of Ottawa e-mail system. Any distribution, use or copying of this e-mail or the information it contains by other than the intended recipient(s) is unauthorized. Thank you.

Le présent courriel a été expédié par le système de courriels de la Ville d'Ottawa. Toute distribution, utilisation ou reproduction du courriel ou des renseignements qui s'y trouvent par une personne autre que son destinataire prévu est interdite. Je vous remercie de votre collaboration.

**Caution:** This email originated from outside of Stantec. Please take extra precaution.

**Attention:** Ce courriel provient de l'extérieur de Stantec. Veuillez prendre des précautions supplémentaires.

**Atención:** Este correo electrónico proviene de fuera de Stantec. Por favor, tome precauciones adicionales.