







CURB TYPE AND PAVEMENT DESIGN TABLE		
STREET NAME	CURB TYPE	PAVEMENT DESIGN
PRIVATE ROAD 1 (EAST SIDE) (STA. 0+16.391 TO STA. 0+079.112) (STA. 0+130.000 TO STA. 0+192.705) PRIVATE ROAD 1 (WEST SIDE) (STA. 0+130.000 TO STA. 0+192.705) PRIVATE ROAD 2 (EAST SIDE) (STA. 0+015.240 TO STA. 0+071.420) PRIVATE ROAD 2 (WEST SIDE) (STA. 0+015.290 TO STA. 0+077.177) (STA. 0+153.617 TO STA. 0+209.797) PRIVATE ROAD 3 (EAST SIDE) (STA. 0+015.240 TO STA. 0+071.424) PRIVATE ROAD 3 (WEST SIDE) (STA. 0+015.240 TO STA. 0+071.420)	CONCRETE MOUNTABLE CURB	SC1.3  40mm SUPERPAVE 12.5 ASPHALT CONCRETE 50mm SUPERPAVE 19.0 ASPHALT CONCRETE 150mm OPSS GRANULAR A CRUSHED STONE 400mm OPSS GRANULAR B TYPE II
PRIVATE ROAD 1 PRIVATE ROAD 2 PRIVATE ROAD 3	CONCRETE BARRIER CURB	SC1.1

**NOTE RE: PAVEMENT DESIGN**  
FOR PAVEMENT STRUCTURAL DESIGN,  
REFER TO GEOTECHNICAL REPORT  
No. P65858-1 DATED JULY 5, 2021,  
PREPARED BY PATERSON GROUP  
INC.



STREET NAME	CATCHBASIN ID	OUTLET PIPE				TOP OF GRATE (m)	GRATING COVER	INVERT	
		DIA. (mm)	TYPE	LENGTH (m)	INV. DEPTH (m)			INLET	OUTLET
PRIVATE ROAD 1	DCB 1	300	PVC	1.00	1.38	107.86	S19 PERFORATED	-	106.48
PRIVATE ROAD 1	DCB 2	375	PVC	6.50	1.38	108.04	S19 PERFORATED	-	106.66
PRIVATE ROAD 1	CB 3	200	PVC	6.00	1.38	108.01	S19 PERFORATED	-	106.63
PRIVATE ROAD 1	CB 4	200	PVC	12.50	1.38	108.23	S19 PERFORATED	-	106.85
PRIVATE ROAD 2	DCB 5	375	PVC	6.50	1.38	108.32	S19 PERFORATED	-	106.94
PRIVATE ROAD 2	DCB 6	300	PVC	3.00	1.38	108.22	S19 PERFORATED	-	106.84
PRIVATE ROAD 2	CB 9	200	PVC	4.00	1.38	108.76	S19 PERFORATED	-	107.38
PRIVATE ROAD 2	CB 10	200	PVC	4.50	1.38	108.91	S19 PERFORATED	-	107.53
PRIVATE ROAD 2	CB 11	200	PVC	11.00	1.47	108.89	S19 PERFORATED	107.49	107.43
PRIVATE ROAD 2	CB 12	200	PVC	6.50	1.38	108.73	S19 PERFORATED	-	107.35
PRIVATE ROAD 2	CB 13	200	PVC	1.50	1.51	108.73	S19 PERFORATED	107.29	107.23
PRIVATE ROAD 3	DCB 7	300	PVC	11.50	1.48	108.47	S19 PERFORATED	107.05	106.99
PRIVATE ROAD 3	CB 8	200	PVC	4.00	1.38	108.47	S19 PERFORATED	-	107.09

**NOT FOR CONSTRUCTION**

No.	BY	DATE	DESCRIPTION
1	S.L.M.	22-01-13	1st SUBMISSION

**TOPOGRAPHIC INFORMATION**  
TOPOGRAPHIC INFORMATION PROVIDED BY ANNIS, O'SULLIVAN, VOLLEBEKK LTD. PROJECT No. 22111-21 RECEIVED JUNE 24, 2021

**LEGAL INFORMATION**  
CALCULATED M-PLAN PROVIDED BY ANNIS, O'SULLIVAN, VOLLEBEKK LTD., PROJECT No. 22111-21. RECEIVED DECEMBER 13, 2021.





**BENCH MARK**  
SITE BENCHMARK #1, FIRE HYDRANT TOP OF SPINDLE  
ELEVATION = 109.78m  
SITE BENCHMARK #2, CP IN ASPHALT  
ELEVATION = 109.09

**TAMARACK HOMES** BOBOLINK RIDGE BLOCK 343

**DSEL**  
120 Iber Road Unit 103  
Slittsville, Ontario, K2S 1E9  
Tel. (613) 836-0856  
Fax. (613) 836-7183  
www.DSEL.ca

**Ottawa** 110 Laurier Ave W  
Ottawa, Ontario, K1P 1J1  
Tel. (613) 580-2400  
www.Ottawa.ca

DRAWN BY: G.G.G.		CHECKED BY: S.L.M.		PROJECT No. 21-1261	
DESIGNED BY: G.G.G.		CHECKED BY: S.L.M.		SHEET No. 3	
SCALE: N.T.S.					



CITY PLAN No. XXXXX  
CITY FILE No. D07-XX-XX-XXXX