



CHAINAGE	ELEVATIONS PROPOSED EXISTING	TOP OF WATERMAIN ELEVATION	STORM SEWER INVERTS	SANITARY SEWER INVERTS
5+000	118.07	118.71	115.20	114.77
5+020	118.62	118.70	63.8m-375mm ^Ø PVC STM @ 0.66%	76.0m-200 PVC SAN @ 0.34%
5+040	118.78	116.44	64.7m-250mm ^Ø PVC STM @ 0.43%	67.7m-200 PVC SAN @ 0.99%
5+060	118.85	116.23	115.62	115.06
5+080	118.89	116.65	115.75	115.06
5+100	118.88	117.06	117.04	115.73
5+120	118.83	117.04	117.04	115.73
5+140	118.78	116.97	116.97	115.73
5+160	118.75	117.39	117.39	115.73
5+180	118.74	117.72	117.72	115.73
5+200	118.74	118.03	118.03	115.73
5+220	118.75	118.95	118.95	115.73
5+230	118.75	119.87	119.87	115.73

CAUTION
 THE POSITION OF ALL POLE LINES, CONDUITS, WATERMANS, SEWERS AND OTHER UNDERGROUND AND OVERGROUND UTILITIES AND STRUCTURES IS NOT NECESSARILY SHOWN ON THE CONTRACT DRAWINGS, AND WHERE SHOWN, THE ACCURACY OF THE POSITION OF SUCH UTILITIES AND STRUCTURES IS NOT GUARANTEED. BEFORE STARTING WORK, DETERMINE THE EXACT LOCATION OF ALL SUCH UTILITIES AND STRUCTURES AND ASSUME ALL LIABILITY FOR DAMAGE TO THEM.

PRELIMINARY
 NOT FOR CONSTRUCTION

REV	REVISION DESCRIPTION	DATE	BY	APPD
1	SUBMISSION NO.2	04/27/21	SK	BMT

SCALE
 0 5m 10m 20m
 HORIZONTAL 1:500
 VERTICAL 1:50

DESIGNED BY
 REVIEWED BY

CLIENT
11654128 CANADA INC.
 768 BOULEVARD ST. JOSEPH
 GATINEAU, QC

exp Services Inc.
 1-877-668-1899 | 1-613-225-7330
 200 Wellington Street, Unit 100
 Ottawa, ON K2B 8H6
 Canada
 www.exp.com

• BUILDINGS • EARTH & ENVIRONMENT • ENERGY •
 • INDUSTRIAL • INFRASTRUCTURE • SUSTAINABILITY •

BASE PLAN	SK	PROJECT	6171 HAZELDEAN ROAD OTTAWA, ONTARIO.	PROJECT No.	258780
DESIGN	JLF	SURVEY			238800-FMW
CHECKED	BMT	DATE	24/07/20		
CAD	SK	TITLE	PLAN AND PROFILE STREET-5	DRAWING No.	PP08
PROJECT MANAGER	JLF				
APPROVED	BMT				