



June 19/2023

City of Ottawa
Development Review West
Planning Infrastructure and Economic Development Department

Attention: To Whom it may Concern

Re: Commercial Development
3095 Palladium Drive
Ottawa ON
Our Project No: 2023-088

This letter is to confirm that the exterior light fixtures used for this project meet the criteria For full cut-off classification as recognized by the IESNA and that the resulting light spillage onto adjacent properties is below the maximum allowable spillage of 5 Lux (0.5 FC) by City of Ottawa Standards

If you have any further Questions or require Further clarification please contact the writer as per below

Yours truly,
TRISTAR ENGINEERING

A handwritten signature in blue ink, appearing to read "Alexander Oberfeld", is written over a horizontal line.

Alexander Oberfeld, P. Eng.

AO/mlw

